

**STUDY ON RELIABILITY IMPROVEMENTS OF  
LAKVIJAYA POWER STATION RELATED TO THE  
BALANCE OF PLANT SYSTEMS: A CASE STUDY**

W. S. T. C. Wickramasinghe



(109261V)  
University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

Degree of Master of Science

Department of Electrical Engineering

University of Moratuwa

Sri Lanka

July 2014

**STUDY ON RELIABILITY IMPROVEMENTS OF  
LAKVIJAYA POWER STATION RELATED TO THE  
BALANCE OF PLANT SYSTEMS: A CASE STUDY**

WickramasingheThusharaChamindaWickramasinghe



(109261V)  
University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

Thesis/Dissertation submitted in partial fulfillment of the requirements for the degree Master  
of Science

Department of Electrical Engineering

University of Moratuwa  
Sri Lanka

July 2014

## DECLARATION

“I hereby declare that this research is my own work and this thesis/dissertation does not incorporate without acknowledgement any material previously submitted for a Degree or Diploma in any other University or institute of higher learning and to the best of my knowledge and belief it does not contain any material previously published or written by another person except where the acknowledgement is made in the text.

Further, I hereby grant to the University of Moratuwa the non-exclusive right to reproduce and distribute my thesis/dissertation, in whole or in part in print, electronic or other media. I retain the right to use the content of this thesis in whole or in part in my future activities.

.....

.....

W.S.T.C. Wickramasighe  
 University of Moratuwa, Sri Lanka  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

The above candidate has carried out research for the Masters Dissertation under my supervision.

.....

.....

Dr. Asanka Rodrigo.  
Faculty of Engineering  
University of Moratuwa

Date

## ACKNOWLEDGEMENT

First, I pay my sincere gratitude to Dr. Asanka Rodrigo who encouraged and guided me to conduct this case study and on the preparation of final dissertation.

I would like to take this opportunity to extend my sincere thanks to Mr. W.I.Dasanayake, Deputy General Manager (Information Technology Branch), Mr. M.D.NalakaKumara, Chief Engineer (Electrical Maintenance, Lakvijaya Power Station) Mr. S.L.K.Fernando, Chief Engineer (Mechanical Maintenance, LakvijayaPowerStation), Mr. R.B.Warnakulasooriya, Chemist(LakvijayaPowerStation), Mr. T.N.Walpita, Mechanical Engineer(Turbine Maintenance Section, Lakvijaya Power Station), Mr. K.N.Perera (Operation Engineer, Lakvijaya Power Station) and Mr. R.P.R.R.Ranasinghe (Operation Engineer, Lakvijaya Power Station), for their valuable assistance to conduct my research successfully.

It is a great pleasure to remember the kind co-operation extended by the colleagues in the post graduate program, who helped me to complete this dissertation.



University of Moratuwa, Sri Lanka  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)



## ABSTRACT

Lakvijaya power station is the first coal fired power station in Sri Lanka having an installed capacity of 300MW. During 2012, it has supplied 18% of the Sri Lankan energy demand. The availability factor of this power station in 2012 was 68.8%. This is rather high compared with the average availability factor of coal powered power stations in countries in the region falls between 65% - 90%. According to the contract document, the availability factor of this plant has been expected as 85% [1].

However, there is a strong public opinion created by media that the plant is unreliable and prone to frequent failures. Therefore, any improvement in the availability of the power station will result in improving the public image as well as reducing overall costs spent on more expensive fuels. This research aims at critically analyzing the Auxiliary Systems of the power plant to identify their contribution to the reduction of plant availability and propose means of improving overall availability through increasing the reliability of auxiliary systems.

Data related to outages were collected from plant operational logs and defect reports from 22.12.2010 to 09.06.2012. Existing systems and layouts were studied referring to plant operation and maintenance manuals and by field observations. Analyzing the data, it was found that failures and unsatisfactory performance in the auxiliary systems have contributed to the low availability of the power plant by delaying re-starts after failures and reducing the plant capacity while in operation.

Failures and problems in auxiliary systems such as The Sea Water Pre-Treatment System, De-salination System, De-mineralization System, Chlorination System and the Hydrogen Production and Storage System were critically analyzed during this research and improvements to the designs are proposed based on the results.

The present availability factor of 21% of the De-salination System can be improved to 91% by carrying out the proposals made by this research. The availability factor of other systems too can be improved above 90% using the results.

Estimated total cost of the proposals is Rs. 543 Million. However, by implementing them Rs. 2.7 Billion is expected to be saved annually, by reducing the operating and maintenance costs of auxiliary systems and improving the availability of the power plant. Expected payback period is only 2 ½ months. Therefore, the proposed modifications are extremely desirable and cost effective. They will make a good financial contribution due to the expected savings while improving the reliability and the public image of the power plant.

## TABLE OF CONTENTS

Declaration of the candidate & Supervisor	i
Acknowledgement	ii
Abstract	iii
Table of content	iv
List of Figures	vii
List of Tables	viii
List of abbreviations	x
List of Appendices	xii
1. Introduction	1
1.1. Background.	1
1.2. Motivation.	3
2. Problem Statement	4
2.1. Identification of the Problem.	4
2.2. Objectives of the Study.	5
3. Sea Water Intake and Pretreatment Plant	7
3.1. Introduction.	7
3.2. Calculation of Availability.	8
3.2.1. Sample Data Collection for Raw Water Pumps.	9
3.2.2. Sample Reliability Calculation for Raw Water Pump-110	
3.3. Availability of Roots Blowers in Gravity Filters.	14
3.4. Proposal for improving availability of Raw Water Pumps.	16
3.5. Proposal for changes in operation of air blowers in gravity filter.	21
3.6. Reliability factors for all raw water pumps.	22

4.	Desalination Plant	23
4.1.	Introduction to Desalination Plant.	23
4.2.	Unit Generation Cost of Water in Desalination Plant.	25
4.3.	Calculation of Availability in RO Units	26
4.4.	Calculation of Availability of UF Units.	28
4.5.	Suggestions and Calculation to Enhance the Reliability of Desalination Plant.29	
4.5.1.	Relocate of Existing VSD's.	29
4.5.2.	Dilute of Feed Water by Ground Water Source.	32
4.5.3.	Pump calculation for Eluwankulama intake	36
4.6.	Payback Period Calculation for the Proposal.	41
5.	Demineralization Plant.	43
5.1.	Introduction to Demineralization Plant (RO-2 Plant).	43
5.2.	Suggestions to Improve System Reliability.	45
6.	Chlorination Plant.	48
6.1.	Introduction of Chlorination Plant.	48
6.2.	Calculation of Availability.	49
7.	Hydrogen Plant.	57
7.1.	Introduction to Hydrogen Plant.	57
7.2.	Unit Wise Availability and Failure Rate Calculations.	58
8.	Cost Analysis	65
8.1	Cost estimation for installing new dosing pipe arrangement for Chlorination plant.	65
8.2.	Cost estimation for installing new sand filter for booster pump at Chlorination plant.	66
8.3.	Cost estimation for installing new vertical mixed flow spindle pumps for Sea water intake.	67
8.4.	Cost estimation for relocating the Existing VSDs.	68
8.5.	Cost estimation for installing of standby blower to degasified system.	69
8.6.	Cost estimation for installation of new hydrogen tanks system.	70

9.	Conclusion and Recommendations.		71
9.1.	Conclusion.	71	
9.2.	Recommendations.		73
	Reference List.	74	
	Appendix A: Fault record for RO-1 unit		75
	Appendix B: Fault record for RO-2 unit		77
	Appendix C: Fault record for RO-3 unit	79	
	Appendix D: Fault record for UF filters		80



University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

## LIST OF FIGURES

Figure No	Description	Page
Figure 3.1	Failure of a raw water pump.8	
Figure 3.2	Raw water pump -01 Run-Repair-Run cycle.10	
Figure 3.3	Raw water pumps arrangement.12	
Figure 3.4	Ebara brand pump selection chart.19	
Figure 3.5	Vertical mixed flow spindle pump.20	
Figure 3.6	Reduction of failure rates with the improvement in the system.22	
Figure 4.1	UF system.24	
Figure 4.2	Desalination plant layout.26	
Figure 4.3	Reduction of failure rates with the improvement in the system.28	
Figure 4.4	Temporary isolation of VSD unit in Desalination plant.29	
Figure 4.5	Cross section of recommended symmetrical cable.31	
Figure 4.6	Flow duration curve for “Eluwankulam” water downstream.34	
Figure 4.7	Geographical piping layout proposal between the source and plant.35	
Figure 4.8	Combined minimum cost for initial cost and energy cost.40	
Figure 5.1	Flow diagram of Demineralization system.43	
Figure 5.2	Proposed standby blower to degasifier.45	
Figure 5.3	Proposed logic modification in PLC ladder program.46	
Figure 5.4	Graphical representation of the improvement of reliability.48	
Figure 6.1	Layout of the chlorination plant.49	
Figure 6.2	Process layout of the chlorination plant.	51
Figure 6.3	Water leak through mechanical seal.52	
Figure 6.4	Installation of sand filter to protect booster pump.53	
Figure 6.5	Barnacles growth in bar screen due to lack of dosing of NaOCl .53	
Figure 6.6	Present pipe line arrangement	54
Figure 6.7	Proposal for installation of separate dosing line (DN80) and necessary flow control equipment.	56
Figure 6.8	Reliability curve of chlorination system before and after the modifications.57	
Figure 7.1	Hydrogen storage tanks with the total capacity of 4 x 250 m <sup>3</sup> .	59
Figure 7.2	Simplified block diagram of hydrogen plant.61	
Figure 7.3	Improvement of reliability with the modification to H <sub>2</sub> plant.	64

## LIST OF TABLES

Table No	Description	Page
Table 3.1	Outage data for pump-01.	9
Table 3.2	Outagedatafor pump-02.9	
Table 3.3	Outage data for pump-03.9	
Table 3.4	Outage data for pump-04.10	
Table 3.5	Running and outage data for raw water pump-01.10	
Table 3.6	Reliability factors for all raw water pumps.11	
Table 3.7	Repair time for root blower in gravity filter -01.14	
Table 3.8	Repair time for root blower in gravity filter -02.14	
Table 3.9	Repair time for root blower in gravity filter -03.14	
Table 3.10	Reliability factors for Roots blowers.15	
Table 3.11	New reliability factors for raw water pumps.	21
Table 3.12	Reliability & Failure comparison.21	
Table 3.13	Failure rates variation with time	22
Table 4.1	Unit cost of water from Desalination plant.25	
Table 4.2	Summary of reliability factors in RO system.26	
Table 4.3	Summary of reliability factors in UF system.28	
Table 4.4	Cost for the modification listed as relocation of VSD's.32	
Table 4.5	Daily average flow discharge of Eluvankulamstream in m <sup>3</sup> /sec. 33	
Table 4.6	Cost calculation for proposed piping layout.35	
Table 4.7	Cost calculation for different motor capacities.39	
Table 4.8	Combination of pipe, pump cost and energy cost.40	
Table 4.9	Calculation of unit cost for feed water as per the proposal 41	
Table 5.1	System outage data in demineralization unit.44	

Table 5.2	Equipment wise reliability factors.	45
Table 5.3	Expected equipment wise reliability factors.	48
Table 6.1	Equipment outages and running hours record.	50
Table 6.2	Calculated equipment wise reliability indices.	51
Table 7.1	Plant No: 01 Outage data.	59
Table 7.2	Plant No: 02 Outage data.	60
Table 7.3	Outage data for storage tank.	60
Table 7.4	Calculated summary of reliability factors for entire system.	60
Table 8.1	Cost estimation for installing new dosing pipe arrangement for Chlorination plant.	65
Table 8.2	Cost estimation for installing new sand filter for booster pump at Chlorination.	66
Table 8.3	Cost estimation for installing new vertical mixed flow spindle pumps for sea water intake.	67
Table 8.4	Cost estimation for relocating the existing VSDs.	68
Table 8.5	Cost estimation for installing of standby blower to degasified system.	69
Table 8.6	Cost estimation for installation of new hydrogen tanks system.	70
Table 9.1	Plant wise availability comparison in BOP section.	72
Table 9.2	Simple payback period for each modification.	73



University of Moratuwa, Sri Lanka.  
 Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

## LIST OF ABBREVIATIONS

Abbreviation	Description
$\mu$	Repair rate
$\mu S$	Micro Siemen
A	Availability
CEB	Ceylon Electricity Board
cm	Centimeter
CU	Copper
D	Pipe Diameter
DC	Direct Current
DI	Ductile Iron
DN	Nominal Diameter
FRP	Glass Reinforced Plastic Pipe
H	Head
h	Hour
H <sub>2</sub>	Hydrogen Gas
IEE	The Institution of Electrical Engineers
kW	Kilo Watt
LVPS	LakVijaya Power Station
$\bar{m}$	Mean running time
Mn	Million
MPa	Mega Pascal
MSL	Mean sea level
MW	Mega Watt
NaOCl	Sodium Hypochlorite
NWS&DB	National Water Supply and Drainage Board
PVC	Polyvinyl chloride
PLC	Programmable Logic Circuit
Q	Flow rate





$\bar{r}$	Mean failure time
RO	Reverse osmosis system
Rs.	Sri Lanka rupees
RWP	Raw Water Pump
SWA	Steel Wire Armoured
SYS	System
UF	Ultra Filtration
$v$	flow velocity
$V$	Voltage
VSD	Variable Speed Drive
XLPE	Cross-linked Polyethylene
$\lambda$	Failure rate
USD	United States Dollar



University of Moratuwa, Sri Lanka.  
 Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

## LIST OF APPENDICES

<b>Appendix No</b>	<b>Description</b>	<b>Page</b>
Appendix A	Fault record for RO-1 unit.	75
Appendix B	Fault record for RO-2 unit.	77
Appendix C	Fault record for RO-3 unit.	79
Appendix D	Fault record for UF filters.	80



University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

## Chapter 1

### INTRODUCTION

#### 1.1. Background.

Lakvijaya power station, with a target capacity of 900 MW, is the very first first ever coal fired power station constructed in Sri Lanka with 900 MW capacity [1]. It is constructed situated in the village of Norochchollei in bordering the sea shore of Kalpitiya peninsula, approximately 12 km west of the city of Puttalam town. Construction was designed planned in two two phases, and first phase was completed in 2011 and handed over to Ceylon Electricity Board (CEB) after commissioning. It has the a capacity of 300 MW. Second stage Other 600 MW will contribute an additional 600 MW. Stage two is being commissioned and expected to start commercial operations in (April 2014.) will be planned to commission in end of 2013 and 2014. (01).

Comment [WID1]: 2013 is already gone!

Formatted: Highlight

Formatted: Font: 12 pt, Complex Script Font: 12 pt, Highlight

Being the power plant having the largest capacity and the lowest cost out of all thermal plants, continuous power generation of this power station is very more important to provide the uninterrupted power supply to the country at a reasonable cost. Therefore, maintaining we have to maintain a high level of reliability of equipment's to ensure keep uninterrupted smooth operations is essential. The life time of power station is 30 years. Therefore improve of design failures also help to increase the efficiency for long time benefit. Any improvements to the present systems to enhance reliability will definitely improve availability and long term benefits of the plant which has a life span of 30 years.

Comment [WID2]: "I" and "We" are not very nice to be in a "professional" report.

Comment [WID3]: How does this fit in here?

Bituminous coal with a calorific value more than above 6,300 kcal kg<sup>-1</sup>, calorific value has been purchased from Indonesia, South Africa and Australia, to supply the energy for steam production.

Daily feed water requirement of the plant needs is 350 m<sup>3</sup> tons of feed water for day. Required water is taken from Indian Ocean the sea and purified to obtained the necessary feed water quality [1]. This was done by using various several treatment processes, and all of those processes are considered evaluated in this study with a view to improve the reliability of equipment's. Because purified

Formatted: Font: 12 pt, Complex Script Font: Times New Roman, 12 pt

water supply to the boiler is a critical factor ~~critical contributing~~ to smooth running of the power station. ~~It needs 350 tons of feed water for day.~~

The most important auxiliary systems in the power station are ~~listed below~~:

1. Sea water intake & pre-treatment plant.
2. Desalination Plant.
3. Demineralization plant.
4. Hydrogen plant
5. Chlorination plant.
6. Compressed Air system( for Instrument & Service air)
7. Auxiliary boiler.
8. Condensate polishing plant
9. Waste water treatment plant

Formatted: Font: 12 pt, Complex Script Font: Times New Roman, 12 pt

Most of suspended materials and particles, which are possible to ~~and damage~~ water seals and obstruct ~~the filters of the~~ fine purification systems were ~~are~~ removed in the pretreatment plant. ~~It is done by~~ using chemical treatments and physical methods such as filtration and precipitation.

Formatted: Font: 12 pt, Complex Script Font: Times New Roman, 12 pt

Formatted: Font: 12 pt, Complex Script Font: Times New Roman, 12 pt, Highlight

Comment [WID4]: One Idea = One Paragraph.

Desalination plant plays a major role to reduce the high salinity of sea water. Reverse osmosis (RO) technology and ultra filtration (UF) technology are used to improve the quality of sea water up to ~~obtain~~ the required surface water quality ~~by sea water~~.

Demineralization water plant ~~performs to~~ produces feed water with a mineral content less than  $0.2 \mu\text{Scm}^{-1}$  [1]. An RO system and ion exchange resins are used in this process.

Hydrogen is used in generator cooling due to its excellent features to suit the application. It is the lightest ~~lighter~~ gas ~~with contain~~ having a higher heat capacity. However handling of hydrogen is dangerous due to its explosion ~~ability~~ veness. Hydrogen can be generated easily by electrolysis of water in ~~with the~~ presence of catalytic conductive material.

Electro chlorination plant produces se sodium hypochlorite (NaOCl) to control the marine growth in sea water ~~which is mainly~~ used for the condenser cooling. Common salt (sodium chloride) available in raw sea water is converted to NaOCl by few

chemical reactions associated with electrolysis [6]. ~~Proper operation of this is~~ plant is ~~very~~ critical ~~to in~~ controlling the ~~amount of debris~~ ~~possible to come~~ with cooling water to ~~prevent clogging of~~ debris filters and condenser tubes. Lakvijaya power station ~~had~~s to reduce its power production several times due to the failure of ~~these~~ debris filters. Design of ~~the available existing~~ electro chlorination plant had many ~~failures deficiencies leading to failures~~, which ~~are~~ severely affected ~~to~~ the continuous running of ~~the~~ power station.

Compressed air system produces instrument air and service air to fulfill the plant requirements. It ~~is containing~~ includes condensers and dryers to obtain ~~proper quality~~ instrument air ~~of proper purity and humidity~~.

~~The~~ ~~eneration of~~ steam ~~generation~~ required for the startup of main boiler, ~~supply is~~ carried out ~~by~~ using ~~the~~ auxiliary boiler. It can supply 20 to 25 tons of steam ~~for~~ per hour [1].

~~Accumulation of residue inside boiler drums~~ ~~The residual materials accumulated with time in boiler drum will be~~ is controlled by blow down procedure. ~~This is done by draining some water at the bottom of boiler drum to remove residues. Though the plant continues to operate during a blow down. But during the blow down process, the pressure of inside boiler drum should be increase. I, which is a disadvantage for high pressure boilers, requires addition of de-mineralized make up water.~~

The steam passing through the three stages of the turbine is condensed in the condenser and fed back to the boiler. However, this condensate has accumulated metal ions and other dissolved solids in it. A ~~Condensate polishing system introduced is used to minimize the accumulation of residual~~ remove such impurities using ion exchangers ~~containing high temperature resistant ion exchange resins metal ions and other dissolved solids. Therefore~~ blow down frequency ~~will be~~ is decreased due to the action of ~~this~~ polishing system. ~~This system containing high temperature resistant ion exchange resins to remove the charge species. Resins used for the purpose can~~ are regenerated ~~by~~ using acidic and alkaline ~~caustic~~ reagents.



University of Moratuwa Sri Lanka  
Electronic Theses & Dissertations  
www.lib.mru.ac.lk

Formatted: Font: 12 pt, Complex Script Font: Times New Roman, 12 pt

Treatment of Waste water treatment is very important to control suppress the liquid pollutants including oil and grease to ensure the minimum minimize effects to on the environment. Waste water collected ing from various type of washing sections of the in power station plant including blow down and sewerage is collected in a pit and sent to two aeration basins where air is mixed using two aeration blowers. It is further treated in a waste water treatment plant by using chemicals. Solid particles are retained by sedimentation in clarifiers. Oils floating on the surface are removed in the oil separators. Treated water of this plant is used in fly ash unloading, bottom ash cooling, and coal yard sprinklers and for gardening.

and physical processes.

Boiler blow down water and discharge of sewerage treatment also collect to the waste water treatment plant. Treated water of this plant used in fly ash unloading, bottom ash cooling and coal yard sprinklers.

## 1.2. Motivation for the Project.

With the inherent large number of auxiliaries, the 1 x 300 MW unit is running in operation for almost two and half years as a the leading thermal steam power plant while catering energy to the system providing approximately 18% of the annual energy demand of the power system. Being the cheapest thermal power plant, it plays a major role as a base load plant throughout the year, its contribution is especially important in during drought seasons specially since the lack of when the hydro power generation is minimal and as a base load plant in whole year.

There had been several failures of the plant during the past, attracting criticism from many parties. Most of these failures originated from the major components of the plant like the main boiler, turbine and coal handling system. However, the other equipment called Balance of Plant (BOP) too was subject to frequent failures. Due to Such failures rarely contributed to a plant outage due to the availability of redundant equipment, Nonetheless, improving the reliability of such BOP would ensure a high reliability of the plant as well.



Formatted: Font: 12 pt, Complex Script Font: 13 pt

Formatted: Font: 12 pt, Complex Script Font: 13 pt, Not Highlight

Formatted: Font: 12 pt, Complex Script Font: 13 pt, Highlight

Formatted: Font: 12 pt, Complex Script Font: 13 pt

~~But with the experienced issues in auxiliaries this project will scrutinize some key reliability indices in important auxiliary units to examine the possibility to improve the reliability.~~

~~So it~~ This study willis aimed at ~~guide to any~~ identifying weak points in the BOP and ~~suggesting~~ possible modifications of such systems to ensure ~~their~~ continuous operation to support ~~the proper operation of for~~ main units such ~~as~~ boiler, turbine and generator.



University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

## Chapter 2

### PROBLEM STATEMENT

#### 2.1. Identification of the Problems.

Several failures of BOP were noted during the data acquisition period from 22.12.2010 to 09.06.2012. It was noticed several failures of BOP section which belongs to Pretreatment plant, Desalination plant, Demineralization Plant, Chlorination plant and Hydrogen Plant can be identified as the components where major failures occurred that lead to a critical issue to running the plant at full load. Even those failures are not belongs to the main equipments such Turbine and boiler units it cannot neglect the availability and failures since those major units are totally depends on above supportive units.

Frequent failure of submersible pumps installed at the sea water intake and presence of fine sand particles in sea water were the major problems which occurred in the pretreatment plant.

Failure of the Reverse Osmosis (RO) membranes and the Variable Speed Drives (VSD) were the most frequent problems in the desalination plant.

The de-mineralizing plant has a low reliability as only one blower is installed in the de-gasifier unit.

Frequent failure of booster pumps and the inability to achieve required chlorine dosing levels are the problems associated with the Chlorination Plant.

Formatted: Font: 12 pt, Complex Script Font: 13 pt



Insufficient storage capacity was the problem associated with the Hydrogen Plant.

The major problem in pretreatment plant is, submersible pumps installed at the sea water intake fails frequently due to high conductivity in sea water and the fine sand particles which come with sea water. In addition to that, it was found that rubber seal at cable connection of the motor also damaged due to high conductivity

Formatted: Font: 12 pt, Complex Script Font: 13 pt, Highlight

## **2.2. Objectives of the Study.**

Lakvijayapower station was a long awaited solution to the ever increasing demand for electricity in Sri Lanka. When the plant was constructed after a long delay, the general public had high expectations about reliable and low cost electricity. However, frequent failures of the plant have provided an arena for various pressure groups to agitate the public by pinpointing the failures while masking off the advantages brought out by the plant.

Due to the lack of potential for new large scale hydro power plants, the availability of this power station is of utmost importance to provide a reliable power supply to Sri Lankans at a reasonable cost.

The objective of this study is to identify deficiencies in the existing auxiliary systems (BOP) of the power plant and propose improvements to enhance the reliability of the whole plant in order to meet the aspirations of the general public for cheap and reliable electricity.

Another objective is to decrease the operational cost of the plant by reducing the cost of operating the BOP.

As the plant factor of the power station will be increased with the improved reliability, it is expected to improve the rate of return on investment of the plant too.

## **2.3. Methodology**

Past operational and failure data of the main auxiliary systems of BOP section during the period from 22.12.2010 to 09.06.2012 were collected using operational and failure logs, defect notices and permits to work. Failure and repair durations of those equipment were summarised and tabulated in order to calculate the Firstly it is expected to evaluate the current availability and failure rates in the Sea Water Pre-

Formatted: Heading 2, Indent: Left: 0", Hanging: 0.38", Outline numbered + Level: 2 + Numbering Style: 1, 2, 3, ... + Start at: 2 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.55"

treatment Plant, Desalination Plant, Chlorination Plant ~~and~~ Hydrogen Generation and Storage plant.

It was observed that the availability factors of these systems were low compared to the expected values. Major problems contributing to the low availability of these systems were studied and identified.

The possibility to improve the reliability by means of new modifications to relevant sections was investigated and modifications and new designs for the systems were proposed. Cost of proposed modifications was calculated using pricing details from former invoices and quotations obtained from equipment suppliers. The estimated cost for the erection and civil works was obtained from the invoices of the first phase of the Puttalam coal power project. Thereafter, the ~~new expected~~ reliability figures after the improvements ~~also~~ were calculated.

Finally the overall reliability improvement of the power plant and the payback periods for the proposed improvements were calculated and the overall project viability was evaluated.



University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)



---

## SEA WATER INTAKE & PRETREATMENT PLANT

### 3.1. Introduction

The total water ~~consumption requirement~~ of Lakvijaya power station ~~is~~ achieved ~~from~~ ~~by purification of~~ sea water ~~purification~~. The ~~required with~~ capacity ~~of is~~ 100 m<sup>3</sup> desalinated water per hour. Many impurities ~~consist~~ in sea water can affect ~~ed on~~ ~~the~~ sensitive ~~U~~ltra-~~F~~iltration (UF) and ~~R~~everse ~~e~~Osmosis (RO) systems. Therefore, ~~an effective~~ pretreatment process is ~~more effective~~ ~~required~~ to protect the above sensitive equipment. Pretreatment plant consists of raw water pumps, settling basin, gravity filters and clear water basin.

The most common ~~outage failure~~ of the pretreatment plant is the ~~failure of~~ ~~submersible~~ raw water pumps ~~outage~~. ~~Submersible pumps~~ installed at the sea water intake, ~~failed frequently by burn-out of~~ The motor windings ~~sare frequently burnt~~ due to water leaking ~~into the motor housing~~ (Figure: 3.1). ~~One cause for~~ ~~T~~his leakage

was identified as the damage of water seal and packing due to the presence of sand particles and fine debris in sea water. Also another cause it was found to be the deterioration of the rubber seal at the cable connection entry to the motor, also damaged due to high conductivity of sea water. The plant has been designed for sea water conductivity less than 50,000  $\mu\text{S}/\text{cm}$  [1]. However, the actual conductivity was found to vary between 60,000 and 90,000  $\mu\text{S}/\text{cm}$  seasonally.

Pretreatment plant consists of two channels each ~~one having the~~ handling capacity of 250  $\text{m}^3$  per hour. Combined, these two channels can to fulfill the total sea water requirement for desalination plant.

Sea water ~~was is~~ pumped using four submersible pumps, to the pre-treatment plant consisting of a settling basin and sand filters by using four submersible pumps. Two pumps are in operation at any time while the other two are on standby.

Suspended solids and dissolved silicates in sea water are precipitated by using chemicals (poly aluminum chloride and poly amide) in the ~~pretreatment plant. This process occurred in the equipment call~~ settling basin. It contains plastic honey combs placed ~~in~~ at  $45^\circ$  angle, to accelerate the precipitation process. Gravity filters which contains sand also help to remove the particles which were not precipitated in settling basin. Filtrate is collected in to clear water basin to ~~be further filtered by feed for~~ UF filters.

The gravity filters are periodically cleaned using root blowers which send a stream of air through the filters in the reverse direction. Frequent overload tripping of these blowers has been observed in the past.

~~The root blowers in gravity filters also fails several times due to unidentified reasons. In this study it is observed to take necessary actions to avoid it.~~

Formatted: Font: 12 pt

Formatted: Font: 12 pt, Complex Script Font: 13 pt, Not Highlight

Formatted: Font: 12 pt, Complex Script Font: 13 pt, Not Highlight





Figure 3.1: Failure of a raw water pump showing water leakage.

### 3.2. Calculation of Availability

The availability of raw water pumps is more important to supply the water demand of power station. Therefore availability of the equipment was calculated according to the break down details recorded by using the Distributed Control System(DCS) history records, issued work permits and log books during the period of one and half years under consideration.

Failures of roots blowers were also taken into consideration to derive combined reliability figure with raw water pumps since both equipments are connected in series manner.

### 3.2.1. Sample data collection for raw water pumps.

Nearly one and half years of data starting from 22/12/2010 are collected ~~for on~~ all four raw water pumps to find required parameters.

Table 3.1:- Outagedata for ~~pump~~ pump-01

<u>Time of start</u> <u>Time of Failure</u> (mm/dd/yyhh:mm)	<u>Time of Restoration</u> <u>Time of Recovered</u> (mm/dd/yyhh:mm)	Incident	Outage Periods (h)
10/11/11 9:22	10/12/11 12:50	Motor winding failure	27.47
11/19/11 11:45	11/20/11 21:45	Motor winding failure	34.00
12/02/11 14:00	12/30/11 8:30	Motor winding failure	666.5
1/16/12 10:09	1/16/12 20:53	Motor bearing failure	10.73
3/2/12 10:20	3/2/12 16:45	Motor winding failure	6.42
3/22/12 15:53	7/19/12 14:45	Motor winding failure	2854.87
Total Outage			3589.98

Formatted: Font: 12 pt

Formatted: Left: None, Space Before: 0 pt, After: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together



Table 3.2: Outage data for pump-02

<u>Time of start</u> <u>Time of Failure</u> (mm/dd/yyhh:mm)	<u>Time of Restoration</u> <u>Time of Recovered</u> (mm/dd/yyhh:mm)	Incident	Outage Periods (h)
3/2/12 10:20	3/2/12 16:45	Motor winding failure	6.42
5/24/12 8:07	7/9/12 18:10	Motor winding failure	1114.05
Total Outage			1120.47

University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
www.lib.mrt.ac.lk

Formatted: Left: None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together

Formatted: Left: None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together

Table 3.3 : Outagedata for pump-03

<u>Time of start</u> <u>Time of Failure</u> (mm/dd/yyhh:mm)	<u>Time of Restoration</u> <u>Time of Recovered</u> (mm/dd/yyhh:mm)	Incident	Outages (h)
10/11/11 8:40	10/13/11 17:30	Motor winding failure	56.83
3/2/12 10:10	3/2/12 16:45	Motor bearing failure	6.58
3/17/12 14:20	3/18/12 17:30	Motor winding failure	27.17
4/26/12 14:42	6/3/12 17:57	Motor winding failure	915.25
Total Outage			1,005.83

Formatted: Left: None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together, Tab stops: Not at 1.18" + 1.58" + 6.1"

Formatted: Left: None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together, Tab stops: Not at 1.18" + 1.58" + 6.1"

Table 3.4 : Outagedata for pump-04

<u>Time of startTime of Failure</u> (mm/dd/yyhh:mm)	<u>Time of Restoration</u> (mm/dd/yyhh:mm)	Incident	Outages (h)
12/21/11 18:50	12/26/11 23:21	Motor winding failure	124.52
3/2/12 9:30	3/2/12 16:50	Motor Bearing failure	7.33
3/22/12 15:53	7/10/12 13:50	Motor winding failure	2637.95
Total Outage			2,769.80

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together, Tab stops: Not at 1.18" + 1.58" + 6.1"

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together, Tab stops: Not at 1.18" + 1.58" + 6.1"

From the above data it is evident that the total outage time for all four pumps due to winding failure alone is 8,486.08 hrs and the total running time is 24,467.38 hrs. This is 34.68% of the total running time and a very high failure rate even at a glance.

~~3.2.2. Due to the motor winding failure problem arise in this pumps ,Total outage is 8486.08 hours and total running time is 24,467.38 According to above data total outages are very high with compare with total running time of pumps.It is approximately 34.68% out of the total running time.~~

**3.2.2. Sample Reliability Calculation for Raw water pump -01**

Table 3.5 : Running and outage data for raw water pump 01

Running hours	Outage hours	No of Outages	No of Starts
4907.75	3589.98	6	7

Formatted: Indent: Left: 0.06", First line: 0", Line spacing: Multiple 1.15 li, Outline numbered + Level: 3 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.5" + Indent at: 0.85"

By using the summarized data given in table 3.5, availability of the raw water pump-1 is calculated. A Run-Repair-Run cycle of a system having  $m_1, m_2, m_3, m_4, \dots, m_n$  run times and  $r_1, r_2, r_3, \dots, r_n$  repair times, is shown in figure 3.2

If system Working,




Figure 3.2: Raw water pump -01 Run-Repair-Run cycle

According to the reliability theory for the system shown in figure 3.2

$$\text{Mean run time } (\bar{m}) = \frac{m_1+m_2+m_3+\dots+m_n}{n} \quad (01)$$

$$\text{Mean repair time } (\bar{r}) = \frac{r_1+r_2+r_3+\dots+r_i}{i} \quad (02)$$

$$\text{Availability} = \frac{\text{Mean run time}}{\text{Mean run time} + \text{Mean repair time}} \quad (03)$$

By using the above equations (01),(02) and (03),raw water pump 1 reliability factors can be calculated as follow.

$$\text{Mean running time } (\bar{m}) = 4907.7577 = 701.11 \text{ h}$$

$$\text{Mean failure time } (\bar{r}) = 3.589.98 = 598.33 \text{ h}$$

$$\text{Availability } (A) = \frac{m}{m+r}$$

$$= 701.11 / (701.11 + 598.33) = \mathbf{0.5395}$$

$$\text{Failure Rate } (\lambda) = \frac{1}{m} = \mathbf{0.0014263 / h}$$

$$\text{Repair Rate } (\mu) = \frac{1}{r} = \mathbf{0.001673 / h}$$

In the same way all above reliability factors of all raw water pumps are calculated and a summary is provided in table 3.6.

Table 3.6: Reliability factors for all raw water pumps

Pump	Running (h)	Outage (h)	No of running times	No of Outages	$\bar{m}$ (h)	$\bar{R}$ (h)	Availability	f	$\lambda/h$	$\mu/h$
------	-------------	------------	---------------------	---------------	---------------	---------------	--------------	---	-------------	---------



RW 1	4,907.75	3,589.98	7	6	701.11	598.33	0.53955	0.00077	0.0014	0.00167
RW 2	1,536.45	1,120.47	3	2	512.15	560.23	0.47758	0.000933	0.0020	0.00178
RW 3	5,949.17	1,005.83	5	4	1,189.83	251.46	0.82553	0.000694	0.0008	0.00398
RW 4	3,290.02	2,769.80	4	3	822.50	923.27	0.47114	0.000573	0.0012	0.00108



University of Moratuwa, Sri Lanka.  
 Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

At full load operation two pumps are running and others two are in standby. The pump arrangement is as follows




Figure:3.3–Raw water pumps arrangement.



University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

Basic reliability factors calculation for the 2 out of 4 model equivalent, parallel & standby model is given by following equation [2].

$$R_{sys}(t) = \sum_{i=r}^n \binom{n}{i} \cdot [R(t)]^i \cdot [1 - R(t)]^{n-i} \quad (4)$$

Source: Basic reliability “bottom-up” Model calculation [2].

Where:

$$\begin{aligned} R_{sys}(t) &= \text{the System reliability} \\ r &= \text{the actual number of failures} \\ n &= \text{the total number of units in the system} \\ R(t) &= \text{the reliability function of identical units} \end{aligned}$$

Assuming the identical raw water pumps, which having the average failure rate of 0.00135 per hour for each, the reliability function for the combined system is derived below.

Average failure rate  $\lambda = 0.00135/\text{h}$

Total observation time period = 12,840h (22/12/2010-09/06/2012)

By using above equation, assuming exponential distribution

$$R_{(RWP)} = e^{-\lambda t} = e^{-0.00135 \times 12840} = 2.964 \times 10^{-8}$$

$$R_{sys}(t) = \sum_{i=2}^4 \binom{4}{i} \cdot [R(t)]^i \cdot [1 - R(t)]^{4-i}$$

$$= \sum_{i=r}^n \frac{n!}{r!(n-r)!} e^{-\lambda t} (1 - e^{-\lambda t})^{n-1}$$

$$= {}^4C_2 (2.964 \times 10^{-8})^2 (1 - 2.964 \times 10^{-8})^2 + {}^4C_3 (2.964 \times 10^{-8})^3 (1 - 2.964 \times 10^{-8})^1 + {}^4C_4 (2.964 \times 10^{-8})^4 (1 - 2.964 \times 10^{-8})^0$$

$$R_{sys} = 5.269 \times 10^{-15}$$

$$\text{Then, } 5.296 \times 10^{-15} = e^{-\lambda \times 12840}$$

Failure rate  $\lambda_1 = 0.00256/\text{h}$

Average availability for raw water pumps A = **0.87517**

### 3.3. Availability of roots blowers in gravity filters

Availability calculations for gravity filters were ~~are~~ given in table below.

Table 3.7: Repair time for root blower in gravity filter -01

<u>Time of start Time of Failure</u> (mm/dd/yyhh:mm)	<u>Time of Restoration</u> (mm/dd/yyhh:mm)	period	Period in hrs
10/5/11 9:25 AM	10/5/11 4:40 PM	7:15:00	7.25
12/10/11 1:02 PM	12/10/11 4:16 PM	3:14:00	3.23
6/14/12 9:30 AM	6/14/12 9:40 PM	12:10:00	12.17
Total			<u>22.65</u>

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together

Table 3.8: Repair time for roots blower in gravity filter -02

<u>Time of start Time of Failure</u> (mm/dd/yyhh:mm)	<u>Time of Restoration</u> (mm/dd/yyhh:mm)	period	Period in hrs
7/14/11 10:50 AM	7/16/11 8:05 AM	45:15:00	45.25
10/8/11 8:40 AM	10/8/11 2:25 PM	5:45:00	5.75
1/10/12 1:50 PM	2/1/12 4:02 PM	530:12:00	530.20
5/18/12 8:40 AM	5/19/12 2:15 PM	29:35:00	29.58
Total			<u>610.78</u>

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together

Table 3.9: Repair time for roots blower in gravity filter -03

<u>Time of start Time of Failure</u> (mm/dd/yyhh:mm)	<u>Time of Restoration</u> (mm/dd/yyhh:mm)	period	Period in hrs
1/10/11 9:46 AM	2/1/11 2:49 PM	533:03:00	533.05
5/14/11 1:30 AM	5/15/11 8:15 PM	42:45:00	42.75
9/12/11 6:15 AM	9/12/11 8:50 PM	14:35:00	14.58
9/6/12 1:30 AM	9/6/12 6:45 PM	17:15:00	17.25
Total			<u>607.63</u>

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together

Summary of availability calculation<sup>s</sup> for gravity filters is given in [the following table](#).

Table 3.10: Reliability factors for Roots blowers

Equipment	Running (h)	Outage (h)	No of running times	No of Outages	m (h)	r (h)	Availability	f	λ/h	μ/h
Roots blower -01	4,077.90	22.65	4	3	1,019.47	7.55	0.99265	0.000974	0.0010	0.13245
Root blower -02	4,077.90	610.78	5	4	815.58	152.70	0.84230	0.001033	0.0012	0.00655
Roots blower -03	4,077.90	607.63	5	4	815.58	151.91	0.84299	0.001034	0.0012	0.00658

Average failure rate ( $\lambda$ ) = 0.0011/h  
 Total running time = 12840 h

By using following equation for the 2 out of 3 model

$$R_{(RB)} = e^{-\lambda t} = e^{-0.0011 \times 12840} = 7.3 \times 10^{-7}$$

$$R_{sys}(t) = \sum_{i=2}^3 \binom{3}{i} R(t)^i [1 - R(t)]^{3-i}$$

$$= \sum_{i=2}^3 \frac{n!}{i!(n-i)!} e^{-\lambda t i} (1 - e^{-\lambda t})^{n-i}$$

$$= {}^3_2C(7.3 \times 10^{-7})^2 (1 - 7.3 \times 10^{-7})^1 + {}^3_3C(7.3 \times 10^{-7})^3 (1 - 7.3 \times 10^{-7})^0$$

$$R_{sys} = 1.6 \times 10^{-12}$$

$$\text{Then, } 1.6 \times 10^{-12} = e^{-(\lambda \times 12840)}$$

Failure rate  $\lambda_{(RB)}$  = 0.0021/h  
 Average availability for root blowers = 0.99982

Total reliability of pretreatment plant was calculated and factors are given below.

Then pretreatment plant failure rate =  $\lambda_1 + \lambda_{(RB)}$   
 = 0.0047 / h

System availability =  $A_1 \times A_2$   
= **0.87501**

According to the results of above calculations, it appears that the availability of the system can be improved.

Mathematically, the availability can be improved by :

1. Adding more pumps to the system
2. Completely doing away with pumps or
3. Improving the reliability of individual pumps.

In practical terms, the first solution can be achieved by installing more pumps with associated piping and valves etc. However, this does not appear to be desirable as the modifications and additional pumps are costly. As the pumps would operate outside designed conductivity values, this is not a prudent technical solution.

The second solution is possible by obtaining raw water from the cooling water lines after the cooling water pumps. However this requires modifications to the cooling water system which needs plant to be shut down. Further, the capacities of main cooling water pumps will have to be increased. Therefore, this solution is not prudent for the on-going plant but may be considered in the second stage work.

The third solution can be achieved by replacing the submersible pumps with vertical mixed flow pumps where the motor is kept above water. This is easier to implement and requires minimal interruptions. As pumps can be replaced one by one, no interruption is needed.

~~A proposal based on the According to the reliability calculations it seems the possibility of improve the system reliability to a higher value than this figure. Therefore some more equipment modifications and replacements could propose as follows.~~

third solution is discussed below.

### 3.4. Proposal for Improving Availability of Raw Water Pumps.

Formatted: List Paragraph, Add space between paragraphs of the same style, Line spacing: 1.5 lines, Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.5"

Formatted: Font: 12 pt

Formatted: Font: 12 pt

Formatted: Font: 12 pt

Formatted: Add space between paragraphs of the same style, Line spacing: 1.5 lines



Formatted: Font: 12 pt, Font color: Auto, Complex Script Font: 12 pt

Formatted: Font: 12 pt, Font color: Auto, Complex Script Font: 12 pt

a) ~~Existing raw water pumps can change with suitable mixed flow pump.~~

It is proposed to ~~exchange-replace~~ the existing pumps with vertical mix flow spindle pumps to eliminate the possibility of damage of water seal by debris and fine sand particles. Even the damages of water seal in new pump will ~~have not effected~~ on motor winding since it is located in ~~an~~ elevated position ~~from-above~~ the water level. Even the suction part of new pump can ~~be designed~~ to tolerate the yearly ~~variation of~~ sea water ~~variation to level due to monsoons.~~

Formatted: Indent: Left: 0", Line spacing: 1.5 lines

The calculations of suitable pump capacity are given below.

Selection of pump capacity and motor power

Daily Water requirement = 7,680m<sup>3</sup>

Number of working hours = 24hr/day

Then flow rate = 320m<sup>3</sup>/hr min. (5m<sup>3</sup>/min)

Required pump quantity = DutyRunning -2 and Standby -2

Pump capacity (Q) = 2.5 m<sup>3</sup>/min (0.04167 m<sup>3</sup>/sec)

Existing Pipe Diameter (D) = 146x(Q/v)<sup>0.72</sup> [13]

Selected velocity range (v) = 1.5 m/s – 3m/s [13]

Pipe diameter range = 267 mm – 188 mm

**Selected pipe diameter (D) = 200mm**

Static Head:

Suction level **hs** = -9.4m (MSL)

Delivery level **hd** = 12m (MSL)

**Static head = 21.4m**

**Friction loss (hf):**

~~Selected Existing~~ pipe material is Fiber Reinforced plastic (FRP), which has C=150

Then using Hazen Williams equation,

$$hf = 10.666 \times C^{(-1.85)} \times D^{(-4.87)} \times q^{(1.85)} \times L \quad [14]$$

Formatted: Font: 12 pt

Formatted: Font: 12 pt

Formatted: Font: 12 pt

Formatted: Font: 12 pt

Formatted: Font: 12 pt

Formatted: Font: 12 pt

Formatted: Font: 12 pt

Formatted: Font: 12 pt

( C =150, L=525m, D=200mm)

hf = 13.5m

Calculation of vVelocity head:

Cross section area = 0.031416m<sup>2</sup>

Flow velocity = 1.3m/s

Velocity head =  $V^2/2g$  = 0.09m

Considering miner losses fittings around the pump = 5m

Total pump head = 45m

Hydraulic power =  $\frac{\sigma \cdot g \cdot Q \cdot H}{1000 \cdot \eta}$  kW

Where,

$\sigma$  Density in kg/m<sup>3</sup> (water) = 1000kg/m<sup>3</sup>

g Gravitational constant = 8.81m/s<sup>2</sup>

Q Flow rate in m<sup>3</sup>/s = 0.042 m<sup>3</sup>/s

$\eta$  Pump efficiency for mixed flow pump = 63%

Hydraulic power of pump = 18.39kW

By considering Motor efficiency(60%) and over capacity factor 115%

**Motor power = 35kW**

Formatted: Font: 12 pt



According to the above calculation, most suitable pump was selected by using standard pump selection criteria [9].



University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

50Hz ■ 4pole[Synchronous speed:1500min<sup>-1</sup>]  
 ■ 6pole[Synchronous speed:1000min<sup>-1</sup>]




Figure 3.4 : Ebara brand pump selection chart

Source:MS series EBARA Pumps Selection Manual [9].

Specifications of selected pump

Pump Head (H) = 45m

Flow (Q) = 2.5 m<sup>3</sup>/min

Make :- Ebara

Type:- Vertical mixed flow pump

Model :- 150VY2M 1H33B




Figure 3.5:vertical mixed flow spindle pump

Source: MS series EBARA Pumps Selection Manual [9].

Total cost for the replacement of four raw water pumps is 9.6 million rupees according to the market price on May 2013. According to the past records, raw water pumps have been rewound seventh times and total maintenance cost per one motor was Rs.160,000.00. The maintenance saving by replacement of new pumps is nearly 1.1 million per year. Therefore payback period for the suggested modification is 8.7 year. The reliability improvement of modification also participate for the saving and improve the payback period. However, the financial benefit of that aspect is difficult to calculate.

### 3.5. Proposal for ~~Operation~~ changes in operation of air blowers in gravity filter

Formatted: Font: 12 pt

Formatted: Font: 12 pt, Bold

Formatted: Indent: Left: 0", Hanging: 0.39", Line spacing: single, Outline numbered + Level: 2 + Numbering Style: 1, 2, 3, ... + Start at: 4 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.55"

Blocking of gravity filters is more effective when the particle size of flocks is too small. Therefore root blower has to supply air in high pressure. Due to this reason blowers are overload and failed. The variation of chemical dosing can achieved large amount of heavy particles. It is helps to reduce the strength of blockage. Therefore operation crew was advice to change the chemical dosing pattern.

Implementation of this suggestion does not effect to increase significant cost for the plant operation. Therefore from this study reliability of plant was increased without additional expenses.

After implementing the new design, there was no any motor winding failures due to water leakage. Therefore, those failures were avoided to recalculate the availabilities and failure rates as follows.

Table 3.11: New reliability factors for raw water pumps

Pump	Running (h)	Outage (h)	No of running times	No of Outage s	$\bar{M}$ (h)	$\bar{T}$ (h)	Availability	f	$\lambda$ /h	$\mu$ /h
RW 1	4,907.75	10.73	2	2	6,845.87	10.73	0.99843	0.000146	0.0001	0.09317
RW 2	1,536.45	-	1	1	1,536.45	-	1.00000	0.000651	0.0007	-
RW 3	5,949.17	6.58	2	2	2,974.58	6.58	0.99779	0.000355	0.0003	0.15190
RW 4	3,290.02	-	1	1	3,290.02	-	1.00000	0.000304	0.0003	-

Improvement calculation can summarize as follows.

Table 3.12: Reliability and Failure comparison

Reliability factor	Present situation	After implementation of proposals
Availability (A)	0.87501	0.91954
Failure rate ( $\lambda$ )	0.0047/h	0.00225/h

It can distinguish the reduction of failure rate through a graph as follows with the time (Figure: 3.6).

Table 3.13: Failure rates variation with time

Formatted: Font: 14 pt, Complex Script Font: 14 pt

Formatted: Indent: Left: 0.39", Line spacing: single, No bullets or numbering

Time(h)	0	30	60	90	120	150	180	210	240	270	300	330	360	390	420	450	480
$\lambda_1 = 0.0047/h$	1	0.82	0.68	0.56	0.46	0.38	0.31	0.26	0.21	0.18	0.14	0.12	0.1	0.08	0.07	0.06	0.05
$\lambda_2 = 0.0022/h$	1	0.93	0.87	0.82	0.76	0.71	0.67	0.62	0.58	0.54	0.51	0.48	0.44	0.42	0.39	0.36	0.34




Figure: 3.6: Reduction of failure rates with the improvement in the system

According to the above figure, failure rate has been increased from 0.0047/h to 0.00225/h after the modification. Hence after this proposal implementation, system improvement can be expected.

## Chapter 4

### DESALINATION PLANT

#### 4.1. Introduction to Desalination Plant

The main objective of desalination plant is reducing the salinity of sea water from its nominal value around 60,000 $\mu$ S/cm to 2,000  $\mu$ S/cm which is almost equal to ground water salinity level. This unit plays a very critical and important role in the process of supplying water to fulfill all the requirements such as boiler makeup, service and firefighting, and drinking water.

This plant consists of two major parts namely Ultra Fine (UF)filtration(Figure 4.1) and Reverse Osmosis (RO) permeation which are connected in cascade.

UF filtration is taking place by vacuum filtration of sea water through 100  $\mu$ m membranes. Three sets of UF systems having a capacity 125 m<sup>3</sup>/hr. each are installed. At any time two units are in operation and the remaining unit is on standby. Therefore, the system is capable of producing 250 m<sup>3</sup> per hour. This system is acting as a supportive system to RO system by reducing the dissolved silica and alumina in sea water to ensure a long lifetime of RO membranes[10]. Growth of marine organisms on UF membranes were controlled by dosing sodium hypochlorite (NaOCl) to the inlet water floor. Correct level of dosing is critical as any excess NaOCl will severely damage RO membranes by corrosion.

According to the operation history records, it is seen that this unit has run with a satisfactory output and no critical breakdowns which lead to unit shut down or de-load has been recorded. However, auto cleaning of pre-filters of UF system was not successfully carried out due to the poor instrument and calibration (I & C) issues and erosion of filter material as well as the housing due to sea water. However it has not caused any plant shut downs. At present these pre-filters are bypassed. This can cause damage to the other equipment connected in cascade and shorten their life time.



Figure 4.1: UF system

RO system helps to reduce the salinity of sea water directly. The energy required for the RO process is supplied by a high pressure pump with the help of an energy recovery device. The pressure of RO concentrate water is between 4.0 and 4.5 M Pa. Energy recovery unit transfers this energy to RO feed water by reducing the pressure to 0.25 M Pa. A booster pump is installed to match the energy of feed water after the energy recovery unit. The performance of booster pump and high pressure pump is balanced using a variable speed drive (VSD). Chemicals are dosed into RO feed water to enhance the permeation efficiency of membranes.

Frequent failures of membranes is the major issue of the RO system. The cause for these failures is the high conductivity of sea water in the Indian Ocean. The system was designed to operate at sea water conductivity below than 50, 000  $\mu\text{S}/\text{cm}$ [1]. However, the conductivity of sea water varies between 60,000 and 90,000  $\mu\text{S}/\text{cm}$  throughout the year.

VSDs of high pressure pumps and booster pumps which are installed very close to this system failed several times. Reason for these failures was identified as the presence of high salinity moisture in the vicinity. When the concentrated brine is released to the open trenches it creates sea water breeze, which is drawn with the inlet draft of VSD main cooling fan mounted in the unit. This creates a favorable environment to form rust and make salty deposits on the circuit boards and several VSD cards had to be

replaced due to short circuiting by salty deposits. The VSD enclosure is rated at IP 21 which doesn't provide sufficient protection against water and dust and not at all suitable for the prevailing conditions.

#### 4.2. Unit Generation Cost of Water in Desalination Plant.

The cost for water production can be calculated based on current conditions and the calculation is given below:

Table 4.1: Unit cost of water from Desalination plant

Cost component	Total Cost (Rs)
Annual Electricity	28,382,400.00
Annual membrane replacement	27,100,000.00
Raw water pump maintenance	1,100,000.00
VSD maintenance	6,700,000.00
Mechanical maintenance	36,192,000.00
Annual chemical usage	33,500,000.00
Operation Manpower	6,480,000.00
<b>Total Cost</b>	<b>139,454,400.00</b>

$$\begin{aligned}
 \text{Annual water production} &= 864,000 \text{ m}^3 \\
 \text{Unit cost of water production (Rs)} &= \frac{\text{Total annual water production cost}}{\text{No of units produced}} \\
 &= \frac{139,454,400.00}{864,000} \\
 &= 161.04 \text{ Rs./m}^3
 \end{aligned}$$

With such a high cost it seems that it is much profitable to procure total water requirement for the power plant from National Water Supply and Drainage Board (NWS &DB) at the unit rate of Rs.16.00/m<sup>3</sup>. But there is no such plan or capacity to provide the plant demand since there are no sufficient infrastructure facilities with NWS &DB.



### 4.3. Calculation of Availability in RO units.




Figure 4.2: Desalination plant layout.

Description of Items.

1. RO feed water pump
2. Chemical dosing system
3. Pre-Filter
4. HP pump
5. Motorized valve -1
6. Energy recovery system
7. RO Membrane unit
8. Motorized valve -2



University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

The reliability factor of each system is calculated separately using fault record history in Appendixes A, B, and C for the RO system. Summary of calculations is given in the following table.

Table 4.2: Summary of reliability factors in RO system

Name	Availability	f	$\lambda/h$	$\mu/h$
RO Unit -1	0.3864	0.0022	0.0058	0.0037
RO Unit -2	0.3128	0.0017	0.0055	0.0025
RO Unit -3	0.2312	0.0014	0.0059	0.0018

Considering two out of three units have to be run at full load, system reliability can be calculated as follows.

Average failure rate  $\lambda = 0.0057/h$

Total observation time period = 12,840 h (22/12/2010-09/06/2012)

Assuming exponential distribution

$$R_{(RWP)} = e^{-\lambda t} = e^{-0.0057 \times 12840} = 1.64 \times 10^{-32}$$

Using following equation [02].

$$R_{sys}(t) = \sum_{i=2}^3 \binom{3}{i} [R(t)]^i \cdot [1 - R(t)]^{3-i}$$

$$R_{sys}(t) = 8.0688 \times 10^{-64}$$

$$\text{Then, } 8.0688 \times 10^{-64} = e^{-\lambda \times 12840}$$

Failure rate ( $\lambda_{sys}$ ) = 0.011315/h.

Availability ( $A_{sys}$ ):

$$\begin{aligned} A_{sys} &= 1 - (A_1 \bar{A}_2 \bar{A}_3 + \bar{A}_1 A_2 \bar{A}_3 + \bar{A}_1 \bar{A}_2 A_3 + A_1 \bar{A}_2 \bar{A}_3) \\ &= 1 - (0.204143 + 0.147559 + 0.097489 + 0.324177) \\ &= 1 - 0.773367 \\ &= 0.226633 \end{aligned}$$

$$\text{Availability for } RO_{sys} = 0.226633$$

$$\text{Failure rate } \lambda_{sys} = 0.011315 / h$$



University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

#### 4.4. Calculation of Availability in UF Units.

After analyzing the breakdown records in the past (Appendix – D), the reliability factors of UF units can be summarized as follows.

Table 4.3: Summary of reliability factors in UF system

Item	Running time(h)	Outage time (h)	No of starts	No of Outages	m (h)	r (h)	A	f	λ/h	μ/h
UF-1	6,727.30	3,236.15	8	7	840.91	462.31	0.64526	0.000767	0.0012	0.00216
UF-2	5,228.93	3,740.38	6	5	871.49	748.08	0.53810	0.000617	0.0011	0.00134
UF-3	3,921.48	3,264.38	6	5	653.58	652.88	0.50027	0.000765	0.0015	0.00153

Using above method, availability and failure rate of UF systems are also calculated

$$A = 0.919713$$

$$\lambda = 0.002381/h$$

Therefore, the total Desalination plant availability and failure rate is given below

$$A_d = 0.208437$$

$$\lambda = 0.014095/h$$

The reduction of failure rate can be demonstrated through the following (Figure: 4.3).

Reliability function,  $R(t) = e^{-\lambda t}$




Figure: 4.3- reduction of failure rates with the improvement in the system

#### 4.5. Suggestions and Calculation to Enhance the Reliability of Desalination Plant

Following two options can be proposed, as a target solution to improve the reliability.

- Relocation of existing VSD's to a better environment
- Reduction of salinity of feed water by adding ground water.

##### 4.5.1. Relocation of Existing VSDs

According to the history data, failure rate of high pressure pump variable speed drivers were significant. These failures affect the water purification system. Therefore, relocation of the VSDs to a proper environment is suggested. As an interim solution to avoid failures of VSDs, a temporary air conditioned cubicle was constructed enclosing the VSDs according to the space availability as shown in Figure 4.4 below.



University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)



Figure 4.4: Temporary isolation of VSD unit in Desalination plant.

Although the effectiveness of isolation from the existing environment was proven, it has created some difficulties in the maintenance work on membranes.

Therefore the suggestion was made to relocate the VSD's into separate partition in the next building coming under phase II of the project, which is close to this place and has air conditioning as well.

The detailed selection of equipment for the particular modifications and cost is given below.

### Selection of required size of cable

For selecting a suitable cable for this requirement, cable selecting guideline [8] was used.

- Motor capacity = 160 kW
- Full Load Motor Current = 288 A
- Required cable length = 73m
- Ambient air temperature = 30°C
- Ground temperature = 25°C
- Depth of laying = 0.6 m
- Soil thermal resistivity = 2 K.m/W

Considering the full load current, a suitable cable can be selected as follows:

Choice 01 : 3x120mm<sup>2</sup> Cu/XLPE/SWA/PVC

Applicable de-rating factors are as follows;

- For ambient air temperature (30°C) = 1
- Ground temperature (25 °C) = 0.93
- Depth of laying (0.6m) = 0.98
- For soil thermal resistivity (1.5K.m/W) = 0.83

Actual current rating =  $363 \times 1 \times 0.93 \times 0.98 \times 0.83 = 274.6A$

Therefore, selected cable is not sufficient for our application.

Choice 02 : 3x 150mm<sup>2</sup> Cu/XLPE/SWA/PVC

Actual current rating for the cable with de-rating factors = $406 \times 1 \times 0.93 \times 0.98 \times 0.83$   
=307.1A

Calculating the voltage drop =  $0.3 \times 289 \times 73$   
=6.33V<16V

(Maximum allowable voltage drop is 4% as per IEE wiring regulations)




Figure 4.5: Cross section of recommended symmetrical cable.

Using a symmetrical shielded cable is recommended to effectively suppress radiated and conducted radio-frequency emissions.

Therefore 3 x 150 Cu /XLPE/SWA/PVC is the suitable cable for above modification.

The costing for the particular modification is as follows.

Table 4.4: Cost for the modification listed as relocation of VSD's

	Description	Unit Cost (Rs)	Quantity	Total Cost(Rs)
1	3X150 Cu/XLPE/SWA/PVC	5,750	219.00	1,259,250.00
2	Cable lugs	500	18	9,000.00
3	Panels mounting material	3,500	3	10,500.00
4	Cost for control cable	2,500	250	625,000.00
5	sundry items	2,500	1	2,500.00
6	Total material cost			1,906,250.00
7	Labour charges	287	400	114,800.00
8	Transportation charges	20,000	1	20,000.00
<b>Total cost (Rs)</b>				<b>2,041,050.00</b>

#### 4.5.2. Dilution of Feed Water by Ground Water Source.

The major reason for the failure of RO membranes was identified as the high conductivity of sea water. Therefore, reduction of conductivity of RO feed water is the best solution to avoid membrane failures. Conductivity of feed water to RO units can be reduced to acceptable limits by mixing sea water with low salinity fresh water.



University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
www.lib.mrt.ac.lk

Water from a surface water source can be used to dilute sea water. However, as Kalpitiya peninsula is located in the dry zone, neither a fresh water stream nor a reservoir is available at a reasonable distance.

A geological survey was done to identify a suitable water source within the puttlam district boundary. A rich surface water stream was identified at Eluwankulamareawhich is located 10 km away from puttlam. The water source is fed from the famous river "Kala Oya".

It is necessary to mix sea water with fresh water in equal amounts to bring the conductivity to the recommended level of less than 50,000  $\mu\text{S}/\text{cm}$ .

Since the total water requirement for RO plant is 260  $\text{m}^3/\text{h}$ ; it is necessary to feed fresh water at the rate of 130  $\text{m}^3/\text{h}$  (around 2  $\text{m}^3/\text{min}$ ) to mix with a similar quantity of sea water.

A detailed historical data analysis was performed to find out the availability of water from this river to fulfill the requirement of RO plant to ensure satisfactory continuous operation. Actual flow discharge data collected by National Water Supply & Drainage Board for a period of one year from February 2010 to January 2011 was based for calculations.[12].

Table 4.5: Daily average flow discharge of Eluvankulamstream in m<sup>3</sup>/sec

Date Month	2010											2011
	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan
1	20.20	7.64	1.53	29.26	4.36	5.09	2.64	0.31	49.22	56.15	41.39	90.73
2	16.90	8.29	1.30	29.78	2.69	2.35	1.80	0.23	26.97	38.28	68.35	79.18
3	13.35	8.25	0.53	28.66	1.67	1.42	0.53	0.25	48.97	11.97	105.6	78.29
4	10.82	7.9	0.84	25.16	1.50	0.97	0.32	0.39	43.74	3.05	104.8	62.15
5	10.32	7.32	0.93	18.25	1.26	0.64	0.24	0.17	31.66	9.85	107.2	44.32
6	10.62	7.08	4.27	13.65	0.86	0.40	0.88	0.17	29.97	45.27	111	19.66
7	11.00	7.49	2.83	10.29	1.63	1.19	4.01	0.13	16.48	91.20	113	42.85
8	9.71	7.55	2.79	8.59	5.85	8.33	7.17	0.13	6.77	74.19	112.5	59.56
9	8.59	7.03	2.35	9.11	9.25	24.76	6.81	0.16	4.91	25.60	106.6	65.22
10	9.17	7.05	1.58	8.15	1.74	33.89	4.52	0.08	16.91	16.01	64.53	63.27
11	11.05	6.84	2.38	5.12	3.85	15.7	1.45	0.11	2.17	38.35	35.42	112.22
12	11.91	6.87	5.17	3.25	2.18	14.18	0.40	0.14	2.18	55.00	34.36	122.01
13	10.72	7.11	5.03	4.96	1.73	10.23	0.11	0.11	1.82	50.50	48.16	130.17
14	10.68	5.99	6.06	8.24	1.06	4.96	0.20	0.23	1.49	60.50	35.47	122.72
15	10.72	6.61	7.84	13.93	0.85	3.03	0.18	0.23	1.29	57.31	31.14	88.01
16	10.07	5.93	9.66	26.3	0.73	2.88	0.13	0.20	1.28	19.74	58.27	86.78
17	12.54	5.1	12.04	33.97	1.00	3.07	0.08	0.19	1.29	16.63	52.58	76.72
18	18.36	5.17	17.44	33.31	5.56	7.63	0.02	0.16	1.04	25.87	48.19	74.9
19	28.17	5.59	17.35	31.3	8.97	10.32	0.03	0.16	0.82	56.86	31.43	46.6
20	12.58	5.41	8.30	30.62	10.46	10.87	0.03	0.42	0.86	56.79	23.75	21.52
21	11.00	5.33	5.17	13.76	6.31	5.11	2.37	0.17	1.06	55.19	21.98	19.6
22	10.39	5.71	3.48	6.94	3.27	2.30	16.77	0.05	1.51	58.37	53.53	19.04
23	9.77	5.7	5.99	6.4	1.36	1.05	18.79	0.04	2.09	56.11	52.34	18.44
24	8.64	4.22	21.66	4.95	0.61	0.42	32.58	0.02	2.66	40.75	66.62	17.47
25	7.97	3	16.08	3.4	0.58	0.40	14.89	0.04	3.18	48.81	106.6	19.49
26	8.16	2.45	11.42	2.91	0.84	0.58	3.81	0.04	4.06	53.75	108.4	44.25
27	7.75	1.97	44.04	2.44	2.05	1.96	2.06	0.04	4.86	60.51	95.8	58.46
28	7.28	1.86	17.41	7.96	4.87	7.13	1.39	0.13	6.74	66.11	80.32	61.74
29		2.3	17.33	16.44	8.22	9.26	1.18	37.33	12.73	58.20	59.48	38.96
30		1.76	28.11	11.89	9.13	9.59	0.66	81.42	53.17	40.72	24.37	29.08
31		1.76		9.03		6.05	0.38		74.69		64.74	48.72
Maximum	28.17	8.29	44.04	33.97	10.46	24.76	32.58	81.42	74.69	91.20	112.99	130.17
Minimum	7.28	1.76	0.53	2.44	0.58	0.40	0.02	0.02	0.82	3.05	21.98	17.47



Average	11.73	5.56	9.37	14.77	3.66	6.10	4.08	4.11	14.28	44.25	66.71	61.42
Standard Deviation	4.42	2.11	9.73	10.58	3.17	5.97	7.25	16.10	20.08	20.75	31.59	34.25
Runoff (MCM)	28.38	14.89	24.3	39.83	9.49	16.35	10.93	10.66	38.25	114.7	178.7	164.52

A flow duration curve was drawn to find out the availability of required water quantity during a period of one year.




Figure 4.6: Flow duration curve at “Eluwankulam” gauging station.

It is clearly evident from above curve that the fresh water requirement can be met with an availability factor of 95% (ie. 345 days in an year) even with the flow rate of 10m<sup>3</sup>/min. As the requirement of the plant is only 2 m<sup>3</sup>/min, the remaining water flow is sufficient to maintain the eco – system stability.

The proposed 39 km piping layout connecting the fresh water source and the power plant is given in figure 4.7 below.




Figure 4.7: Proposed piping layout between the source and plant.

Cost is calculated by considering different pipe sizes as the independent parameter and corresponding cost components such as material cost, transport cost, laying cost and operational cost etc as dependent parameters. Then the suitable pump is selected considering the pump head and the costs of motor, installation, electrical control panel, spare parts and electricity.

Table 4.6: Cost calculation for proposed piping layout

NO.	DESCRIPTION	OPTION 1	OPTION 2	OPTION 3	OPTION 4	OPTION 5
<b>1</b>	<b>General Data</b>					
	Nominal Diameter (mm)	<b>180</b>	<b>225</b>	<b>250</b>	<b>300</b>	<b>350</b>
	Pipe Material	<b>HDPE</b>	<b>HDPE</b>	<b>HDPE</b>	<b>HDPE</b>	<b>HDPE</b>
	Pipe line length (m)	<b>38,000</b>	<b>38,000</b>	<b>38,000</b>	<b>38,000</b>	<b>38,000</b>
<b>2</b>	<b>Transmission Pipe Cost Analysis</b>					
<b>2.1</b>	<b>Basic Supplying cost Rs./mtr</b>					
	CIF value of pipes	2,200.00	3,010.00	4,900.00	7,406.00	10,100.00
	CIF value of special accessories	770.00	1,054.00	1,715.00	2,593.00	3,535.00
	Transport and clearing	297.00	407.00	662.00	1,000.00	1,564.00
	Custom duty	1,049.00	1,436.00	2,337.00	3,532.00	4,816.00
	Total cost for 1m material at site	4,316.00	5,907.00	9,614.00	14,531.00	20,015.00



Selected Diameter = 300 mm

**Static Head**

Suction head<sub>s</sub> = -6.4 m (MSL)

Delivery head<sub>d</sub> = 8 m (MSL)

Static Head = 14.4 m

**Friction losses**

Assuming all transmission pipes to be DI having a C = 130

Applying of Hazen William's Equation

$$h_f = 10.666 \times C^{(-1.85)} \times D^{(-4.87)} \times q^{(1.85)} \times L \quad [14]$$

$$C = 130$$

$$L = 38 \text{ km}$$

$$= 38000 \text{ m}$$

$$h_f = 32.4 \text{ m}$$



University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

**Velocity Head**

Cross sectional Area = 0.070686 m<sup>2</sup>

Flow velocity = 0.5 m/s

$$V^2/2g = 0.01 \text{ m}$$

Allow for minor losses

fittings at the pump = 4 m

Static head at pump

Discharge = 5 m

Pump Total Head = 43 m

Now Hydraulic power 
$$= \frac{\sigma \cdot g \cdot Q \cdot H}{1000 \cdot \eta} \text{ kW}$$

Where,

$$\sigma \text{ Density in kg/m}^3 \text{ (water)} = 1000\text{kg/m}^3$$

$$g \text{ Gravitational constant} = 8.81\text{m/s}^2$$

$$Q \text{ Flow rate in m}^3/\text{s} = 0.0333 \text{ m}^3/\text{s}$$

$$\eta \text{ Pump efficiency for mixed flow pump} = 63\%$$

$$\text{Hydraulic power of pump} = 14.06 \text{ kW}$$

Considering Motor efficiency(75%) and over capacity factor 115%

$$\text{Motor Power} = \underline{\underline{22 \text{ kW}}}$$

Same calculation is repeated for other pipe sizes to find the relevant motor power and the other cost components associated with motors of different ratings.



University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

Table 4.7  
Cost calculation for different motor capacities.

<b>1 Pumping Cost Analysis</b>						
<b>1.1 Pump General Data</b>						
Plant Capacity (m <sup>3</sup> /day)	2880	2880	2880	2880	2880	
No. of working Hours	20	20	20	20	20	
No. of Pumps						
Duty	1	1	1	1	2	
Stand By	1	1	1	1	1	
Pump Duty Point						
Flow Rate - Q (m <sup>3</sup> /min)	2	2	2	2	2	
Head (m)	401	142	90	43	26	
Motor Power (kW)	201	71	45	22	13	
<b>1.2 Cost for pumping system</b>						
Pump Supply Cost	3,843,000.00	1,952,000.00	1,464,000.00	915,000.00	585,600.00	
Installation cost	384,300.00	195,200.00	146,400.00	91,500.00	58,560.00	
Spare Part supply cost	768,600.00	390,400.00	292,800.00	183,000.00	117,120.00	
Electrical Panel boards						
Motor controller	3,904,000.00	1,830,000.00	1,220,000.00	256,200.00	170,800.00	
Installation cost	390,400.00	183,000.00	122,000.00	25,620.00	17,080.00	
Total cost for supply & installation of one pump with motor controller	9,290,300.00	4,551,600.00	3,245,200.00	1,471,320.00	949,160.00	
Total for two pumps	18,580,600.00	9,101,200.00	6,490,400.00	2,942,640.00	2,847,480.00	
Main power incoming section (Capacity for 1 duty pump)	1,220,000.00	451,400.00	390,400.00	292,800.00	231,800.00	
<b>Total Cost for Supply and installation of pumps and electrical panel boards</b>	<b>19,800,600.00</b>	<b>9,552,600.00</b>	<b>6,880,800.00</b>	<b>3,235,440.00</b>	<b>3,079,280.00</b>	
<b>1.3 Energy Cost for pump operation for one year</b>						
Power consumption	201	71	45	22	13	
<b>Assume plant to be operated 20 hrs/ Day X 365 days/ year X 20 years and cost for 1 kWh (Rs.) is 17.50.</b>						
Total energy consumption (kWh)	29,346,000	10,366,000	6,570,000	3,212,000	1,898,000	
<b>Total Energy cost (Rs)</b>	<b>513,555,000.00</b>	<b>181,405,000.00</b>	<b>114,975,000.00</b>	<b>56,210,000.00</b>	<b>33,215,000.00</b>	
Note:-All rates from Rate Book 2012 published by National Water Supply & Drainage Board (NWS&DB)						

The total installation cost and energy cost were combined to take the optimum pump and pipe specifications.

Table 4.8: Combination of pipe, pump cost and energy cost

Pipe Diameter (mm)	Pump Head (m)	Pipe line + Pump cost (MnRs)	Energy cost (MnRs)	Total (MnRs)
180	401	270	514	783
225	142	344	181	526
250	90	515	115	630
300	43	753	56	810
350	26	1,016	33	1,050

According to the above table, capital cost increases with the increase of pipe diameter, but at the same time energy cost decreases. Therefore, the pipe system has to be selected in such a way to minimize the total cost. These three variables are drawn in the graph (Figure 4.8). It can be clearly identified that the best economical pipe system is the one with a diameter of 225mm.


 University of Moratuwa, Sri Lanka.  
 Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)




Figure 4.8: Combined cost of initial cost and energy cost.

The minimum cost point is identified with respect to the pipe diameter 225mm and its cost is noted as Rs.525 Mn. The payback period is calculated below.

#### 4.6. Payback Period Calculation for the Proposal.

The cost to generate one unit of water is calculated by considering the in-house plant energy consumption, additional energy to pump water from the river and all maintenance cost components as follows.

Table 4.9: Calculation of unit cost for feed water as per the proposal

.	Description	Unit.	Amount	Remark
1	Annual water production requirement	m <sup>3</sup>	864,000	(2,400 x 30 x 12)
2	Energy consumption per day	kWh	7,776	
2.1	Annual energy consumption	kWh	2,799,360	
2.3	Annual energy cost for existing units	Rs.	27,993,600.00	Assume, electricity unit cost is Rs 10/kWh
3	Additional energy for supply surface water	kWh	190,080	(22 x 24 x 30 x 12)
3.1	Energy cost for additional pump	Rs.	2,536,960.00	Assume unit cost is Rs 12/kWh and Maxi Demand Charge is Rs 850/kVA
3	Annual membrane replacement cost	Rs.	9,464,000.00	According to membrane manufacture's manual(DOW FILMTEC) It has three year warranty period for recommended operation limits)
3.1	Annual VSD maintenance cost	Rs.	1,340,000.00	(6,700,000.00/5)
4	Annual Chemical usage cost	Rs.	26,800,000.00	(33,500,000 x 80%)
5	Annual manpower cost	RS.	6,480,000.00	(80,000 x 3 x 12+50,000 x 6 x 12)
6	Total maintenance and Operation cost	Rs.	74,664,560.00	
7	Unit production cost of water with the proposed system	Rs./m <sup>3</sup>	85.41	(74,664,560/864,000)



As calculated in Table 4.1 (page 25), the unit cost of feed water at present is Rs. 161.04, taking into consideration the operation and maintenance costs.

Therefore, the annual cost savings (Rs) = (161.04-85.41) x 2,880 x 365

= Rs. 79,502,256.00

Total project cost (Rs) = 528,041,050.00

Payback period (Years) =  $\frac{528,041,050.00}{79,502,256.00}$

= **6.6**

As the expected life time of the plant is 30 years, this payback period is desirable.



University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

### 5.1. Introduction to Demineralization Plant (RO-2 plant).

De-mineralized water production plant mainly consists of domestic water RO system which is commonly named as RO-2 and ion exchange process. Conductivity of water produced from desalination plant should be less than  $2,000 \mu\text{S cm}^{-1}$  to be treated in this RO-2 plant [1]. RO-2 system will reduce the conductivity of water below  $50 \mu\text{S cm}^{-1}$ . It is further reduced to  $0.2 \mu\text{S cm}^{-1}$  after passing through the ion exchange columns. Treated water from RO-2 system is used to fulfill the potable water requirement of the plant as well.

Treated water from RO-1 unit is pumped through RO membranes using high pressure pumps. Then the water is stored in an intermediate storage tank called RO-2 water tank. Part of this water is sent through limestone filters to make potable water. Rest of the water is sent through a cation bed, de-gasifier, anion bed and a mix bed connected in cascade. The final product is collected in a storage tank as demineralized water which is suitable to be fed into the boiler.




Figure 5.1: Flow diagram of Demineralization system.

The system operating data was collected to identify the causes and durations of failures to identify and explore the areas which need modifications or improvements. The collected data is summarized below.

Table 5.1 System outage data in demineralization unit.

<u>Time of start</u> <u>Time of Failure</u> <small>(mm/dd/yyhh:mm)</small>	<u>Time of Restoration</u> <small>(mm/dd/yyhh:mm)</small>	Incident	Outage (h)
11/16/11 9:38	11/16/11 16:11	Ro-2 System (HP pump #1)	6.55
10/19/11 9:20	10/19/11 17:40	Ro-2 System (HP pump #2)	8.33
9/30/11 9:35	10/1/11 18:10	Degasified blower	32.58
9/30/11 10:45	10/1/11 18:20	Anion Bed #1	31.58
12/8/11 8:35	1/5/12 9:33	Broken pipe line which connect with portable water tank	672.97
5/21/12 8:13	5/22/12 8:45	Anion Bed #2	24.53
4/19/12 15:05	4/21/12 17:05	Degasified blower	50.00
4/19/12 3:18	4/21/12 5:10	Anion Bed #1	49.87
<b>Total Outage</b>			<b>876.42</b>

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together



The longest outage during this evaluation period was caused by a failure of pipe line which is not directly related to the demineralization process. However, the second longest outage was due to the failure of blower attached to the de-gasifier unit. There is only a single blower installed according to the design and no redundancy is available in case of a failure of the blower. Further, a failure of degasifier blower will cause an overload on the anion bed located next causing it to cease the iron exchange operations and shut its inlet and outlet valves.

Using the above data equipment wise reliability indices can be calculated to facilitate making recommendations to improve availability.

Table 5.2: Equipment wise reliability factors.

Equipment	Running (h)	Outage (h)	No of running times	No of Outages	M (h)	r (h)	Availability	f	λ/h	μ/h
Ro-2 System (HP pump #1)	10,845	6.55	3	2	3,615.00	3.275	0.999	0.000276	0.000277	0.305
Ro-2 System (HP pump #2)	10,845	8.33	2	1	5,422.50	8.333	0.998	0.000184	0.000184	0.120
Degasified blower	10,845	82.58	4	3	2,711.25	27.527	0.990	0.000365	0.000369	0.036
Anion Bed #1	10,845	31.58	5	4	2,169.00	7.896	0.996	0.000459	0.000461	0.127
Pipe Line	10,845	672.97	5	4	2,169.00	168.242	0.928	0.000428	0.000461	0.006
Anion Bed #2	10,845	24.53	2	1	5,422.50	24.533	0.995	0.000184	0.000184	0.041
Anion Bed #1	10,845	49.87	3	2	3,615.00	24.933	0.993	0.000275	0.000277	0.040
		876.42			417.12	45.21	0.902214	0.002356	0.002397	0.751

Therefore, demineralization plant has an availability of 0.902214 and a failure rate of 0.002397/h.

### 5.2. Suggestions to Improve System Reliability.

The easiest point of improvement is the degasifier by installing an additional blower (Figure 5.2) to operate on standby basis to avoid the tripping of entire plant. It can be demonstrated as follows in the graphic window which is in the control system.



University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
www.lib.mrt.ac.lk




Figure 5.2: Proposed standby blower to degasifier.

In order to connect the additional blower to degasifier it is needed to modify the logic ladder diagram in PLC program as follows.




Figure 5.3: Proposed logic modification in PLC ladder program

Legends of the gates are as follows.

**Inputs**

- Manual mode selection I0.0
- Auto mode selection I0.1
- P1 manual start I0.2
- P1 manual stop I0.3
- P2 manual start I0.4

- P2 manual stop I0.5
- Auto sequence start I0.6
- Auto sequences stop I0.7
- P1 thermal overload I1.0
- P2 thermal overload I1.1

**OUT PUTS**

- P1 start Q0.0
- P2 start Q0.1

After doing this implementation, failures in the degasifiers and anion bed systems can be reduced.

According to the new design, two identical degasifiers are in parallel. Therefore, the availability of this particular section can be calculated as follows:

$$\begin{aligned}
 A_p &= A_1 \times A_2 \\
 &= (1 - A_1) \times (1 - A_2) \\
 &= A_1 = A_2 \\
 &= (1 - 0.990) \times (1 - 0.990) \\
 &= 0.01 \times 0.01 \\
 &= 0.0001
 \end{aligned}$$

$$A_p = (1 - A_p)$$

$$= 0.9999$$

Mean running value of parallel blowers are denoted by  $m_p$

$$m_p = \frac{1 + \lambda_1 r_1 + \lambda_2 r_2}{(\lambda_1 \lambda_2)(r_1 + r_2)}$$



University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

Where,

$\lambda_1$  = Failure rate of blower 1

$\lambda_2$  = Failure rate of blower 2

$r_1$  = Mean repair time of blower 1

$r_2$  = Mean repair time of blower 2

Assuming the identical blowers having same failure rates,  $\lambda_1 = \lambda_2$

Therefore, the mean value of above parallel system can be calculated as follows:

$$\begin{aligned}
 &= \frac{1 + 0.000369 \times 27.527 + 0.000369 \times 27.527}{(0.000369 \times 0.000369)(27.527 + 27.527)} \\
 &= 13000
 \end{aligned}$$

Failure rate  $\lambda_p = 1/\bar{m}_p$   
 $= 0.00000075/h$

Considering these values and other existing reliability factors, the expected factors can be obtained.

Expected reliability factors are as follows:

Table 5.3: Expected equipment wise reliability factors.

Equipment	Running (h)	Outage (h)	No of running times	No of Outages	m (h)	r (h)	Availability	f	$\lambda/h$	$\mu/h$
HP pump #1	10845.00	6.55	3	2	3,615	3.28	0.999	0.000276	0.000277	0.305
HP pump #2	10845.00	8.33	2	1	5,422	8.333	0.998	0.000184	0.000184	0.120
Pipe Line	10845.00	672.97	5	4	2,169	168.24	0.928	0.000428	0.000461	0.006
Anion Bed	10845.00	49.87	3	2	3,615	24.93	0.993	0.000275	0.000277	0.040
Blower 1&2							0.9999		0.0000075	
		737.72			<b>834.23</b>	<b>73.12</b>	<b>0.919413</b>	0.001163	0.001199	0.471

Now availability is increased to 0.919413 and failure rate is reduced to 0.001199. This is a good achievement for boiler water production system.




Figure 5.4: Graphical representation of the improvement of reliability.

We can clearly see that from the above graph (Figure 5.4), that failure rate will be reduced after the improvement.

## Chapter 6

### CHLORINATION PLANT

#### 6.1 Operation of Chlorination Plant.

The electro chlorination system operates on 44V DC power derived from the 6kV AC system using a transformer and rectifier. The DC voltage is applied between the cathode and anode of the electrolytic cell to electrolyze the seawater and produce sodium hypochlorite. The hypochlorite is then injected into cooling seawater using two dosing methods. A continuous dosage of mg/l is carried out using one pump and an impulsive dosage of 3mg/l is performed three times a day using three pumps.[6].




Figure 6.1: Layout of the chlorination plant.

Sodium hypochlorite produced by the electro chlorination system is used to destroy the organisms in seawater. Otherwise, massive marine organism breeds, grows and attaches to the surfaces of the cooling water pipelines, debris filers and condenser coil pipes can degrade the conveying capability of pipelines, reduce the cooling efficiency of the condenser, and force the generator to run at lower loads.



## 6.2 Calculation of Availability

The identified defects and frequency of occurrence for the entire chlorination plant are tabulated as follows.

Table 6.1: Equipment outages and running hours record.

Equipment	Running Hrs	Outage (h)	No of Operations	No of Outages
sea water pre filter#1	12,663.50	46.97	3	2
sea water pre filter#2	12,663.50	14.75	3	2
sea water pre filter#3	12,663.50	43.12	3	2
sea water pump #1	12,663.50	1,272.50	3	2
sea water pump #2	12,663.50	29.40	2	1
sea water pump #3	12,663.50	344.18	3	2
Auto back wash filter #1	12,663.50	15.67	3	2
Auto back wash filter #2	12,663.50	20.40	4	3
Sea water cooling booster pump-1	6,485.40	3,311.33	5	4
Sea water cooling booster pump-2	6,178.10	3,591.00	4	3
Rectifier #1	6,485.40	851.73	3	2
Rectifier #2	6,178.10	1,651.35	4	3
NaOCl Dosing pipe line	12,663.50	71.78	8	7

Using above data, the following reliability indices can be calculated.

Table 6.2: Calculated equipment wise reliability indices.

Equipment	m	r	Availability	f	$\lambda/h$	$\mu/h$
Sea water pre filter#1	4,221.17	23.48	0.99447	0.000236	0.0002	0.04258
Sea water pre filter#2	4,221.17	7.38	0.99826	0.000236	0.0002	0.13559
Sea water pre filter#3	4,221.17	21.56	0.99492	0.000236	0.0002	0.04639
Sea water pump#1	4,221.17	636.25	0.86901	0.000206	0.0002	0.00157
Sea water pump#2	6,331.75	29.40	0.99538	0.000157	0.0002	0.03401
Sea water pump#3	4,221.17	172.09	0.96083	0.000228	0.0002	0.00581
Auto back wash filter #1	4,221.17	7.83	0.99815	0.000236	0.0003	0.12766
Auto back wash filter #2	3,165.88	6.80	0.99786	0.000315	0.0008	0.14706
Sea water cooling booster pump#1	1,297.08	827.83	0.61042	0.000471	0.0008	0.00121
Sea water cooling booster pump#2	1,544.53	1,197.00	0.56338	0.000365	0.0006	0.00084
Rectifier #1	2,161.89	425.87	0.83542	0.000586	0.0005	0.00235
Rectifier#2	1,544.53	550.45	0.73725	0.000477	0.0006	0.00182
NaOCl dosing pipe line	1,582.94	10.25	0.99356	0.000428	0.0006	0.09752

The individual reliability indices are combined according to the process path design to calculate the total failure rate and total system availability.




Figure 6.2: Process layout of the chlorination plant.

Considering the series combination of equipment of chlorination plant present failure rate and availability can be calculate as follows.

$$\begin{aligned}\text{Total failure rate } (\lambda) &= \lambda_1 + \lambda_2 + \lambda_3 + \lambda_4 + \lambda_5 \\ &= 0.000674 + 0.0001998 + 0.00033855 + 0.000352 + 0.000628 \\ &= \mathbf{0.00219/h}\end{aligned}$$

$$\begin{aligned}\text{Total system availability } (A) &= A_1 \times A_2 \times A_3 \times A_4 \times A_5 \\ &= 0.992952 \times 0.999996 \times 0.829901 \times 0.956757 \times 0.993560 \\ &= \mathbf{0.78334}\end{aligned}$$

This value indicates a low availability rate of 78.3%.

Two major defects which directly contributed to the failure of chlorination plant were observed. Major design changes were identified to improve the reliability of the chlorination system.

First defect is the regular damage of mechanical water seal in the sea water cooling pumps which feed water to heat-exchangers. High content of sand in the sea water causes damages the carbon water seals of pumps. Leaking water seals is a very common sight at the chlorination plant (Figure 6.3).



Figure 6.3: water leak through mechanical seal.

In order to prevent the damage caused by sand to the booster pump mechanical seals it is suggest to install sand filter before the booster pump with a bypass line as follows.(Figure 6.4)




Figure 6.4: Installation of sand filter to protect booster pump.



University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

The second defect is inadequate dosing of NaOCl to the pump intake due to wrong piping layout from the chlorination plant to cooling water intake. This insufficient dosing fails to arrest the growth of barnacles and causes blockage of the sea water intake(Figure 6.5).



Figure 6.5: Barnacles growth in bar screen due to lack of dosing of NaOCl .

According to the design there must be two distinct dosing modes of NaOCl to the cooling intake head and pump bay (continuous and shock dosing). Continuous dosing is done at the sea water intake where as shock dosing is done at the pump bay. In the initial section, the same pipe line (DN125) is used for both purposes as shown in figure 6.6.




Figure 6.6: present pipe line arrangement.

The disadvantage of this arrangement is that the common section of pipe line frequently gets damaged due to the high pressure of shock dosing pumps. Then the continuous dosing too is affected due to leakages and pressure drops.

Presently continuous dosing is attempted using gravity flow as the operation of pumps aggravates leakages. However, this arrangement violates the designs and provides virtually no chlorination.

For proper operation of dosing systems the velocity of NaOCl along a pipe should be between 1.5 m/s and 3 m/s. Slower speeds would cause coagulation while higher speeds need higher pressures which may cause damages to pipe line. In the present system the speed of continuous dosing at the common section of pipeline is too slow

because it has a larger diameter to accommodate the flow required for the shock dosing. Therefore, this section tends to be blocked due to coagulation.

The correct design is to use two separate pipe lines for the two types of dosing as shown in figure 6.7.

The following situation is considered:

- Design Point: continuous dosing ( $34 \text{ m}^3/\text{h}$ ) in DN125  $\Rightarrow v = 0.77 \text{ m/s}$
- Current operation: gravity dosing (ca.  $25 \text{ m}^3/\text{h}$ ) in DN125  $\Rightarrow v = 0.56 \text{ m/s}$
- Current operation: dosing pump (ca.  $80 \text{ m}^3/\text{h}$ ) in DN125  $\Rightarrow v = 1.8 \text{ m/s}$

This means that the chlorination plant, which is presently operated by gravity in the continuous dosing mode alone, is sending a  $\text{NaOCl}$  solution along the DN125 distribution pipe at a velocity of  $1.8 \text{ m/s}$ , which is far too low. The risk of forming deposit scales is considered very high. It is suggested to inspect the dosing pipe to find out if scaling deposits have already occurred and suitable actions should be taken to clean the same.



University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

As an improvement, it is proposed to install a separate dosing pipe (DN80) from the continuous dosing pumps header into the Intake. Each line shall be equipped with flow control valves and respective control loops (see proposal in Figure 6.6). In this way during continuous dosing to the Intake a pipe velocity of  $1.9 \text{ m/s}$  will be achieved, which is deemed appropriate. For shock dosing ( $102 \text{ m}^3/\text{h}$ ) the current DN125 pipe to Pump bay will have a velocity of  $2.3 \text{ m/s}$ , which is also deemed appropriate.




Figure 6.7: Proposal for installation of separate dosing line (DN80) and necessary flow control equipment

By implementing the above modifications the expected results are as follows.

Let's assume the failure time is reduced by 50% after introducing sand pre-filter for booster pump line and the dosing lines are in separate parallel circuit.

Failure rate for cooling water booster pumps  $\lambda_3 = 0.000201$

Availability of booster pumps  $A_3 = 0.9339$

Failure rate of new dosing line  $\lambda_5 = 0.00000074$

Availability  $A_5 = 0.999995$

$$\begin{aligned} \text{Total failure rate } (\lambda) &= \lambda_1 + \lambda_2 + \lambda_{3 \text{ new}} + \lambda_4 + \lambda_{5 \text{ new}} \\ &= 0.000674 + 0.0001998 + 0.000201 + 0.000352 + 0.00000074 \\ &= \mathbf{0.001427/h} \end{aligned}$$

$$\begin{aligned} \text{Total system availability } (A) &= A_1 \times A_2 \times A_{3 \text{ new}} \times A_4 \times A_{5 \text{ new}} \\ &= 0.992952 \times 0.999996 \times 0.9339 \times 0.956757 \times 0.999995 \\ &= \mathbf{0.88721} \end{aligned}$$

The comparison of reliability improvement before and after the modification is as follows.




Figure 6.8 :Reliability curve of chlorination system before and after the modifications.

According to the graph shown in figure 6.8, show a clear improvement of the reliability by the proposed design.



University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)



#### 7.1. Introduction to Hydrogen Plant.

To fill the air gap between the stator and rotor is filled with highly purified hydrogen gas, considering its excellent qualities comparing with conventional air. The pressure of hydrogen in the generator needs to be maintained at 0.3 M Pa with 98% purity to obtain an efficient cooling at the rated load of 300 MW [1]. Due to the explosive nature of hydrogen, CEB operation and maintenance crew pays extra attention to the whole area covering the generator, hydrogen feeding and piping system, hydrogen generation plant as well as storage premises.

Hydrogen plant contains two electrolyzers. Each unit has a generating capacity of 5 m<sup>3</sup>/h of Hydrogen. Daily use of hydrogen in generator is in between 30-50 m<sup>3</sup>. Therefore generating capacity is clearly sufficient to fulfill the requirement of hydrogen in the power station. During maintenance periods the generator hydrogen will be replaced with carbon dioxide as a safety measure. Therefore during the startup procedure, extra amount of hydrogen is needed to re-fill the generator enclosure. For this purpose more than 800 m<sup>3</sup> of hydrogen is required. Total hydrogen storage capacity of the plant is 1,000 m<sup>3</sup>. Provided by four storage tanks with a capacity of 250 m<sup>3</sup> each. Therefore, hydrogen storage capacity is insufficient for two consecutive fillings if a need arises. (Figure 7.1). During the time of data collection there was one incident on 16/02/2012 where the generator failed to start after a repair and a second filling of hydrogen was needed. However, as the remaining capacity of the tanks (200 m<sup>3</sup>) was not sufficient and the total Hydrogen production capacity is 240 m<sup>3</sup>/day, the start of power plant was delayed by 4 days. No new Hydrogen tanks are included in the second stage of the power plant as well. With the operation of the second stage the possibility of needing two consecutive fills would be further increased.



Figure 7.1: Hydrogen storage tanks with the total capacity of 4 x 250 m<sup>3</sup>

## 7.2. Unit Wise Availability and Failure Rate Calculations

The system operating data was collected to identify the causes of failures and durations to have an idea to explore the areas which need modifications or improvements. The entire hydrogen plant is sub divided in to three units as generation plant No: 01, generation plant No: 02 and storage tank. The collected data can be summarized as follows:



University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
www.lib.mrt.ac.lk

Table 7.1: Plant No - 01 Outage data

	<b>Item</b>	<b>Time of start Time of Failure</b> (mm/dd/yyhh:mm)	<b>Time of Restoration</b> (mm/dd/yyhh:mm)	<b>Outage time(hrs)</b>
1	Power failure of Electrolyzer #1	1/18/2012 12:10	2/11/12 10:45 AM	574.58
2	Plant #1 PLC fault	2/2/2012 14:00	2/11/12 4:43 PM	218.72
3	Solenoid valve #1	5/3/2012 8:07	5/3/12 4:16 PM	8.15
4	Rectifier fault #1	4/10/2012 10:18	4/11/12 11:10 AM	24.87
5	Solenoid valve #1	4/9/2012 14:07	4/9/12 3:05 PM	0.97
<b>Total Outage</b>				<b>827.28</b>

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together

Table 7.2: Plant No - 02 Outage data

	<b>Item</b>	<b>Time of start Time of Failure</b> (mm/dd/yyhh:mm)	<b>Time of Restoration</b> (mm/dd/yyhh:mm)	<b>Outage time(hrs)</b>
1	Humidity Analyzer #2	1/18/2012 14:03	2/13/12 3:52 PM	625.82
2	Rectifier cooler #2	5/17/2012 10:45	5/17/12 12:10 PM	1.42
3	Feed water pump #2	4/30/2012 14:49	5/4/12 11:00 AM	92.18
4	Solenoid valve #2	4/9/2012 14:07	4/9/12 3:05 PM	0.97
<b>Total Outage</b>				<b>720.38</b>

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together, Tab stops: Not at 1.18" + 1.58" + 6.1"

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together, Tab stops: Not at 1.18" + 1.58" + 6.1"

Table 7.3: Outage data for storage tank.

	<b>Item</b>	<b>Time of start Time of Failure</b> (mm/dd/yyhh:mm)	<b>Time of Restoration</b> (mm/dd/yyhh:mm)	<b>Outage time (h)</b>
1	 Storage tank capacity problem	2/16/2012 8:30	2/19/12 9:45 PM	85.25

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together, Tab stops: Not at 1.18" + 1.58" + 6.1"

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together, Tab stops: Not at 1.18" + 1.58" + 6.1"

Above facts can be combined to calculate reliability factors as follow:

Table 7.4: Calculated summary of reliability factors for entire Hydrogen system.

Equip ment	Running (h)	Outage (h)	No of running time	No of Outages	m (h)	r (h)	A	F	λ/h
Unit #1	6,350	827.28	6	5	1,058.33	165.46	0.86480	0.000817	0.0009
Unit#2	5,440	720.38	5	4	1,088.00	180.10	0.85798	0.000789	0.0009
Storage tank	8,674	85.25	2	1	4,337.38	85.25	0.98072	0.000226	0.0002

Hydrogen system can be represented by the following block diagram and the reliability factors can be combined as follows.




Figure 7.2: Simplified block diagram of hydrogen plant.

Hydrogen generators number one and two are in parallel. Therefore, the availability of this particular section can be calculated as follows:

$$\bar{A}_p = \bar{A}_1 \times \bar{A}_2$$

$$= (1 - A_1) \times (1 - A_2)$$

$$= (1 - 0.86480) \times (1 - 0.85798)$$

$$= 0.1352 \times 0.14202$$

$$= 0.01920$$

$$A_p = (1 - \bar{A}_p)$$

$$= \mathbf{0.9808}$$

Mean running value of parallel system is denoted by  $\bar{m}_p$

$$\bar{m}_p = \frac{1 + \lambda_1 r_1 + \lambda_2 r_2}{(\lambda_1 \lambda_2)(r_1 + r_2)}$$

Where,

$\lambda_1$  = Failure rate of system 1

$\lambda_2$  = Failure rate of system 2

$r_1$  = Mean repair time of system 1

$r_2$  = Mean repair time of system 2



Therefore, the mean value of above parallel system can be calculated as follows:

$$\frac{1+0.0009 \times 165.46+0.0009 \times 180.10}{(0.0009 \times 0.0009)(165.46+180.10)}$$

$$= 4683.79$$

$$\text{Failure rate } \lambda_p = 1/\bar{m}_p$$

$$= 0.000214/h$$

Since the Electrolyzers and storage tanks are in series, their total system availability and failure rates are calculated as follows:

$$\text{Total system Availability( } A_T) = A_p \times A_3$$

$$= 0.9808 \times 0.98072$$

$$= 0.9619$$

System failure rate



$$\lambda_p + \lambda_3$$

$$= 0.000214 + 0.0002$$

$$= 0.000414/h$$

University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
www.lib.mrt.ac.lk

After eliminating the storage issue by installing additional identical H<sub>2</sub> storage tanks to the system and assuming these H<sub>2</sub> tank also have same failure rate and availability, the present system the failure rate and availability can be calculated as follows.

Because propose H<sub>2</sub> tanks are installed in parallel to the existing tanks,

$$A_{ht} = A_3 \times A_3$$

$$= (1-A_3)^2$$

$$= (1- 0.98072)^2$$

$$= 0.0003717$$

$$A_{ht} = (1-A_{ht})$$

$$= 0.99962$$

Mean running value of parallel system is denoted by  $m_{ht}$

$$m_{ht} = (1 + \lambda_1 r_1 + \lambda_2 r_2) / [(\lambda_1 \lambda_2)(r_1 + r_2)]$$

Where,

$$\lambda_1 = \lambda_2$$

Therefore, the mean value of above parallel system,

$$m_{ht} = 146,670.19$$

Failure rate  $\lambda_p = 1/m_{ht}$

$$= 0.0000068/h$$

Total system Availability,

$$A_T = A_p \times A_{ht}$$

$$= 0.9808 \times 0.99962$$

$$= 0.9804$$

System failure rate

$$\lambda_s = \lambda_p + \lambda_{ht}$$

$$= 0.000214 + 0.0000068$$

$$= \mathbf{0.00022/h}$$



University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)




Figure 7.3: Improvement of reliability with the modification to H<sub>2</sub> generation plant.

Additional expenditure for installing additional storage tanks with a total capacity of 1,000 m<sup>3</sup> is around Rs. 3 million and it is not a considerable cost when the opportunity cost for improving the availability of power plant.



University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
www.lib.mrt.ac.lk

## Chapter 8

### COST ANALYSIS

The invoices in puttalam coal power project and some quotations called from various organizations were used for the cost analysis. Here the financial loss due to loss of a unit from LVPS is approximated as nine rupees.

#### 8.1. Cost estimation for installing new dosing pipe arrangement for Chlorination plant.

Because of solution are given for some of dosing system failures in chlorination plant, the related outages in chlorination system and maintenance cost ignored and considered only the energy loss due to blocking the debris filters in main machine.

Table 8.1: Cost estimation for constructing new dosing pipe arrangement for Chlorination plant.

NO.	DESCRIPTION		
<b>1</b>	<b>General Data</b>		
	Nominal Diameter (mm)	125	80
	Pipe Material	FRP	FRP
	Pipe line length (m)	25	40
<b>2</b>	<b>Pipe Cost</b>		
<b>2.1</b>	<b>Basic Supplying cost</b>		
	CIF value Rs/m	13,124.80	7,675.20
	CIF value for specials	5,249.92	3,070.08
	Transport & clearing	125.00	115.00
	<b>Total cost for 1m material at site</b>	<b>18,499.72</b>	<b>10,860.28</b>
<b>2.2</b>	<b>Pipe laying Cost</b>		
	Basic laying cost	474.00	276.00
	Excavation cost	216.00	206.00
	Cost for specials	280.00	240.00
	Cost for hydro test	32.00	37.00
	Total laying cost for one meter	1,002.00	759.00
	Price escalation factor	1	1
	<b>Estimated cost for pipe laying for transmission line</b>	<b>25,050.00</b>	<b>30,360.00</b>
	Cost for motorized butterfly valve	187,200.00	139,776.00
	No of valves	2	1
	Total cost for motorized butterfly valve	374,400.00	139,776.00
<b>2.3</b>	<b>Total cost for Supplying and laying cost of FRP Pipe line</b>	<b>1,463,143.00</b>	<b>1,788,587.20</b>
	<b>Total cost for proposed modification (Rs.)</b>		<b>3,251,730.20</b>



Energy could be recovered from loss = 9,000,000 kWh  
 Saving from a unit generation of LVPS = Rs 9.00  
 Total expected annual saving by the new design =Rs 81,000,000.00  
 Total cost for new improvement = Rs3200000.00  
 Simple payback period =  $\frac{3,200,000}{81,000,000}$  years  
 = **0.5 Month**

The simple payback period for proposed improvement is very low. Therefore this proposal can be considered as an economical viable.

### 8.2. Cost estimation for installing new sand filter for booster pump at Chlorination plant.

Total cost for install a sand filter before the booster pump with a bypass line as follows.

Table 8.2: Cost estimation for installing new sand filter for booster pump at,



University of Moratuwa, Sri Lanka.  
 Chlorination plant.  
 Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

	Item	Quantity	Unit Cost (Rs)	Total Cost(Rs)
1	"Y" type strainer	2 Nos.	16,400.00	32,800.00
2	2" PVC pipe L-bow	4 Nos.	250.00	1,000.00
3	2" PVC pipe T-socket	3 Nos.	320.00	960.00
4	2" PVC 4m pipe	2 Nos.	2,520.00	5,040.00
5	sundry items	1 Item	500.00	500.00
	<b>Total material cost</b>			<b>40,300.00</b>
	Labour charges	8*2	287.00	4,592.00
	Transportation charges	1	1,000.00	1,000.00
	Total cost			<b>45,892.00</b>

Total maintenance cost saving per year = Rs 300,000.00

Total cost for new improvement = Rs 45,892.00

Simple payback period =  $\frac{45,892}{300,000}$  years

= **2 month**

The simple payback period for proposed improvement in booster pumps is very low. Therefore this proposal can be considered as an economical viable project.

### 8.3. Cost estimation for installing new vertical mixed flow spindle pumps for Sea water intake.

The cost for supplying and installing new vertical mixed flow spindle pumps for sea water intake are calculated by using year 2013 market price in table 8.3.

Table 8.3: Cost estimation for installing new vertical mixed flow spindle pumps for sea water intake.

	Item	Quantity	Unit Cost (Rs)	Total Cost(Rs)
1	35 kW mixed flow pump	4 Nos.	2,100,000.00	8,400,000.00
2	supporting material cost	4 Nos.	100,000.00	400,000.00
	<b>Total material cost</b>			<b>8,800,000.00</b>
	Installation charges	8*12*10	300.00	288,000.00
	<b>Total cost</b>			<b>9,088,000.00</b>

Considering only cost saving for motor rewinding cost per year = Rs 1,100,000.00

Total cost for new improvement = Rs 9,088,000.00

Simple payback period =  $\frac{9,088,000}{1,100,000}$  years

= **8.3 years**

Plant has a 30 year life time period. Therefore this project can be considered as an economical viable project.

**8.4. Cost estimation for relocating the Existing VSDs.**

Considering the local market prices estimated total cost for relocate the existing VSDs in table 8.4

Table 8.4:Cost estimation for relocating the existing VSDs.

	Item	Quantity	Unit Cost (Rs)	Total Cost(Rs)
1	3x150 Cu/XLPE/SWA/PVC	219 m	5,750.00	1,259,250.00
2	Cable lugs	18 nos.	500.00	9,000.00
3	Panels mounting material	3 Nos.	3,500.00	10,500.00
4	Control cable	250 m	2,500.00	625,000.00
5	sundry items	1 No.	2,500.00	2,500.00
	<b>Total material cost</b>			<b>1,906,250.00</b>
	Labour charges	8*5*10	287.00	114,800.00
	Transportation charges	1 item	20,000.00	20,000.00
	<b>Total cost</b>			<b>2,041,050.00</b>

Considering the failures for one year period maintenance cost for repairing VSDs salty deposits on the circuit board.

Maintenance cost saving per year = Rs 6,700,000.00

Total cost for new improvement = Rs 2,041,050.00

Simple payback period =  $\frac{2,041,050}{6,700,000}$  years

= **3.5 Month**

The simple payback period for relocating the Existing VSDs improvement is very low. Therefore this proposal can be considered as an economical viable project.

**8.5. Cost estimation for installing of standby blower to degasified system.**

Total cost calculation for installing standby blower to present degasified system are given in table 8.5

Table 8.5: Cost estimation for installing of standby blower to degasified system.

	<b>Item</b>	<b>Quantity</b>	<b>Unit Cost (Rs)</b>	<b>Total Cost(Rs)</b>
1	2.2kW blower fan	1 No.	250,000.00	250,000.00
2	supporting material cost	1 No.	10,000.00	10,000.00
3	Cable cost	1 No.	20,500.00	20,500.00
4	Contactora and relay	1 Nos	12,500.00	12,500.00
5	sundry items	1 Item	500.00	500.00
	<b>Total material cost</b>			<b>293,500.00</b>
	Labour charges	8*2*3	287.00	13,776.00
	Transportation charges	1	5,000.00	5,000.00
	<b>Total cost</b>			<b>312,276.00</b>

Considering total maintenance cost for last year = Rs 240,000.00

Assumed this maintenance cost will be reduced by 50% after introducing new standby blower.

Now expecting Maintenance cost saving =Rs 120,000.00

Total cost for new improvement = Rs 312,276.00

Simple payback period =  $\frac{312,276}{120,000}$  years

= **2.6 year**

The simple payback period for installing of standby blower to degasified system is very low. Therefore this proposal can be considered as an economical viable project.

**8.6. Cost estimation for installation of new hydrogen tanks system.**

According to year 2013 market price total H<sub>2</sub> storage tanks installing cost was calculated in table 8.6

Table 8.6: Cost estimation for installation of new hydrogen tanks system.

	Item	Quantity	Unit Cost (Rs)	Total Cost (Rs)
1	200m <sup>3</sup> H <sub>2</sub> tank	4 Nos.	600,000.00	2,400,000.00
2	20mm 304 SS pipe	100 m	250.00	25,000.00
3	20mm Valve	4 Nos.	15,000.00	60,000.00
4	20 mm Pneumatic valve	4Nos.	35,000.00	140,000.00
5	sundry items	10 Nos.	500.00	5,000.00
	<b>Total material cost</b>			<b>2,630,000.00</b>
	Labour charges	8*3*10	287.00	68,880.00
	Transportation charges	1 item	50,000.00	50,000.00
	<b>Total cost</b>			<b>2,748,880.00</b>

Energy could be recovered from loss = 25,575MWh

Saving from a unit generation of LVPS =Rs 9.00

Total expected annual saving by the new design =Rs230,175,000.00

Total cost for new improvement =Rs2,748,880.00

Simple payback period =  $\frac{2,748,880}{230,175,000}$  years

= **5 Days**

The simple payback period for proposed improvement is very low. Therefore this proposal can be considered as an economical viable.

---

### CONCLUSION AND RECOMMENDATIONS

#### 9.1 Conclusion.

The objective of this study is to evaluate the reliability in Balance of Plant section including sea water pre treatment plant, desalination plant, demineralization system, chlorination plant and hydrogen generation plant against the noted history starting from the date of commissioning of the power plant. Then the study is extended to identify the possible improvements to increase the reliability of the power plant and calculate improved reliability figure with the above design proposals. Results of the study show that it is possible to improve the systems using simple and cost effective modifications at a reasonable cost, to increase the overall availability of the power plant in a measurable way.

It is proposed to replace the existing submerged raw water pumps by suitable mix flow vertical spindle pumps to eliminate frequent winding failure in sea water intake and pretreatment system to improve the system reliability.

There are two modifications proposed to improve the reliability of desalination plant which has the lowest availability figure in BOP section. First is to relocate the VSDs to a separate, air conditioned compartment in order to improve the operation to eliminate the failures of VSDs. Second modification is the introduction of river water from "Kala Oya" to mix with the sea water to bring the conductivity of inlet water to RO unit within design value range. However, a considerable time is needed to construct the pipe line to bring river water from the source nearly 48 km away from the power plant.

It is proposed to introduce a standby blower parallel with the existing one to degasifier tank with suitable logic modifications to act as a backup.

Also it is proposed to modify the piping layout from the chlorination plant to cooling water intake to meet the appropriate dosing speeds for both shock dosing at the pump bay and continuous dosing at the intake head. This modification can eliminate many issues caused by sea born organisms such as barnacles and herbs. It will also increase the life time of pipe lines, heat exchangers and auto clean filters and debris filters located before the condenser main cooling water line.

Also it is proposed to introduce a sand filter before the rectifier cooling water pump to eliminate the ingress of sand to the pump unit to reduce water leaks through mechanical seal damage.

Installation of additional storage tanks having a total capacity of 1,000m<sup>3</sup> to store H<sub>2</sub> for use in emergency situations when consecutive fillings of generator enclosures are needed, is recommended to eliminate unnecessary delays.

The summarized availability figures of each section before and after the proposed modifications are compared below:.

Table 9.1: Plant wise availability comparison in BOP section.

Plant	Availability	
	Existing	Expected
Chlorination Plant	0.783337	0.88721
Pretreatment Plant	0.875010	0.919544
Desalination Plant	0.208372	0.919506
Demineralization Plant	0.902214	0.919413
Hydrogen generation plant	0.96189	0.9804

Simple payback period also was calculated for each modification to prove the credibility of each proposal as follows:

Table 9.2: Simple payback period for each modification.

No.	Proposals	Total Cost(Rs)	Saving/year	Pay back period	Remak
1	Design new dosing pipe line arrangement	3.2 M	81M	0.5 Month	Feasible
2	Design suitable pre-filter for cooling booster pumps	0.05M	0.3 M	2 Month	Feasible
3	Replace existing raw water submersible pumps with vertical mixed flow pumps	9.1 M	1.1 M	8.3 year	Feasible
4	Dilute of RO feed water by using river water	528 M	79 M	6.6 year	Feasible
5	Change the VSD location from the sea water mist environment	2 M	6.7 M	3.5 Month	Feasible
6	Introducing IP 54 VSD	15 M	6.7 M	2.2 year	Feasible but No is more desirable
7	Design new standby blower fan for degasified system	0.3 M	0.12 M	2.6 Year	Feasible
8	Enhance hydrogen Storage capacity	2.8 M	230.2 M	5 Days	Feasible

### 9.2 Recommendations.

It is obvious that the reliability of BOP section of the Lakvijaya Power Plant can be improved by a considerable extent to increase the plant availability. Also it is recommended to make those modifications simultaneously to sub divisions to achieve total improvement for the division as per the table 8.2.

CEB as well as all consumers and citizens of Sri Lanka will reap the benefits as the Lakvijaya Power Plant is the cheapest thermal power provider among the CEB generation division.



**Reference list:**

- [01] *Technical document for Puttalam 1×300MW coal fired power plant project*, China National Machinery and Equipment Import and Export Corporation, 2006, pp. 3.
- [02] Ana Zuliastuti. (2013, January 06). Basic reliability bottom up models. Available: <http://www.slideshare.net/mitzy88/basic-reliability-models>.
- [03] *Enterprise Standard of Puttalam 300MW Coal Fired Power Plant, Maintenance Manual of Boiler Equipments*, China National Machinery & Equipment Import & Export Corporation, CHD Power Plant Operation Co., Ltd., 2008, pp.86-126.
- [04] *ACS 800 ABB drives Firm Ware and Maintenance Manual drives ,Low voltage drives motor cable selection for more efficient and reliable plant operation*. ABB, pp.46.
- [05] ElisabettaCarrea “Report of Electrochlorination,” Poyry Consulting and Engineering, Mumbai ,March 2012.
- [06] *Electro chlorination Plant Operation and Maintenance Manual*, Qingdao Sunrui Corrosion and Fouling Control Co.Ltd, PP 6.
- [07] *Annual Rate Book*, National Water Supply & Drainage board, Sri Lanka, 2012.
- [08] *Guidelines for the Selection of Required Size of Cable*, Kelani Cables PLC, Sri Lanka, 2012, pp. 46.
- [09] *MS series EBARA Pumps Selection Manual*, EPM Marketing Co.,Ltd. 2001, pp.07-10
- [10] *DOW FILMTECMembranes Maintenance Manual*, DOW Water & Process solution business, Noth America, 2004, pp. 1-2
- [11] LucyEmertonl, “IUCN Water, Nature & Economics Technical Paper No 1,” The world conservation union, Switzerland, 2005, pp. 27.
- [12] *Kalaoyariver basin water level log data measuring point at Eluwankulama station*,Hydrology division, Department of irrigation, Sri Lanka, 2010, pp. 06
- [13] *Steel water pipe A guide for design and installation*, American water works association (AWWA), 2000,pp. 16.
- [14] *Selecting centrifugal pumps*, KSB,Germany, 2004, pp.11.

[Appendix- A]

Fault Record for RO-1 Unit				
	Item	Time of start Failure (mm/dd/yyhh:mm)	Time of Restoration (mm/dd/yyhh:mm)	Period in hrs
1	Energy recovery Unit	12/21/11 6:50 PM	12/21/11 11:21 PM	4.52
2	Energy recovery Unit	2/9/12 2:40 PM	2/13/12 4:34 PM	97.90
3	Chemical feeding unit	2/10/12 9:12 AM	2/10/12 9:50 AM	0.63
4	Energy recovery Unit	1/16/12 10:09 AM	1/16/12 10:53 AM	0.73
5	HP pump VSD	12/2/11 2:00 PM	12/30/11 8:30 AM	666.50
6	Chemical feeding unit	12/20/11 2:02 PM	12/20/11 3:45 PM	1.72
7	RO membrane unit	12/8/11 9:00 PM	12/10/11 8:57 AM	35.95
8	RO membrane unit	12/4/11 10:10 AM	12/10/11 8:58 AM	142.80
9	RO membrane unit	12/1/11 10:13 AM	12/1/11 5:04 PM	6.85
10	RO membrane unit	11/30/11 3:25 PM	12/1/11 9:14 AM	17.82
11	RO membrane unit	11/29/11 4:40 PM	11/30/11 3:25 PM	22.75
12	RO feed water pump	11/19/11 4:02 PM	11/30/11 3:25 PM	263.38
13	Chemical feeding unit	11/3/11 11:20 AM	11/3/11 3:40 PM	4.33
14	HP pump VSD	11/2/11 3:11 AM	11/2/11 5:12 PM	14.02
15	HP pump VSD	10/27/11 2:05 PM	10/27/11 5:42 PM	3.62
16	RO feed water pump	11/19/11 3:40 PM	11/19/11 5:50 PM	2.10
17	Chemical feeding unit	11/12/11 3:27 PM	11/16/11 5:49 PM	98.37
18	Pre filter	10/4/11 2:36 PM	10/4/11 6:22 PM	3.77
19	Chemical feeding unit	10/2/11 2:23 PM	10/2/11 7:06 PM	4.72
20	HP pump VSD	10/1/11 3:22 PM	10/1/2011 17:20	1.97
21	RO membrane unit	9/20/11 11:35 AM	10/27/11 5:30 PM	893.92
22	Pre filter	9/13/11 6:18 PM	9/13/11 11:00 PM	4.70
23	Chemical feeding unit	9/13/11 2:45 PM	9/15/11 7:55 PM	53.17
24	Energy recovery Unit	6/30/12 10:10 AM	6/30/12 2:27 PM	4.28
25	HP pump VSD	12/7/11 10:10 AM	2/14/12 8:05 AM	1653.92
26	RO membrane unit	1/15/12 9:10 AM	2/29/12 1:42 PM	1084.53
27	RO membrane unit	2/28/12 2:47 PM	2/29/12 1:42 PM	22.92
28	Pre filter	2/3/12 3:15 PM	3/2/12 6:51 PM	675.60
29	Pre filter	3/6/12 5:59 PM	3/6/12 7:07 PM	1.13
30	Chemical feeding unit	3/12/12 7:38 PM	3/13/12 10:03 PM	26.42
31	Chemical feeding unit	3/15/12 10:40 AM	3/18/12 3:05 PM	76.42
32	Chemical feeding unit	3/29/12 2:31 PM	3/31/12 8:34 AM	42.05
33	Chemical feeding unit	3/29/12 9:29 AM	4/3/12 2:49 PM	125.33
34	HP pump VSD	4/6/12 10:42 AM	4/6/12 1:02 PM	2.33
35	Pre filter	4/18/12 10:20 AM	4/18/12 11:36 AM	1.27
36	RO membrane unit	4/9/12 10:32 AM	4/13/12 8:49 AM	94.28
37	HP pump VSD	4/9/12 9:08 AM	4/9/12 12:10 PM	3.03
38	HP pump VSD	4/30/12 4:17 PM	4/30/12 7:26 PM	3.15
39	RO membrane unit	5/17/12 8:52 AM	5/17/12 8:58 AM	0.10

Formatted: Left, None, Space Before: 0 pt, After: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together

40	HP pump VSD	5/5/12 12:00 AM	5/22/12 9:00 PM	429.00
41	RO membrane unit	5/23/12 12:20 PM	5/24/12 4:10 PM	27.83
42	RO membrane unit	6/7/12 8:53 AM	6/7/12 6:50 PM	9.95
43	Pre filter	6/18/12 3:25 PM	6/18/12 4:06 PM	0.68
44	Chemical feeding unit	6/19/12 10:08 AM	6/19/12 6:13 PM	8.08
45	RO feed water pump	6/23/12 9:57 AM	6/23/12 5:17 PM	7.33
46	HP pump VSD	6/25/12 3:00 PM	6/25/12 5:46 PM	2.77
Total Outage (h)				6,648.70



University of Moratuwa, Sri Lanka.  
 Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

[Appendix- B]

<b>Fault Record for RO-2 Unit</b>				
	Item	<u>Time of start of Failure</u> (mm/dd/yyhh:mm)	<u>Time of Restoration</u> (mm/dd/yyhh:mm)	Period in hrs
1	HP pump VSD	7/12/11 10:10 AM	2/14/12 8:05 AM	5205.92
2	HP pump VSD	8/29/11 5:22 PM	8/30/11 3:00 PM	21.63
3	HP pump VSD	8/30/11 4:00 PM	9/2/11 8:46 AM	64.77
4	Pre filter	9/13/11 2:45 PM	9/13/11 11:00 PM	8.25
5	RO membrane unit	11/29/11 4:40 PM	11/30/11 3:25 PM	22.75
6	RO membrane unit	11/30/11 3:25 PM	12/1/11 9:14 AM	17.82
7	RO membrane unit	12/1/11 10:13 AM	12/1/11 5:04 PM	6.85
8	RO membrane unit	12/4/11 10:10 AM	2/10/11 8:58 AM	142.80
9	Energy recovery Unit	12/10/11 9:58 AM	12/10/11 5:26 PM	7.47
10	HP pump VSD	12/11/11 4:00 PM	12/10/11 3:40 PM	1.90
11	Chemical feeding unit	12/20/11 2:32 PM	12/20/11 3:45 PM	1.22
12	RO membrane unit	12/25/11 10:38 AM	12/26/11 3:34 PM	28.93
13	Pre filter	1/3/12 5:52 PM	1/3/12 9:13 PM	3.35
14	Pre filter	2/2/12 1:49 PM	2/2/12 5:50 PM	4.02
15	Pre filter	2/3/12 3:15 PM	2/3/12 6:51 PM	3.60
16	RO feed water pump	2/8/12 8:40 AM	2/8/12 2:25 PM	5.75
17	Energy recovery Unit	2/9/12 1:40 PM	2/9/12 4:02 PM	2.37
18	Pre filter	2/19/12 5:30 PM	2/19/2012 21:15	3.75
19	Chemical feeding unit	3/3/12 9:22 AM	3/3/12 5:45 PM	8.38
20	Pre filter	3/5/12 3:30 PM	3/5/12 5:45 PM	2.25
21	Energy recovery Unit	3/12/12 4:27 PM	3/12/12 7:33 PM	3.10

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together, Tab stops: Not at 1.18" + 1.58" + 6.1"

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together, Tab stops: Not at 1.18" + 1.58" + 6.1"

University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
www.lib.mrac.lk

22	HP pump VSD	4/19/12 3:07 PM	6/8/12 8:21 PM	1205.23
23	RO feed water pump	4/23/12 9:19 AM	4/23/12 10:48 AM	1.48
24	RO feed water pump	4/23/12 12:20 PM	4/24/12 5:09 PM	28.82
25	RO membrane unit	5/20/12 1:39 PM	5/20/12 3:12 PM	1.55
26	HP pump VSD	5/27/12 3:55 PM	8/27/12 7:16 PM	2211.35
27	RO membrane unit	5/28/12 12:00 AM	5/29/12 11:33 AM	35.55
28	RO membrane unit	5/28/12 2:47 PM	5/28/12 4:09 PM	1.37
29	RO membrane unit	6/1/12 9:35 AM	6/1/12 10:37 AM	1.03
30	RO membrane unit	6/9/12 12:02 AM	6/9/12 1:10 AM	1.13
31	RO membrane unit	6/21/12 7:15 AM	6/29/12 9:30 PM	206.25
32	Energy recovery Unit	7/7/12 10:02 AM	7/9/12 11:43 AM	49.68
33	Energy recovery Unit	7/12/12 2:45 PM	7/13/12 3:54 PM	25.15
Total Outage (h)				9.3547



University of Moratuwa, Sri Lanka.  
 Electronic Theses & Dissertations  
[www.lib.mrt.ac.lk](http://www.lib.mrt.ac.lk)

[Appendix - C]

Fault Record for RO-3 Unit				
	Item	Time of start Time of Failure (mm/dd/yyhh:mm)	Time of Restoration (mm/dd/yyhh:mm)	Period(hrs)
1	RO membrane unit	2/10/12 9:12 AM	2/10/12 1:15 PM	4.05
2	Pre filter	2/3/12 1:44 PM	2/3/12 3:21 PM	1.62
3	HP pump VSD	12/29/11 2:00 PM	12/30/11 8:30 AM	18.50
4	HP pump VSD	12/20/11 2:32 PM	12/30/11 12:00 AM	225.47
5	Chemical feeding unit	12/20/11 2:32 PM	12/20/11 3:45 PM	1.22
6	RO membrane unit	12/20/11 9:10 AM	12/28/11 1:54 PM	196.73
7	RO membrane unit	12/4/11 10:10 AM	12/10/11 8:58 AM	142.80
8	RO membrane unit	12/4/11 10:10 AM	12/10/11 8:58 AM	142.80
9	RO membrane unit	12/1/11 10:13 AM	12/1/11 5:04 PM	6.85
10	RO membrane unit	11/30/11 3:25 PM	12/1/11 9:14 AM	17.82
11	Chemical feeding unit	11/3/11 11:20 AM	11/3/11 3:25 PM	4.08
12	Energy recovery Unit	10/27/11 2:05 PM	10/27/11 3:42 PM	1.62
13	Pre filter	10/4/11 2:36 PM	10/4/11 6:22 PM	3.77
14	RO membrane unit	10/2/11 2:23 PM	10/2/11 7:05 PM	4.70
15	RO membrane unit	10/2/11 2:04 PM	10/2/11 7:05 PM	5.02
16	RO membrane unit	9/20/11 4:35 AM	10/27/11 5:30 PM	893.92
17	Energy recovery Unit	9/2/11 5:59 PM	9/3/11 2:40 PM	20.68
18	HP pump VSD	9/5/11 10:20 AM	9/6/11 1:45 PM	27.42
19	Chemical feeding unit	6/14/12 2:30 PM	6/14/2012 14:50	0.33
20	Pre filter	6/12/12 1:48 PM	6/12/12 3:16 PM	1.47
21	RO membrane unit	1/15/12 9:10 AM	2/29/12 1:42 PM	1084.53
22	RO membrane unit	2/28/12 2:47 PM	2/29/12 1:42 PM	22.92
23	Pre filter	2/3/12 3:15 PM	3/2/12 6:51 PM	675.60
24	Pre filter	3/6/12 5:59 PM	3/6/12 7:07 PM	1.13
25	RO membrane unit	3/1/12 3:07 PM	3/6/12 11:16 AM	116.15
26	Chemical feeding unit	3/12/12 9:48 AM	3/12/12 3:45 PM	5.95
27	HP pump VSD	2/13/12 4:58 AM	3/27/12 6:50 PM	1045.87
28	HP pump VSD	2/13/12 5:02 PM	3/27/12 6:28 PM	1033.43
29	Pre filter	4/7/12 4:10 PM	4/7/12 4:55 PM	0.75
30	HP pump VSD	4/12/12 8:49 AM	4/13/12 5:50 PM	33.02
31	RO membrane unit	5/10/12 4:48 PM	5/25/12 1:26 PM	356.63
32	RO membrane unit	6/3/12 12:00 AM	7/12/12 12:00 PM	948.00
Total Outage (h)				7,044.83

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together

University of Moratuwa, Sri Lanka.  
Electronic Theses & Dissertations  
www.lib.mru.ac.lk

[Appendix – D]

Fault record for UF filter 01				
	Item	<u>Time of start</u> <u>of Failure</u> <small>(mm/dd/yyhh:mm)</small>	<u>Time of</u> <u>Restoration</u> <small>(mm/dd/yyhh:mm)</small>	Period in hrs
1	UF Filter vacuum pump#1	3/10/11 10:14 AM	3/26/11 5:40 PM	391.43
2	UF auto cleaning filter #1	11/10/11 10:00 PM	12/1/11 8:57 AM	490.95
3	UF Chemical dosing pump	12/20/11 2:02 PM	12/20/11 3:45 PM	1.72
4	UF auto cleaning filter #1	12/28/11 6:50 PM	12/29/11 11:21 PM	28.52
5	UF Filter vacuum pump#1	2/9/12 2:40 PM	2/13/12 4:34 PM	97.90
6	UF Feed water pump#1	2/10/12 9:12 AM	2/10/12 9:50 AM	0.63
7	UF Chemical dosing pump	3/8/12 12:00 AM	6/8/12 5:00 PM	2,225.00
Total outage(h)				3,236.15

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together

Fault record for UF filter 02				
	Item	<u>Time of start</u> <u>of Failure</u> <small>(mm/dd/yyhh:mm)</small>	<u>Time of</u> <u>Restoration</u> <small>(mm/dd/yyhh:mm)</small>	Period in hrs
1	UF auto cleaning filter #2	9/13/11 10:45 AM	1/6/12 8:05 AM	2757.83
2	UF Filter vacuum pump#2	2/8/12 8:40 AM	2/8/12 2:25 PM	5.75
3	UF Feed water pump#1	2/10/12 1:50 PM	2/11/12 4:02 PM	26.20
4	UF Chemical dosing pump	6/19/12 3:31 PM	6/19/12 4:22 PM	0.85
5	UF Feed water pump#1	8/21/12 8:15 AM	9/29/12 10:30 PM	950.25
Total outage (h)				3,740.38

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together

Fault record for UF filter 3				
	Item	<u>Time of start</u> <u>of Failure</u> <small>(mm/dd/yyhh:mm)</small>	<u>Time of</u> <u>Restoration</u> <small>(mm/dd/yyhh:mm)</small>	Period in hrs
1	UF auto cleaning filter #3	1/10/11 9:46 AM	2/10/11 2:49 PM	749.05
2	UF Chemical dosing pump	5/10/11 10:12 AM	6/10/11 11:15 PM	757.05
3	UF Filter vacuum pump#3	7/20/11 10:14 AM	7/26/11 5:40 PM	151.43
4	UF auto cleaning filter #3	1/4/12 1:14 PM	1/9/12 7:05 PM	125.85
5	UF Filter vacuum pump#3	3/8/12 12:00 AM	5/8/12 5:00 PM	1481.00
Total outage (h)				3,264.38

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together

Formatted: Left, None, Space Before: 0 pt, Line spacing: single, Don't keep with next, Don't keep lines together