

REFERENCES

- [1] Luis G.W. da Silva, Rodrigo A.F. Pereira, Jose R.S. Mantovani, “Allocation of protective devices in distribution circuits using nonlinear programming models and genetic algorithms”, Sao Paulo State University, August 2003
- [2] Luis G.W. da Silva, Rodrigo A.F. Pereira, Juan R. Abbad, Jose R.S. Mantovani, “Optimized placement of control and protective devices in electric distribution systems through reactive tabu search algorithm”, Sao Paulo State University, April 2007
- [3] M.R. Haghifam, H. Falaghi, M. Ramezani, M. Parsa, G. Shahryari, “Enhancement in Distribution Systems using Optimal Allocation of Switching Devices”, Tarbiat Modarres University, Iran, May 2003
- [4] P. Jintagasonwit, P. Jintakosonwit, N. Wattanapongsakorn, “Optimal Feeder Switches and Pole Mounted RTUs Relocation on Electrical Distribution System considering Load Profile”, KMUTT, Thailand, June 2005
- [5] Prof. H.Y.R. Perera, S.P. Thushara, “Distribution Reliability Improvement through Optimal Location of Load Break Switches in 33 kV Network”, University of Moratuwa, Sri Lanka, April 2012
- [6] P. Raesaar, E. Tiigimagi, J. Valtin, “Assessment of electricity supply interruption costs under restricted time and information resources”, Tallinn University of Technology, Estonia, May 2006
- [7] Wenyuan Li, “Expected Energy Not Served (EENS) Study for Vancouver Island Transmission Reinforcement Project” British Columbia Transmission Corporation, January 2006
- [8] Nexant SARI/Energy, “Economic Impact of Poor Power Quality on industry: Review of Studies, Sri Lanka”, Nexant SARI/Energy, November 2003
- [9] Ceylon Electricity Board, “Price List of Materials-2011”, Ceylon Electricity Board, 2015
- [10] “Summary of 33 kV Line Tripping” from System Control Branch, CEB.
- [11] Chao Shun Chen, Chai Hung Lin, Hui Jen Chuang and Chai Wen Hung, “Optimal Placement of Line Switches for distribution Automatic System using immune algorithm”, IEEE Transactions on Power Systems, Vol.21, August 2008
- [12] Taigo Alencar, Anselmo Rodrigues and Maria da Guia da Silva, “Switches allocation in distribution network using particle swarm optimization based on fuzzy expert systems”, 17th Power System Computation Conference, Sweden, August 2011



Annexure 1 - Auto Recloser Location - Region 4

GSS	Feeder No	Distance to AR (km)	AR Location	Auto Recloser Name	Distance to AR from the previous AR(km)	AR location	Auto Recloser Name	
Ambalangoda	Feeder 1	15.132	Thanabaddegama Tapping	Thanabaddegama	15.868	Ketandola	Ketandola	
	Feeder 2	28.228	Thalgaswala Gantry	Udugama	9.017	Udugama Bar Junction	Bar Junction AR	
				Thalgaswala				
	Feeder 3	9.903	Nindana Gantry	Kurundugaha				
				Karandeniya AR				
	Feeder 4	5.184	Magala Gantry	Gonapinuwala AR				
Meetiyagoda AR								
Feeder 6	9.36	Uragasmanhadiya	Uragasmanhandiya				Induruwa side Balapitiya side	
Galle	Feeder 1	13.106	Indigasketiya Pump House	Hegoda				
				Divithura				
	Feeder 2	12.398	Citrus	Citrus	5.396	Mabotuwana	Mabotuwana Tapping	
	Feeder 3	10.214	Waulugala	Agaliya Pump House				
	Feeder 4	14.986	Mawella Gantry	Waulugala				
				Mawella				
	Feeder 5	18.18	Gonapinuwala Gantry	PSS side	1.089	Gonapinuwala PSS	Nalagasdeniya side Pinkanda side	
				Baddegama side				
Feeder 6	12.751	Udumullagoda	Udumullagoda					
			Wanduramba					
Feeder 7	19.183	Baddegma Gantry	Elpitiya					
			Goonapinuwala					
		6.22	Thotagoda	Thotagoda AR				
Matara	Feeder 2	9.065	Thlijjawila Gantry	Semidale side	12.372	Hikgodra	Hikgodra AR	
				12.694	Semidale Gantry	Imaduwa side		
	Feeder 3	17.535	Pitadeniya Gantry	Rathmale Side				
				Dandeniya Side				
				Matara Side	10.038	Gandara	Gandara	
	Feeder 6	10.296	Udukawa Gantry	Tangalle Side				
				Thelijjawila side				
Feeder 7	14.597	Kamburupitiya Gantry	Load star factory					
			Galbokka side	7.64	Galbokka PSS	Ahangama Side 11 kV Matara Side 11 kV		

	Feeder 8	7.221	Meddawatta PSS	11 kV side			
		7.96	Devinuwara PSS	11 kV side			
		3.945	Weherahena	Weherahena			
Beliatta	Feeder 4	15.417	Tangalle Gantry	Beliatta Side			
				Wadigala Side			
				Dickwella Side			
				Tangalle Town Side			
	Feeder 6	16.472	Tumbe	Tumbe			
Deniyaya	Gen Feeder 1	16.526	Morawaka Gantry	Waralla side			
	Feeder 1	8.999	Alakoladeniya	Alakoladeniya AR	5.291	Katuwana	Katuwana AR
	Feeder 2	2.864	Beralapanthara	Beralapanathara AR			
		14.433	Pasgoda	Pasgoda AR			
Feeder 3	2.445	Deniyaya Gantry	Pallegama side				
Hambantota	Feeder 3	29.453	22nd Junction	22nd Junction AR			
		39.334	Saman Rice Mill	Saman Rice Mill AR			
	Feeder 5	22.044	Open Prison	Open Prison AR			
		28.665	Kasingama	Kasingama AR			
	Feeder 6	49.676	Kataragama	Kataragama Bus Stand AR			
		10.299	Harbour PSS	Harbour side			
		16.835	Bolana	Bolana Water Board AR			
Embilipitiya	Feeder 6	27.831	Nonagama Gantry	Lunama side			
Ratmalana	Feeder 3	2.193	Thelawala PSS	Transformer Feeder			
	Feeder 9	2.978	Angulana PSS	Transformer - 3 LECO Feeder			
Panadura	Feeder 4	16.475	Uggalboda Gantry	Uggalboda			
	Feeder 5	4.941	Kahatawela Gantry	Deniya			
		9.612	Kahathuduwa Gantry	Piliyandala - Kahatuduwa			
Matugama	Feeder 2	20.763	Lathpandura	Lathpandura			
		29.108	Athweltota	Kalawana			
	Feeder 3	14.441	Kithulgoda Gantry	Athwelthota			
				Pelawatta			
				Kallumale			
	Feeder 5	35.251	Miriswatta	Sirikandura			
	Feeder 7	13.815	Fullerton Gantry	Elpitiya			
				Payagala			
Feeder 8	3.017	Malaboda	Naththupana				
			Gamegoda				
			Malaboda				

Annexure 2.1 - Customer Interruption Duration for Ambalangoda Feeder 3

sin no	Interrupted Hours												Consumers
	Feb-13	Jan-13	Dec-12	Nov-12	Oct-12	Sep-12	Aug-12	Jul-12	Jun-12	May-12	Apr-12	Mar-12	
AG 95	0.45	0.63	0.23	0.35	0.56	0.006	0.04	0.89	0.24	0.02	0.98	0.005	1
AG 90	2.7911	2107.9968	48.112	13.392	416.2928	88.66	18.3768	1045.122	1.2597	17.9826	8383.926	4.27	247
AG 100	2.5086	1886.1024	42.486	1.095	365.9348	19.8338	25.4664	10395.63	136.869	161.1206	10316.833	0.021	222
AG 105	2.4521	1367.9897	68.6664	359.8776	3261.1032	628.1496	0.6264	3140.77	16.2945	160.3677	8719.7438	10.7532	217
AG 130	163.3025	11467.654	1815.044	118.7315	2311.0935	3310.8966	4973.6007	790.9239	3728.0634	21409.531	20719.13	6818.6628	415
AG 120	159.0957	37.1907	94.9311	67.3767	2158.0164	1967.6787	3075.2784	1651.305	3312.938	6251.5724	18411.997	6020.596	387
AG 110	507.6492	3.1176	146.4406	0.2165	37.7576	2248.2226	4023.648	1700.511	1.5516	3649.539	23661.008	50.138	433
AG 140	1823.7344	2849.8764	24.708	745.764	8311.2746	1901.3738	10314.744	4610.104	16970.757	5559.723	2.006	4.352	349
AG 146	1055.5712	12.4419	1940.5545	33.165	0.7437	1042.9086	5876.1118	1206.493	2.6136	46.5696	441.3391	3.0618	202
AG 145	930.1568	0.8366	11.7882	2612.6616	1024.4229	459.4566	5214.352	2345.024	71.7325	2707.915	417.8125	158.0182	178
AG 160	3467.6628	11639.606	613.1032	98063.711	6672.7465	19841.176	3689.5628	15203.31	6871.856	25127.585	7019.2743	71.9758	636
AS 315	2.6703	596.2122	17.121	7.3401	84.2112	1958.1952	250.063	15.3416	30.5308	3399.0534	79.9084	2.6625	129
AS 313	1.3936	480.6672	251.3368	5.9176	68.4216	849.7528	604.4143	42.5081	24.7612	2346.8859	64.1784	73.9724	104
AS 310	4.8776	1668.4698	647.316	20.4271	417.1545	8622.0498	2089.0436	323.4063	2510.4052	20775.021	4264.402	297.891	364
AS 305	59.8584	929.334	24.2452	75.309	1719.1005	2309.697	1205.3145	0	1116.5476	15415.473	81.446	161.568	196
AS 302	55.5828	1540.0112	693.056	70.2884	1127.5446	931.4578	922.9948	97.7886	41.496	2810.1346	28.9744	152.3115	182
AS 320	97.0884	1673.3794	13.392	46.476	2207.3115	2551.7002	1102.3454	1165.853	199.4418	0	1094.695	2747.5025	362
AS 300	284.2386	2366.7786	39.3175	183.445	2711.7066	7956.0492	17.2857	2439.723	3458.0777	23.0256	4063.7584	5054.511	479
AS 290	1527.96	3380.032	571.7118	1053.8528	663.956	8417.4965	6352.3044	1745.212	4346.6844	949.7954	1012.6248	14316.624	642
AS 275	1.05	0.54	0.3	0.55	0.32	0.76	0.23	0.88	0.54	0.33	0.43	0.98	1
AS 001	4.5087	1741.635	482.774	19.9796	1962.339	39.601	65.142	0	163.3325	5035.4995	294.1176	369.759	399
AS 276	0.23	0.88	0.54	0.33	0.43	0.98	1.05	0.54	0.3	0.55	0.32	0.76	1
AS 280	0.55	0.34	0.24	0.32	0.67	0.56	0.76	0.45	0.88	0.66	0.32	0.67	1
AS 220	0.76	0.45	0.88	0.66	0.32	0.67	0.55	0.34	0.24	0.32	0.67	0.56	1
AS 240	0.23	0.35	0.56	0.006	0.04	0.89	0.24	0.02	0.98	0.005	0	0	1
AS 210	1535	4191.4199	12659.427	19.479	2415.3976	1622.0703	2421.5464	2233.6	5912.3961	6251	8837.344	2693.15	913
AS 230	16981.776	13515.115	10811.5	90.7649	6055.661	958.2135	2386.848	2849.98	20046.831	548.5053	3736.9524	1437.0741	720
AS 200	619.6905	72.039	72.216	641.8527	2035.3743	4170.584	4844.3676	17085.59	15137.034	242.382	104.404	7976.423	891
AS 190	3789.4932	31981.32	12682.025	2354.2365	3976.236	86.9056	106.428	2890.388	8989.0642	905.5215	21929.393	512.4504	603
AS 193	50.2752	426.4176	169.6592	23.7402	40.164	0.8808	0.905	19.696	5.2832	4.6437	113.6238	1.8172	8
AS 194	12391.315	2562.8792	43.1376	71.1776	2202.6786	2.162	963.8413	5243.012	1259.0886	6643.329	6381.6216	6780.1575	477
AS 198	8291.2752	24751.091	33.7513	4536.6744	381.75	89.64	4046.864	6343.195	8368.1648	1161.2205	3732.624	591.744	507
AS 180	3782.1042	1209.604	9617.08	849.026	2828.3514	92.6936	2.9011	2740.392	125.0762	12363.222	2298.5837	191.7426	441
AS 170	5711.9453	3292.989	14.8035	3796.4589	3714.3301	320.0733	278.7218	17563.41	11974.651	30909.097	15434.689	523.5267	703
AS 250	128.8185	3686.4423	6149.4378	9.9187	752.4154	2341.482	13826.772	897.605	3360.71	669.2004	4849.922	817.2495	785
AS 260	1054.1844	2845.9125	51.5533	111.384	661.2522	2588.8032	73.0235	4341.721	3122.1531	622.1068	668.414	976.374	618
AS 265	3444.5162	0	57.8144	25.515	1058.3992	921.5448	99.8568	1817.733	13683.478	1150.4289	2341.78	264.8701	409
AS 270	530.5125	21.484	558.8984	44.2656	4691.3706	432.224	8955.5466	93.577	5703.7508	22.5492	3175.5213	487.6828	525

Annexure 2.2 - Customer Interruption Duration for Galle Feeder 8

Sin No	Interrupted hours												Customers
	Feb-13	Jan-13	Dec-12	Nov-12	Oct-12	Sep-12	Aug-12	Jul-12	Jun-12	May-12	Apr-12	Mar-12	
GB 300	8.1396	1834.5312	68.8296	39.6372	3521.9988	1622.8226	6070.7226	1240.713	645.4311	1730.76	0	347.9588	204
GB 310	885.1492	9061.2907	1541.4956	1182.5137	28577.697	27054.086	34524.858	3289.514	1176.1463	883.2447	4454.0495	2946.7255	527
GB 320	163.4584	1977.9032	66.552	3143.7457	29648.164	9042.8484	131943.2	1040.023	3817.8222	10620.511	115.2542	4243.1788	707
GB 321	10.1992	418.6626	447.866	1323.12	854.9471	8.5407	4607.0884	1669.023	902.7845	1163.9088	142.4686	909.2526	152
GB 330	5.3176	1.4996	2.1712	102.8537	972.7643	300.5571	4449.6973	35.1256	128.9426	359.7522	4.0043	148.3178	23
GB 410	0.09	0.24	0.02	0.98	0.005	0.45	0.63	0.23	0.35	0.56	0.006	0.04	1
GB 420	0.09	0.24	0.02	0.98	0.005	0.45	0.63	0.23	0.35	0.56	0.006	0.04	1
GB 421	0.09	0.24	0.02	0.98	0.005	0.45	0.63	0.23	0.35	0.56	0.006	0.04	1
GB 490	72.4878	4287.892	466.9888	396.7722	11475.596	36.972	3861.0945	2989.722	980.0192	726.1903	1836.7776	169.25	523
GB 530	5.2269	191.9936	116.194	32.006	1249.9584	1023.2576	5234.9056	571.5968	82.0736	691.4944	1.3716	223.6878	131
GB 600	3.2123	573.3426	10133.783	1586.2528	3432.88	150.228	10759.251	2001.306	1018.033	2341.344	72.4073	142.6403	353
GB 620	9.1707	1129.128	214.061	307.0629	1310.5845	87.604	5769.0648	16.023	221.8586	1092.4272	583.407	368.244	231
GB 630	32.5875	46.275	18.988	1382.3788	6303.8074	101.184	18514.636	2183.21	4477.6569	6904.5225	2714.6875	2241.246	375
GB 680	18.9126	1965.4045	3.0845	0	1345.9716	0	2.4505	72.9072	905.9184	920.9664	409.5706	10.4796	158
GB 730	0.8463	369.5355	2612.3916	410.0824	887.4775	298.4436	129.843	6.615	0	16.3891	14.841	37.647	93
GB 740	165.4448	13051.447	482.5126	20155.879	53675.238	168.9778	63069.699	10009.88	11165.188	21632.391	37429.633	12438.494	848
GB 760	0	433.008	1.8335	229.8624	1054.4346	1513.521	2597.5782	75.6512	364.1372	1064.2176	0	300.15	194
GB 770	0.09	0.24	0.02	0.98	0.005	0.45	0.63	0.23	0.35	0.56	0.006	0.04	1
GB 870	0.09	0.24	0.02	0.98	0.005	0.45	0.63	0.23	0.35	0.56	0.006	0.04	1
GB 920	1.8333	0	0	0	0	0	0	0	0	0	0	0	1
GB 921	229.1172	2376.4212	171.7524	52.8683	2613.4964	49.3498	2627.7924	0	57.517	48.816	696.87	554.6688	228
GG 375	26162.928	1066.0632	32.538	107.0871	5376.6464	217.854	2618.5592	2000.597	6788.068	4623.9952	277.02	67.124	495
GG 380	102.924	7720.488	22.9608	1574.4456	1358.6065	28.3585	54825	128.6345	139.3568	405.7012	739.3924	1564.56	216
GG 382	0.89	0.24	0.02	0.98	0.005	0.45	0.63	0.23	0.35	0.56	0.006	0.04	1
GG 385	1.6936	7472.6304	69.5836	38.3104	5885.7564	108.5072	45.7452	866.9376	1495.584	175.1464	89.886	43.7644	292
GG 395	0.029	127.956	1.1915	0.5248	80.6268	1.4864	0.6288	12.0408	20.772	2.4496	0.633	0.1541	5
GG 450	0.9978	1.0833	0.3972	0.53	1	0.48	0.1635	0	0	0.24	0.503	0.3036	50
GG 540	136.3946	132.1848	46.0192	178.3742	15449.226	18782.398	5587.9461	980.7864	216.504	181.116	36.4046	422.964	398
GG 545	28539.898	20.9223	4.536	4192.5762	9454.0281	648.6285	3.663	167.962	102.7026	378.045	4925.0672	20.0838	568
GG 550	519.0915	26.7652	12.5628	91.465	4444.006	164.7232	7491.768	9808.681	1498.599	1537.5365	740.304	175.3856	555
GG 560	1062.657	18395.002	197.372	158.5056	68797.155	389.2166	43189.132	604.1964	3817.8675	2985.9821	556.92	955.259	1065
GG 570	214.578	609.855	85.0272	3269.6745	13622.902	9791.4201	29659.96	772.3795	2824.372	43650.228	5237.2584	4319.84	546
GG 580	0.09	0.24	0.02	0.98	0.005	0.45	0.63	0.23	0.35	0.56	0.006	0.04	1
GG 590	0.52	0.11	2.11	0.45	2.9	0.88	0.86	0	0	0.25	0.52	0.32	53

Annexure 2.2 - Customer Interruption Duration for Matara Feeder 7

Sin No.		Interrupted Hours											Customers	
		Mar-12	Apr-12	May-12	Jun-12	Jul-12	Aug-12	Sep-12	Oct-12	Nov-12	Dec-12	Jan-13		Feb-13
K	435	2,198.93	2,508.80	0.00	63.75	1,211.25	187.50	420.00	1,864.50	131.83	0.00	0.00	245.92	227
K	440	2,346.18	2,676.80	0.00	68.00	1,292.00	200.00	448.00	1,980.00	140.00	0.00	0.00	260.00	240
K	430	2,365.82	2,755.20	0.00	69.98	1,329.68	205.83	461.07	2,037.75	144.67	0.00	0.00	269.75	249
K	432	29.45	33.60	0.00	0.85	16.15	2.50	5.60	24.75	1.75	0.00	0.00	3.25	3
K	010	251.10	2,444.70	0.00	80.47	534.87	0.00	532.00	0.00	166.25	0.00	0.00	0.00	287
K	020	704.70	6,820.80	0.00	223.27	1,484.07	0.00	1,467.20	0.00	460.83	0.00	0.00	0.00	797
K	025	310.50	3,001.50	0.00	98.03	651.63	0.00	645.87	0.00	204.17	0.00	0.00	0.00	356
K	050	8,633.50	4,089.00	0.00	134.02	890.82	0.00	2,967.07	318.00	279.42	400.00	0.00	0.00	481
K	030	325.80	3,175.50	0.00	104.55	694.95	0.00	688.80	0.00	217.00	558.00	0.00	0.00	376
K	035	220.50	2,148.90	0.00	70.27	467.07	0.00	462.93	0.00	1,645.83	375.00	0.00	0.00	252
K	045	209.70	2,035.80	0.00	66.30	440.70	0.00	440.53	0.00	137.67	354.00	0.00	0.00	237
K	040	106.20	1,035.30	0.00	34.00	226.00	0.00	225.87	0.00	70.58	181.50	0.00	0.00	121
K	060	404.10	3,958.50	0.00	129.20	858.80	0.00	856.80	0.00	267.75	688.50	0.00	0.00	460
K	055	286.20	2,766.60	0.00	90.67	602.67	0.00	604.80	0.00	189.58	487.50	0.00	0.00	325
K	090	448.20	4,402.20	0.00	144.22	960.50	0.00	953.87	0.00	298.67	768.00	0.00	0.00	516
K	100	0.90	8.70	0.00	0.28	1.88	0.00	1.87	0.00	0.58	1.50	0.00	0.00	1
K	070	288.00	5,012.47	0.00	92.65	617.73	0.00	617.87	0.00	194.83	501.00	723.67	3,649.90	339
K	065	302.40	5,592.40	0.00	96.90	644.10	0.00	640.27	0.00	201.25	517.50	747.50	3,725.27	346
K	075	215.10	3,919.60	0.00	67.72	450.12	0.00	446.13	0.00	139.42	358.50	517.83	2,573.23	239
K	080	285.30	5,012.47	0.00	91.80	610.20	0.00	604.80	0.00	191.92	492.00	715.00	3,553.00	330
K	085	331.20	5,790.80	0.00	106.82	710.02	0.00	709.33	0.00	224.00	574.50	838.50	4,166.70	387
K	105	45.00	435.00	0.00	14.17	0.00	0.00	93.33	0.00	29.17	75.00	0.00	0.00	50
K	107	106.20	1,035.30	0.00	34.00	226.00	0.00	225.87	0.00	70.58	181.50	0.00	0.00	122
K	410	184.25	1,444.20	0.00	47.03	428.83	235.17	309.87	0.00	96.83	0.00	0.00	1,853.67	166
K	420	365.15	2,862.30	0.00	94.07	857.67	470.33	619.73	0.00	193.67	0.00	0.00	3,729.67	334
K	415	300.38	2,340.30	0.00	77.92	710.42	391.00	515.20	0.00	161.00	0.00	0.00	3,093.17	277
T	345	587.37	4,584.90	0.00	150.73	1,374.33	755.08	998.67	0.00	316.17	0.00	0.00	6,063.50	543
T	344	450.02	3,593.10	0.00	118.72	789.12	0.00	785.87	0.00	246.75	0.00	0.00	0.00	425
K	385	15.63	121.80	0.00	3.97	26.37	0.00	26.13	0.00	8.17	0.00	0.00	0.00	14
K	380	419.87	3,288.60	0.00	108.80	723.20	0.00	724.27	0.00	228.08	0.00	0.00	0.00	391
K	375	304.85	5,073.75	0.00	78.77	525.45	0.00	520.80	0.00	162.75	0.00	0.00	0.00	280
K	373	1,280.53	3,986.63	318.25	418.75	428.80	0.00	377.07	0.00	118.42	0.00	0.00	1,098.67	206
K	370	3.35	18.45	0.00	0.28	1.88	0.00	1.87	0.00	2.33	0.00	0.00	0.00	4
K	367	429.92	7,915.05	0.00	122.12	811.72	0.00	808.27	0.00	254.33	0.00	0.00	0.00	438
K	365	185.37	3,062.70	0.00	46.75	312.63	0.00	309.87	0.00	96.83	0.00	0.00	0.00	166
K	360	441.08	6,549.75	0.00	101.15	674.23	0.00	668.27	0.00	211.17	0.00	0.00	0.00	363
K	340	374.08	2,923.20	0.00	1,019.63	2,501.20	0.00	625.33	0.00	196.00	0.00	0.00	0.00	338
K	353	270.23	2,114.10	0.00	922.83	2,976.75	0.00	459.20	0.00	492.00	0.00	576.33	329.33	247
K	350	398.65	3,219.00	0.00	1,408.73	4,544.10	0.00	700.00	0.00	760.00	0.00	886.67	508.00	381
K	355	232.27	1,835.70	0.00	802.30	2,587.95	0.00	399.47	0.00	428.00	0.00	501.67	288.00	216
K	345	341.70	2,670.90	0.00	1,163.90	3,766.50	0.00	576.80	0.00	620.00	0.00	730.33	418.67	314
K	337	32.38	252.30	0.00	87.48	214.60	0.00	54.13	0.00	16.92	0.00	0.00	0.00	29
K	335	1.12	8.70	0.00	3.02	7.40	0.00	1.87	0.00	0.58	0.00	0.00	0.00	1
K	330	1.12	8.70	0.23	0.28	1.88	0.00	1.87	0.00	0.58	0.00	0.00	0.00	1
K	320	618.63	4,828.50	129.97	158.38	1,052.78	0.00	1,047.20	0.00	330.75	0.00	0.00	0.00	573
K	310	158.57	1,270.20	34.30	42.22	282.50	0.00	278.13	0.00	87.50	0.00	0.00	0.00	153
K	315	254.60	2,001.00	53.90	66.02	438.82	0.00	436.80	175.50	137.08	0.00	0.00	0.00	235
K	295	1,319.27	3,254.80	640.67	88.40	589.48	0.00	589.87	0.00	184.33	0.00	0.00	0.00	320
K	300	341.70	2,697.00	72.33	88.12	585.72	0.00	580.53	0.00	182.00	0.00	0.00	0.00	313
K	290	282.52	2,201.10	59.27	71.97	478.37	0.00	476.00	0.00	149.33	0.00	0.00	0.00	257
B	600	437.40	4,236.90	488.00	787.32	919.07	0.00	912.80	0.00	286.42	0.00	0.00	0.00	492
B	610	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0
B	620	364.50	3,532.20	407.00	659.60	770.28	0.00	769.07	0.00	241.50	0.00	0.00	0.00	416
B	630	383.40	3,732.30	431.00	700.02	817.37	0.00	812.00	0.00	253.75	0.00	0.00	0.00	441
B	640	367.20	3,567.00	411.00	666.07	775.93	0.00	772.80	0.00	242.67	0.00	0.00	0.00	419
B	650	0.00	0.00	0.00	1.62	1.88	0.00	1.87	0.00	0.58	0.00	0.00	0.00	1

B	660	492.30	4,776.30	550.00	892.40	1,041.48	0.00	1,032.27	0.00	324.33	0.00	0.00	0.00	561
B	655	198.00	1,931.40	223.00	360.52	421.87	0.00	423.73	0.00	133.58	0.00	0.00	0.00	230
B	670	339.30	3,314.70	381.00	617.57	719.43	0.00	713.07	0.00	222.83	0.00	0.00	0.00	383
B	185	355.50	3,462.60	398.00	645.05	751.45	0.00	744.80	0.00	233.92	0.00	0.00	0.00	405
B	685	0.90	8.70	1.00	1.62	1.88	0.00	1.87	0.00	0.58	0.00	0.00	0.00	1
B	680	320.40	3,105.90	358.00	578.77	674.23	0.00	672.00	0.00	211.17	0.00	0.00	0.00	364
B	675	4.50	43.50	5.00	8.08	9.42	0.00	9.33	0.00	2.92	0.00	0.00	0.00	5
B	690	412.20	4,010.70	462.00	746.90	871.98	0.00	866.13	0.00	270.67	0.00	0.00	0.00	467
B	693	216.00	2,096.70	241.00	389.62	453.88	0.00	453.60	0.00	142.92	0.00	0.00	0.00	249
B	700	169.20	1,626.90	189.00	305.55	357.83	0.00	354.67	0.00	110.83	0.00	0.00	0.00	191
B	695	120.60	1,165.80	135.00	219.87	256.13	0.00	253.87	0.00	79.92	0.00	0.00	0.00	139
B	710	333.90	3,253.80	377.00	609.48	713.78	0.00	711.20	0.00	224.00	0.00	0.00	0.00	386
B	725	39.60	391.50	45.00	72.75	84.75	0.00	87.73	0.00	27.42	0.00	0.00	0.00	47
B	720	164.70	1,618.20	189.00	305.55	355.95	0.00	352.80	0.00	110.25	0.00	0.00	0.00	191
B	715	88.20	861.30	99.00	160.05	186.45	0.00	184.80	0.00	57.75	0.00	0.00	0.00	100
B	730	495.90	4,793.70	552.00	892.40	1,041.48	0.00	1,032.27	0.00	322.58	0.00	0.00	0.00	556
B	735	0.90	8.70	1.00	1.62	1.88	0.00	1.87	0.00	0.58	0.00	0.00	0.00	1
B	740	45.90	443.70	51.00	82.45	96.05	0.00	95.20	0.00	29.75	0.00	0.00	0.00	53
K	220	387.90	3,819.30	440.00	125.52	839.97	0.00	836.27	0.00	262.50	0.00	0.00	0.00	452
K	305	107.10	1,044.00	240.00	34.28	227.88	292.42	224.00	0.00	430.00	0.00	685.67	641.30	121
K	215	58.50	574.20	134.00	19.27	128.07	164.33	128.80	0.00	247.25	0.00	391.00	365.70	69
K	210	591.87	1,696.50	0.00	55.82	371.02	1,122.90	367.73	0.00	165.00	1,178.10	600.60	1,566.15	197
K	140	1,030.40	2,949.30	0.00	96.33	642.22	1,943.70	636.53	0.00	284.17	2,034.90	1,043.47	2,742.75	345
K	130	1,278.80	3,645.30	0.00	119.57	798.53	2,416.80	1,565.10	0.00	353.33	2,534.70	1,292.20	3,402.60	428
K	135	3.12	17.40	0.17	0.57	3.77	15.07	7.40	0.00	2.50	24.35	9.10	59.35	3
K	147	3.07	8.70	0.00	0.28	1.88	5.70	1.87	0.00	0.83	5.95	3.03	7.95	1
K	143	199.33	565.50	0.00	18.98	126.18	881.90	126.93	0.00	57.50	410.55	209.30	548.55	69
K	150	591.87	1,679.10	0.00	54.97	365.37	1,122.90	369.60	0.00	165.83	1,190.00	609.70	1,605.90	202
K	180	1,134.67	3,323.40	0.00	109.93	730.73	2,211.60	1,251.20	1,368.50	488.75	2,326.45	1,189.07	3,550.10	393
K	175	484.53	1,545.77	0.00	45.05	299.45	917.70	518.40	570.50	203.75	969.85	500.50	1,490.50	165
K	182	407.87	1,330.53	0.00	38.53	256.13	780.90	435.20	479.50	172.50	821.10	418.60	1,255.63	139
K	183	389.47	1,104.90	0.00	36.27	241.07	735.30	416.00	455.00	162.50	773.50	394.33	1,174.33	130
K	160	1,521.07	4,367.40	0.00	143.37	1,121.63	2,884.20	942.67	0.00	420.83	3,004.75	1,537.90	4,030.65	507
K	170	1,223.60	3,532.20	0.00	115.32	665.85	5,168.90	761.60	0.00	341.67	2,439.50	1,243.67	3,275.40	412
K	165	1,131.60	3,227.70	0.00	106.82	711.90	2,154.60	705.60	0.00	315.83	2,255.05	1,149.63	3,005.10	378
K	168	300.53	870.00	0.00	28.90	192.10	632.70	209.07	0.00	93.33	666.40	342.77	898.35	113
K	185	591.87	1,705.20	0.00	56.38	374.78	1,134.30	371.47	0.00	166.67	1,190.00	606.67	1,590.00	200
K	186	303.60	878.70	0.00	28.90	192.10	587.10	192.27	0.00	87.50	624.75	318.50	834.75	105
K	187	1,855.33	5,350.50	0.00	175.38	1,167.67	3,545.40	1,161.07	0.00	520.00	3,712.80	1,901.90	5,000.55	629
K	190	1,751.07	5,011.20	0.00	165.47	1,099.87	3,340.20	1,093.87	0.00	493.33	3,522.40	1,804.83	4,738.20	596
K	195	472.27	1,339.80	12.83	43.92	640.67	2,536.83	560.58	935.17	129.17	922.25	1,562.15	2,674.23	157
K	197	3.07	8.70	0.08	0.28	4.13	16.37	3.62	6.03	0.83	5.95	9.95	17.03	1
K	200	1,475.07	4,106.40	39.58	135.43	1,975.73	7,856.00	1,750.47	2,926.17	409.17	2,921.45	4,915.30	8,414.47	494
L	385	3.07	8.70	0.00	0.28	1.88	5.70	1.87	0.00	0.83	5.95	3.03	17.03	1
L	390	953.73	2,749.20	0.00	89.53	602.67	1,824.00	597.33	0.00	267.50	1,909.95	973.70	2,551.95	321
L	375	1,066.22	2,157.60	0.00	70.27	467.07	268.67	462.93	0.00	143.50	0.00	0.00	0.00	247
L	380	2,577.05	5,280.90	0.00	172.55	1,148.83	660.83	1,140.53	0.00	356.42	0.00	0.00	0.00	610
L	383	241.73	495.90	0.00	16.15	107.35	61.75	106.40	0.00	33.25	0.00	0.00	0.00	57
L	365	4.32	8.70	0.00	0.28	1.88	1.08	1.87	0.00	0.58	0.00	0.00	0.00	1
L	360	1,286.37	2,653.50	0.00	86.42	574.42	330.42	569.33	0.00	178.50	0.00	0.00	0.00	306
L	370	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0
L	400	779.10	2,592.60	0.00	84.43	561.23	323.92	558.13	0.00	174.42	0.00	0.00	0.00	299
L	405	2.65	8.70	0.00	0.28	1.88	1.08	1.87	0.00	0.58	0.00	0.00	0.00	1
L	410	1,354.15	4,480.50	0.00	146.20	969.92	557.92	965.07	0.00	301.58	0.00	0.00	0.00	517
L	415	132.50	435.00	0.00	14.17	94.17	54.17	93.33	0.00	29.17	0.00	0.00	0.00	55
L	420	241.15	809.10	0.00	26.92	178.92	102.92	177.33	0.00	55.42	0.00	0.00	0.00	95
L	430	908.95	3,010.20	0.00	98.32	653.52	375.92	647.73	0.00	201.83	0.00	0.00	0.00	346
L	440	1,091.80	3,662.70	0.00	120.42	802.30	461.50	795.20	0.00	248.50	0.00	0.00	0.00	426
L	450	127.20	426.30	0.00	14.17	94.17	54.17	93.33	0.00	29.17	0.00	0.00	0.00	50
L	444	251.75	843.90	0.00	28.05	186.45	107.25	184.80	0.00	57.75	0.00	0.00	0.00	99
L	443	564.45	1,896.60	0.00	61.77	410.57	236.17	406.93	0.00	126.58	0.00	0.00	0.00	219

L	445	1,433.65	4,750.20	0.00	154.98	1,030.18	593.67	1,022.93	0.00	316.75	0.00	0.00	0.00	543
L	447	469.05	1,583.40	0.00	51.57	346.53	199.33	343.47	0.00	106.17	0.00	0.00	0.00	182
L	442	320.65	1,078.80	0.00	35.42	235.42	135.42	233.33	0.00	72.92	0.00	0.00	0.00	124
L	460	850.65	2,844.90	0.00	92.65	615.85	354.25	610.40	0.00	190.75	0.00	0.00	0.00	327
L	350	1,346.20	4,558.80	0.00	149.03	990.63	569.83	981.87	0.00	303.92	0.00	0.00	0.00	521
L	353	980.50	3,288.60	0.00	107.38	713.78	410.58	707.47	0.00	221.08	0.00	0.00	0.00	379
L	352	164.30	556.80	0.00	18.13	120.53	69.33	119.47	0.00	37.33	0.00	0.00	0.00	64
L	354	209.35	704.70	0.00	22.95	152.55	87.75	151.20	0.00	47.25	0.00	0.00	0.00	81
L	355	628.05	2,096.70	0.00	68.28	453.88	261.08	449.87	0.00	140.58	0.00	0.00	0.00	241
L	342	280.90	930.90	0.00	31.17	207.17	119.17	205.33	0.00	64.17	0.00	0.00	0.00	110
L	345	773.80	2,575.20	0.00	83.87	557.47	320.67	552.53	0.00	172.67	0.00	0.00	0.00	294
L	344	198.75	661.20	0.00	22.10	146.90	84.50	145.60	0.00	45.50	0.00	0.00	0.00	77
L	346	201.40	678.60	0.00	22.10	146.90	84.50	145.60	0.00	45.50	0.00	0.00	0.00	78
L	349	492.90	1,618.20	0.00	52.70	350.30	201.50	347.20	0.00	108.50	0.00	0.00	0.00	186
L	347	781.75	2,601.30	0.00	84.72	563.12	323.92	558.13	0.00	174.42	0.00	0.00	0.00	299
L	348	588.30	2,001.00	0.00	65.17	433.17	249.17	429.33	0.00	133.58	0.00	0.00	0.00	229
L	340	1,523.75	5,098.20	0.00	166.60	1,109.28	642.42	1,106.93	0.00	345.92	0.00	0.00	0.00	593
L	330	1,264.05	4,202.10	0.00	136.85	911.53	526.50	907.20	0.00	282.92	0.00	0.00	0.00	485
L	335	535.30	1,774.80	0.00	58.37	389.85	224.25	386.40	0.00	120.75	0.00	0.00	0.00	207
L	325	580.35	1,940.10	0.00	63.18	419.98	242.67	418.13	0.00	130.67	0.00	0.00	0.00	224
L	320	972.55	3,262.50	0.00	106.53	711.90	409.50	705.60	0.00	219.92	0.00	0.00	0.00	377
L	323	588.30	1,974.90	0.00	64.32	427.52	245.92	423.73	0.00	131.83	0.00	0.00	0.00	226
L	324	400.15	1,357.20	0.00	44.48	295.68	170.08	309.87	0.00	96.83	0.00	0.00	0.00	166



University of Moratuwa, Sri Lanka.
 Electronic Theses & Dissertations
www.lib.mrt.ac.lk

Annexure 3 - Supporting Calculation for Ambalangoda Feeder 3

Gonapinuwala		Other Subs SAIDI												Relevant SAIDI																																															
Temp %	Section	Type	Feb-13	Jan-13	Dec-12	Nov-12	Oct-12	Sep-12	Aug-12	Jul-12	Jun-12	May-12	Apr-12	Mar-12	Temp Fault %	Section	Type	Feb-13	Jan-13	Dec-12	Nov-12	Oct-12	Sep-12	Aug-12	Jul-12	Jun-12	May-12	Apr-12	Mar-12																																
-0-584	1	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	1	1	B	-	-	-	-	-	-	-	-	-	-	-	-	-																															
		R	5.07	9.80	4.48	8.60	4.88	5.83	6.51	8.22	10.42	13.14	12.91	4.41			R	0.01	8.53	0.19	0.05	1.69	0.36	0.07	4.23	0.01	0.07	33.94	0.02																																
	2	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	1	2	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	0.94	3	B	-	-	-	-	-	-	-	-	-	-	-	-	-	-															
		R	5.07	9.80	4.48	8.60	4.88	5.83	6.51	8.22	10.42	13.14	12.91	4.41			R	0.01	8.53	0.19	0.05	1.69	0.36	0.07	4.23	0.01	0.07	33.94	0.02																																
	3	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	0.97	4	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	0.9	5	B	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-														
		R	5.15	9.85	4.54	8.70	4.71	5.87	6.60	7.40	10.56	13.31	12.30	4.48			R	0.01	7.41	0.25	0.82	8.26	1.48	0.06	30.83	0.35	0.73	43.36	0.02																																
	4	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	0.9	6	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	0.9	7	B	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-														
		R	5.24	9.88	4.62	8.86	4.77	5.98	6.72	7.46	10.76	13.56	11.89	4.56			R	0.01	7.82	0.23	0.55	5.89	1.07	0.06	21.26	0.23	0.49	39.97	0.02																																
	5	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	0.9	8	B	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-																												
		R	5.12	9.22	4.40	8.70	4.80	5.66	6.22	8.35	10.28	11.70	12.15	3.96			R	0.39	27.63	4.37	0.29	5.57	7.98	11.98	1.91	8.98	51.59	49.93	16.43																																
	6	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	0.9	9	B	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-																												
		R	5.27	9.49	4.52	8.96	4.78	5.68	6.16	8.47	10.33	11.57	11.09	3.61			R	0.40	14.35	2.38	0.23	5.57	6.58	10.04	3.05	8.78	34.49	48.79	16.01																																
	7	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	0.9	10	B	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-																												
		R	5.11	10.09	4.53	8.72	4.98	5.75	6.30	8.29	10.57	13.05	11.95	4.47			R	1.17	0.01	0.34	0.00	0.09	5.19	9.29	3.93	0.00	8.43	54.64	0.12																																
	8	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	0.9	11	B	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-																												
		R	5.41	9.82	4.67	9.27	4.94	5.70	6.06	8.63	10.69	11.67	9.59	3.73			R	0.67	9.32	1.67	0.15	3.65	6.09	9.78	3.35	5.70	25.35	50.84	10.44																																
	9	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	0.9	12	B	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-																												
		R	4.98	9.92	4.32	8.57	4.90	5.74	6.05	8.18	10.39	13.09	13.46	4.40			R	5.23	0.06	9.61	0.16	0.00	5.16	29.09	5.97	0.01	0.23	2.18	0.02																																
	10	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	0.9	13	B	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-																												
		R	4.97	9.96	4.43	8.74	4.40	5.75	5.43	8.05	9.38	13.02	13.81	4.52			R	5.23	5.19	3.57	1.41	15.09	5.34	29.38	10.56	30.80	10.17	0.80	0.01																																
	11	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	0.95	14	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	0.95	15	B	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-														
		R	5.72	9.93	4.93	9.77	4.89	5.96	6.40	7.89	11.29	12.32	7.82	3.95			R	0.44	8.78	1.15	0.29	4.45	4.30	6.31	9.75	3.75	16.48	46.96	6.72																																
	12	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	0.93	16	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	0.95	17	B	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-														
		R	5.74	10.17	4.99	10.18	4.39	5.99	5.28	7.76	10.34	12.43	8.16	4.14			R	1.50	7.98	1.69	0.54	6.82	4.53	11.45	9.93	9.78	15.07	36.67	5.22																																
	13	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	0.95	18	B	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-																												
		R	4.96	9.36	4.57	1.37	4.55	4.50	6.42	7.39	10.2	11.61	13.40	4.54			R	5.45	18.30	0.96	154.19	10.49	31.20	5.80	23.90	10.80	39.51	11.04	0.11																																
	14	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	0.95	19	B	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-																												
		R	4.96	9.49	4.63	1.19	4.54	4.52	6.10	7.31	10.34	11.56	13.55	4.59			R	5.40	14.30	0.77	123.68	9.46	24.94	10.94	21.56	8.53	34.20	9.14	0.28																																
	15	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	0.94	20	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	0.94	21	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	0.94	22	B	-	-	-	-	-	-	-	-	-	-	-	-	-	-
		R	5.77	9.84	5.32	1.34	3.99	4.52	4.84	6.69	10.4	10.73	8.09	4.44			R	2.47	9.55	1.46	31.0	7.47	9.59	11.3	12.8	9.47	19.81	29.8	4.00																																

Kahatapitiya

Temp %	Section	Type	Feb-13	Jan-13	Dec-12	Nov-12	Oct-12	Sep-12	Aug-12	Jul-12	Jun-12	May-12	Apr-12	Mar-12
0.584	15	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01
		R	5.22	10.1	3.73	9.05	4.98	6.01	6.66	8.56	10.5	13.34	13.5	4.43
	16	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01
		R	5.22	10.1	3.73	9.05	4.98	6.01	6.66	8.56	10.5	13.34	13.5	4.43
	17	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01
		R	4.12	9.63	3.06	9.58	4.78	6.29	6.86	8.83	9.47	14.08	14.0	4.58
	18	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01
		R	5.28	10.4	4.70	8.98	5.00	5.80	6.46	7.39	9.77	13.78	14.2	4.01
	19	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01
		R	4.40	10.3	3.29	10.2	4.98	6.42	6.97	8.01	8.88	15.18	15.1	4.23
	20	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01
		R	4.98	9.77	4.40	8.45	4.83	5.73	6.39	8.15	10.2	12.90	13.2	4.33
	21	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01
		R	4.55	8.28	4.57	8.43	4.98	5.94	6.33	7.99	10.0	13.31	13.5	4.46
	22	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01
		R	3.74	8.39	4.73	8.74	5.00	6.17	6.49	7.87	10.2	13.29	13.5	4.09
	23	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01
		R	4.98	9.75	4.39	8.45	4.83	5.74	6.39	8.16	10.2	12.91	13.2	4.34
	24	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01
		R	3.74	8.36	4.72	8.74	5.00	6.17	6.49	7.88	10.2	13.30	13.5	4.09
	25	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01
		R	3.62	6.14	3.91	8.98	4.92	6.47	6.81	8.03	10.0	13.88	12.3	4.25
	26	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01
		R	2.58	5.90	2.49	11.2	5.12	7.46	7.59	7.83	8.41	16.79	14.3	4.11
	27	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01
		R	4.81	10.0	4.64	8.61	4.80	6.02	6.71	7.25	9.87	11.23	12.8	4.53
	28	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01
		R	4.68	10.3	4.03	8.84	4.75	6.22	6.95	7.28	10.2	10.64	13.0	4.67
	29	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01
		R	1.81	6.17	1.69	12.2	5.03	8.42	8.58	6.49	8.12	13.95	14.1	4.58
	30	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01
		R	1.97	6.32	1.07	13.4	5.45	8.98	7.66	7.04	8.51	15.29	14.9	4.94
	31	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01
		R	2.00	6.47	1.15	14.6	5.83	9.40	8.32	7.04	8.82	16.54	16.1	5.24
	32	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01
		R	1.60	6.86	1.22	15.5	6.03	9.83	8.81	7.20	7.30	17.38	16.8	5.52
	33	B	0.45	0.63	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01
		R	1.65	7.45	1.23	16.8	5.78	10.6	8.11	7.80	7.00	18.86	17.7	5.91


Temp Fault %	Section	Type	Feb-13	Jan-13	Dec-12	Nov-12	Oct-12	Sep-12	Aug-12	Jul-12	Jun-12	May-12	Apr-12	Mar-12
0.9	15	B	-	-	-	-	-	-	-	-	-	-	-	-
		R	1.68	4.59	13.8	0.02	2.65	1.78	2.65	2.45	6.48	6.85	9.68	2.95
0.9	16	B	0.76	0.45	0.88	0.66	0.32	0.67	0.55	0.34	0.24	0.32	0.67	0.56
		R	1.68	4.59	13.8	0.02	2.65	1.78	2.65	2.45	6.48	6.85	9.68	2.95
0.9	17	B	0.76	0.45	0.88	0.66	0.32	0.67	0.55	0.34	0.24	0.32	0.67	0.56
		R	11.3	10.8	14.3	0.07	5.19	1.58	2.94	3.11	15.9	4.16	7.70	2.53
1	18	B	-	-	-	-	-	-	-	-	-	-	-	-
		R	0.70	0.08	0.08	0.72	2.28	4.68	5.44	19.1	16.9	0.27	0.12	8.95
0.95	19	B	0.76	0.45	0.88	0.66	0.32	0.67	0.55	0.34	0.24	0.32	0.67	0.56
		R	7.58	7.02	9.30	0.04	3.36	1.02	1.91	2.01	10.2	2.69	4.98	1.64
0.96	20	B	0.23	0.35	0.56	0.01	0.04	0.89	0.24	0.02	0.98	0.01	-	-
		R	-	-	-	-	-	-	-	-	-	-	-	-
0.96	21	B	-	-	-	-	-	-	-	-	-	-	-	-
		R	16.3	48.8	0.07	8.95	0.75	0.18	7.98	12.5	16.5	2.29	7.36	1.17
0.96	22	B	-	-	-	-	-	-	-	-	-	-	-	-
		R	21.0	27.7	0.08	4.68	2.63	0.09	5.09	11.7	9.78	7.93	10.2	7.49
0.96	23	B	-	-	-	-	-	-	-	-	-	-	-	-
		R	6.28	53.3	21.2	2.97	5.02	0.11	0.11	2.46	0.66	0.58	14.2	0.23
0.96	24	B	-	-	-	-	-	-	-	-	-	-	-	-
		R	20.9	27.9	0.25	4.67	2.65	0.09	5.05	11.7	9.71	7.87	10.3	7.43
0.96	25	B	-	-	-	-	-	-	-	-	-	-	-	-
		R	15.3	37.4	8.11	4.38	4.14	0.11	3.21	9.09	11.6	5.46	20.1	4.94
0.95	26	B	0.50	0.40	0.72	0.33	0.18	0.78	0.40	0.18	0.61	0.16	0.34	0.28
		R	10.6	18.8	8.84	1.72	3.66	0.67	2.41	4.75	10.8	3.77	10.8	2.92
0.93	27	B	-	-	-	-	-	-	-	-	-	-	-	-
		R	8.13	4.68	0.02	5.40	5.28	0.46	0.40	24.9	17.0	43.97	21.9	0.74
0.93	28	B	-	-	-	-	-	-	-	-	-	-	-	-
		R	8.30	3.94	8.42	4.06	5.72	0.36	0.25	17.7	10.5	37.83	15.5	0.63
0.95	29	B	0.50	0.40	0.72	0.33	0.18	0.78	0.40	0.18	0.61	0.16	0.34	0.28
		R	10.1	15.5	8.75	2.23	4.11	0.60	1.94	7.58	10.7	11.17	11.8	2.42
0.95	30	B	0.50	0.40	0.72	0.33	0.18	0.78	0.40	0.18	0.61	0.16	0.34	0.28
		R	8.81	14.1	8.63	1.94	3.70	0.91	3.97	6.74	9.93	9.83	11.1	2.24
0.95	31	B	0.50	0.40	0.72	0.33	0.18	0.78	0.40	0.18	0.61	0.16	0.34	0.28
		R	8.15	13.2	7.84	1.78	3.45	1.22	3.62	6.77	9.48	9.01	10.2	2.18
0.95	32	B	0.50	0.40	0.72	0.33	0.18	0.78	0.40	0.18	0.61	0.16	0.34	0.28
		R	8.17	12.5	7.39	1.68	3.40	1.28	3.42	6.63	10.8	8.65	9.94	2.09
0.95	33	B	0.50	0.40	0.72	0.33	0.18	0.78	0.40	0.18	0.61	0.16	0.34	0.28
		R	7.67	11.6	6.95	1.57	3.79	1.24	4.36	6.19	10.8	8.06	9.67	2.01

Kuleegoda

Other Subs SAIDI

Temp %	Section	Type	Feb-13	Jan-13	Dec-12	Nov-12	Oct-12	Sep-12	Aug-12	Jul-12	Jun-12	May-12	Apr-12	Mar-12
0.584	34	B	0.5	0.6	0.2	0.4	0.6	0.0	0.0	0.9	0.2	0.0	1.0	0.0
		R	5.0	9.8	4.5	8.6	4.8	5.6	6.4	8.3	10.3	12.0	13.5	4.4
	35	B	0.5	0.6	0.2	0.4	0.6	0.0	0.0	0.9	0.2	0.0	1.0	0.0
		R	5.1	9.9	4.5	8.7	4.8	5.7	6.4	8.4	10.4	11.9	13.7	4.4
	36	B	0.5	0.6	0.2	0.4	0.6	0.0	0.0	0.9	0.2	0.0	1.0	0.0
		R	5.0	9.8	4.4	8.5	4.9	5.6	6.4	8.2	10.3	12.8	13.4	4.4
	37	B	0.5	0.6	0.2	0.4	0.6	0.0	0.0	0.9	0.2	0.0	1.0	0.0
		R	5.0	9.8	4.4	8.5	4.9	5.7	6.4	8.2	10.3	12.8	13.4	4.4
	38	B	0.5	0.6	0.2	0.4	0.6	0.0	0.0	0.9	0.2	0.0	1.0	0.0
		R	5.1	9.9	4.5	8.6	4.9	5.6	6.4	8.3	10.4	12.7	13.5	4.4
	39	B	0.5	0.6	0.2	0.4	0.6	0.0	0.0	0.9	0.2	0.0	1.0	0.0
		R	5.2	10.0	4.5	8.8	5.0	5.1	6.5	8.5	10.5	11.5	13.6	4.5
	40	B	0.5	0.6	0.2	0.4	0.6	0.0	0.0	0.9	0.2	0.0	1.0	0.0
		R	5.4	10.1	4.6	9.1	4.9	5.0	6.5	8.7	10.7	10.4	14.0	4.6
	41	B	0.5	0.6	0.2	0.4	0.6	0.0	0.0	0.9	0.2	0.0	1.0	0.0
		R	5.1	9.9	4.5	8.7	4.8	5.7	6.5	8.3	10.5	13.3	13.6	4.2
	42	B	0.5	0.6	0.2	0.4	0.6	0.0	0.0	0.9	0.2	0.0	1.0	0.0
		R	5.7	10.5	4.9	9.7	4.9	4.5	6.8	9.1	11.2	11.1	14.5	4.3
	43	B	0.5	0.6	0.2	0.4	0.6	0.0	0.0	0.9	0.2	0.0	1.0	0.0
		R	5.1	10.0	4.6	8.8	5.0	5.4	6.2	8.4	10.4	13.5	13.9	3.5
	44	B	0.5	0.6	0.2	0.4	0.6	0.0	0.0	0.9	0.2	0.0	1.0	0.0
		R	5.9	10.8	5.2	10.2	5.1	4.0	6.7	9.4	11.4	11.7	15.2	3.3
	45	B	0.5	0.6	0.2	0.4	0.6	0.0	0.0	0.9	0.2	0.0	1.0	0.0
		R	5.0	9.8	4.4	8.4	4.8	5.7	6.4	8.2	10.2	12.9	13.3	4.3
	46	B	0.5	0.6	0.2	0.4	0.6	0.0	0.0	0.9	0.2	0.0	1.0	0.0
		R	5.9	10.8	5.2	10.2	5.1	4.0	6.7	9.4	11.4	11.7	15.2	3.3
	47	B	0.5	0.6	0.2	0.4	0.6	0.0	0.0	0.9	0.2	0.0	1.0	0.0
		R	5.9	10.8	5.2	10.2	5.1	4.0	6.7	9.4	11.4	11.7	15.2	3.3
	48	B	0.5	0.6	0.2	0.4	0.6	0.0	0.0	0.9	0.2	0.0	1.0	0.0
		R	6.1	11.0	5.3	10.5	5.1	4.1	6.9	9.8	11.8	11.6	15.8	3.3
	49	B	0.5	0.6	0.2	0.4	0.6	0.0	0.0	0.9	0.2	0.0	1.0	0.0
		R	5.0	9.8	4.4	8.4	4.8	5.7	6.4	8.2	10.2	12.9	13.3	4.3
	50	B	0.5	0.6	0.2	0.4	0.6	0.0	0.0	0.9	0.2	0.0	1.0	0.0
		R	6.1	11.0	5.3	10.5	5.1	4.1	6.9	9.8	11.8	11.6	15.8	3.3

Temp Fault %	Section	Type	Feb-13	Jan-13	Dec-12	Nov-12	Oct-12	Sep-12	Aug-12	Jul-12	Jun-12	May-12	Apr-12	Mar-12
0.96	34	B	-	-	-	-	-	-	-	-	-	-	-	-
		R	0.3	4.7	0.1	0.4	8.8	11.8	6.1	-	5.7	78.7	0.4	0.8
0.96	35	B	-	-	-	-	-	-	-	-	-	-	-	-
		R	0.3	6.5	1.9	0.4	7.5	8.6	5.6	0.3	3.1	48.2	0.3	0.8
0.9	36	B	-	-	-	-	-	-	-	-	-	-	-	-
		R	0.0	4.6	0.1	0.1	0.7	15.2	1.9	0.1	0.2	26.3	0.6	0.0
0.9	37	B	-	-	-	-	-	-	-	-	-	-	-	-
		R	0.0	4.6	2.4	0.1	0.7	8.2	5.8	0.4	0.2	22.6	0.6	0.7
0.9	38	B	-	-	-	-	-	-	-	-	-	-	-	-
		R	0.0	4.6	1.2	0.1	0.7	12.1	3.7	0.2	0.2	24.7	0.6	0.3
0.9	39	B	-	-	-	-	-	-	-	-	-	-	-	-
		R	0.0	4.6	1.5	0.1	1.0	19.1	4.9	0.6	4.3	44.4	7.4	0.6
0.93	40	B	-	-	-	-	-	-	-	-	-	-	-	-
		R	0.1	5.3	1.7	0.2	3.5	15.0	5.2	0.5	3.8	45.9	4.6	0.7
0.62	41	B	-	-	-	-	-	-	-	-	-	-	-	-
		R	0.3	4.6	0.0	0.1	6.1	7.0	3.0	3.2	0.6	-	3.0	7.6
0.62	42	B	-	-	-	-	-	-	-	-	-	-	-	-
		R	0.3	5.1	0.9	0.2	4.6	13.9	3.4	2.2	4.1	24.7	5.3	4.7
0.62	43	B	-	-	-	-	-	-	-	-	-	-	-	-
		R	2.4	5.3	0.9	1.6	1.0	13.1	9.9	2.7	6.8	1.5	1.6	22.3
0.62	44	B	-	-	-	-	-	-	-	-	-	-	-	-
		R	0.8	5.1	0.9	0.6	3.7	13.7	5.1	2.4	4.8	18.6	4.3	9.3
0.9	45	B	1.1	0.5	0.3	0.6	0.3	0.8	0.2	0.9	0.5	0.3	0.4	1.0
		R	-	-	-	-	-	-	-	-	-	-	-	-
0.55	46	B	1.1	0.5	0.3	0.6	0.3	0.8	0.2	0.9	0.5	0.3	0.4	1.0
		R	0.8	5.1	0.9	0.6	3.7	13.7	5.1	2.4	4.8	18.6	4.3	9.3
0.55	47	B	0.6	0.7	0.4	0.4	0.4	0.9	0.6	0.7	0.4	0.4	0.4	0.9
		R	0.8	5.1	0.9	0.6	3.7	13.7	5.1	2.4	4.8	18.6	4.3	9.3
0.55	48	B	0.6	0.7	0.4	0.4	0.4	0.9	0.6	0.7	0.4	0.4	0.4	0.9
		R	0.7	5.0	1.0	0.5	3.8	11.8	4.4	2.0	4.2	17.8	3.8	8.1
0.95	49	B	0.6	0.3	0.2	0.3	0.7	0.6	0.8	0.5	0.9	0.7	0.3	0.7
		R	-	-	-	-	-	-	-	-	-	-	-	-
0.61	50	B	0.6	0.6	0.4	0.4	0.5	0.8	0.7	0.6	0.6	0.5	0.4	0.8
		R	2.2	5.0	0.8	1.5	4.1	9.5	3.6	6.6	6.7	22.9	7.4	6.7



Cost of Interruption

Section	Feb-13	Jan-13	Dec-12	Nov-12	Oct-12	Sep-12	Aug-12	Jul-12	Jun-12	May-12	Apr-12	Mar-12	Avg
1	(488.8)	(586.6)	(262.6)	(417.7)	(573.0)	(48.8)	(92.1)	(892.6)	(324.0)	(126.7)	(603.0)	(41.0)	(371.4)
2	277.1	485.6	128.8	178.0	380.1	(38.6)	(24.0)	622.1	84.4	(92.7)	1,064.9	(32.4)	252.8
3	(489.4)	(609.1)	(262.5)	(408.4)	(486.1)	(34.7)	(93.1)	(538.0)	(320.7)	(119.4)	(502.1)	(41.4)	(325.4)
4	252.7	439.4	116.4	164.6	409.1	(30.5)	(28.0)	813.2	72.4	(91.4)	1,091.2	(33.9)	264.6
5	(484.4)	(352.3)	(209.4)	(415.7)	(525.6)	48.5	60.8	(929.0)	(209.3)	536.7	(442.2)	170.4	(229.3)
6	(485.4)	(522.6)	(235.6)	(418.5)	(525.4)	30.7	36.6	(915.6)	(212.3)	321.5	(447.9)	167.9	(267.2)
7	(474.4)	(708.9)	(261.5)	(419.5)	(596.4)	12.5	26.1	(903.0)	(325.3)	(20.4)	(380.9)	(40.2)	(341.0)
8	(483.2)	(588.9)	(245.9)	(422.0)	(551.0)	24.4	34.2	(913.0)	(254.1)	205.0	(409.6)	96.4	(292.3)
9	(422.0)	(706.8)	(142.6)	(416.1)	(596.8)	12.2	278.6	(876.2)	(323.7)	(124.4)	(1,056.9)	(40.9)	(368.0)
10	(422.0)	(642.3)	(219.9)	(401.7)	(401.9)	14.5	287.4	(817.2)	74.2	2.0	(1,077.3)	(41.9)	(303.8)
11	239.2	428.2	118.2	141.7	368.1	12.2	56.6	619.8	106.8	131.3	1,173.3	60.4	288.0
12	237.5	391.9	116.6	129.6	382.9	13.6	129.9	590.1	184.3	106.8	989.5	37.2	275.8
13	(415.2)	(458.6)	(253.2)	1,699.7	(453.9)	373.7	(15.0)	(626.1)	(178.1)	412.4	(936.7)	(40.7)	(74.3)

Section	Type	Feb-13	Jan-13	Dec-12	Nov-12	Oct-12	Sep-12	Aug-12	Jul-12	Jun-12	May-12	Apr-12	Mar-12
1	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-	-0.14	-0.01	-0.57	0.00
	R	-2.95	2.81	-2.42	-4.97	-1.17	-3.05	-3.73	-	-6.08	-7.60	26.40	-2.56
2	B	0.19	0.26	0.10	0.15	0.23	0.00	0.02	0.37	0.10	0.01	0.41	0.00
	R	-2.95	2.81	-2.42	-4.97	-1.17	-3.05	-3.73	-	-6.08	-7.60	26.40	-2.56
3	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-	-0.14	-0.01	-0.57	0.00
	R	-2.99	1.22	-2.41	-4.31	5.01	-2.04	-3.80	24.66	-5.84	-7.08	33.58	-2.59
4	B	0.17	0.24	0.09	0.14	0.22	0.00	0.02	0.34	0.09	0.01	0.38	0.00
	R	-3.05	1.81	-2.47	-4.65	2.93	-2.45	-3.86	16.26	-6.07	-7.44	31.83	-2.64
5	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-	-0.14	-0.01	-0.57	0.00
	R	-2.64	19.49	1.37	-4.82	2.21	3.87	7.16	-	2.08	39.60	37.84	12.48
6	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-	-0.14	-0.01	-0.57	0.00
	R	-2.71	7.37	-0.50	-5.02	2.22	2.61	5.43	-	1.87	24.29	37.43	12.30
6*	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-	-0.14	-0.01	-0.57	0.00
	R	-1.93	-5.89	-2.34	-5.09	-2.83	1.32	4.69	-	-6.17	-0.04	42.20	-2.51
7	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-	-0.14	-0.01	-0.57	0.00
	R	-2.55	2.65	-1.23	-5.28	0.40	2.16	5.26	-	-1.11	16.00	40.16	7.21
8	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-	-0.14	-0.01	-0.57	0.00
	R	1.80	-5.74	6.12	-4.86	-2.86	1.29	22.65	0.60	-6.06	-7.44	-5.89	-2.56
9	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-	-0.14	-0.01	-0.57	0.00
	R	1.80	-1.14	0.62	-3.83	11.01	1.45	23.27	4.80	22.25	1.55	-7.34	-2.62
9*	B	0.16	0.23	0.08	0.13	0.20	0.00	0.01	0.33	0.09	0.01	0.36	0.00
	R	-2.93	2.54	-1.78	-5.43	1.37	0.60	2.25	4.65	-3.04	8.46	40.05	4.08
10	B	0.16	0.22	0.08	0.12	0.19	0.00	0.01	0.31	0.08	0.01	0.34	0.00
	R	-1.96	1.49	-1.34	-5.44	3.78	0.72	7.57	4.70	3.06	6.76	29.34	2.44
11	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-	-0.14	-0.01	-0.57	0.00
	R	2.28	11.92	-1.75	145.68	7.31	27.01	1.76	18.39	4.30	30.75	2.66	-2.54

14	(415.8)	(513.1)	(256.4)	1,293.9	(467.6)	289.9	56.2	(656.7)	(209.6)	341.8	(963.3)	(38.9)	(128.3)
15	257.9	427.1	115.0	611.2	405.3	93.2	134.1	653.6	184.5	185.7	921.8	19.4	334.1

12	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-0.52	-0.14	-0.01	-0.57	0.00
	R	2.24	8.04	-1.97	116.80	6.33	21.05	6.83	16.21	2.06	25.73	0.76	-2.41
13	B	0.16	0.22	0.08	0.12	0.20	0.00	0.01	0.32	0.09	0.01	0.35	0.00
	R	-1.05	3.23	-1.73	28.40	4.69	6.37	7.82	8.13	2.78	12.35	23.34	1.17


Section	Feb-13	Jan-13	Dec-12	Nov-12	Oct-12	Sep-12	Aug-12	Jul-12	Jun-12	May-12	Apr-12	Mar-12	Avg
16	(468.8)	(644.9)	(64.3)	(421.8)	(560.3)	(30.4)	(57.1)	(920.5)	(233.8)	(33.1)	(949.2)	0.1	(365.3)
17	695.3	121.0	1,433.4	701.5	(15.7)	1,110.0	879.0	(341.8)	174.7	511.5	191.1	953.2	534.4
18	826.5	158.0	1,344.1	630.3	(15.3)	1,035.2	822.8	(372.0)	277.7	431.5	84.3	886.8	509.1
19	(480.8)	(710.8)	(266.1)	(411.8)	(566.5)	10.2	(18.6)	(683.8)	(87.1)	(129.3)	(1,089.1)	84.1	(362.5)
20	745.4	66.6	1,210.0	579.3	(64.8)	980.6	769.6	(404.1)	186.3	379.8	(9.1)	838.8	439.9
21	(112.4)	(170.3)	593.1	(408.0)	(535.0)	1,310.3	275.4	(920.9)	1,178.5	(118.1)	(1,083.2)	(40.6)	(2.6)
22	(263.9)	(76.6)	(265.2)	(303.9)	(588.0)	(52.5)	9.3	(791.9)	(111.8)	(100.2)	(991.9)	(26.8)	(296.9)
23	(194.4)	(343.9)	(266.5)	(360.4)	(564.4)	(55.4)	(28.6)	(800.3)	(199.1)	(28.6)	(955.1)	56.2	(311.7)
24	(403.4)	(31.9)	3.6	(379.7)	(532.7)	(51.6)	(90.8)	(920.4)	(314.3)	(118.5)	(903.5)	(37.7)	(315.1)

Section	Type	Feb-13	Jan-13	Dec-12	Nov-12	Oct-12	Sep-12	Aug-12	Jul-12	Jun-12	May-12	Apr-12	Mar-12
14	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-0.52	-0.14	-0.01	-0.57	0.00
	R	-1.53	-1.33	11.69	-5.26	-0.26	-1.74	-1.24	-2.55	0.34	-0.94	1.77	0.36
15	B	0.42	0.08	0.75	0.46	-0.01	0.67	0.53	-0.18	0.10	0.31	0.10	0.56
	R	-1.53	-1.33	11.69	-5.26	-0.26	-1.74	-1.24	-2.55	0.34	-0.94	1.77	0.36
16	B	0.42	0.06	0.69	0.42	-0.03	0.63	0.49	-0.20	0.09	0.29	0.06	0.52
	R	7.80	4.57	11.73	5.53	2.09	-2.19	-1.24	2.23	9.41	-4.31	-0.97	-0.30
17	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-0.52	-0.14	-0.01	-0.57	0.00
	R	-2.39	-6.02	-2.67	-4.55	-0.71	1.15	1.50	14.29	10.77	-7.78	-8.18	6.34
18	B	0.46	0.04	0.66	0.39	-0.04	0.60	0.47	-0.21	0.08	0.28	0.03	0.50
	R	-2.57	0.25	6.45	-5.96	0.11	-2.83	-2.35	-2.87	4.07	-6.44	-4.37	-1.00
19	B	-0.04	-0.05	0.37	-0.20	-0.29	0.80	0.19	-0.50	0.74	-0.01	-0.57	0.00
	R	-2.91	-5.71	-2.57	-4.93	-2.82	-3.35	-3.73	-4.76	-5.98	-7.54	-7.76	-2.53
20	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-0.52	-0.14	-0.01	-0.57	0.00
	R	13.04	39.10	-2.61	3.13	-2.23	-3.31	3.49	6.60	9.02	-5.71	-1.27	-1.55
21	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-0.52	-0.14	-0.01	-0.57	0.00
	R	17.99	20.09	-2.69	-0.89	-0.55	-3.52	0.79	6.00	2.81	-0.62	1.35	4.35
21*	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-0.52	-0.14	-0.01	-0.57	0.00
	R	3.12	42.28	16.52	-2.26	1.70	-3.25	-3.63	-2.55	-5.39	-7.02	5.02	-2.33

25	(196.0)	(341.0)	(264.2)	(360.6)	(564.2)	(55.4)	(29.2)	(801.3)	(200.1)	(29.4)	(954.7)	55.5	(311.7)	22	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-0.52	-0.14	-0.01	-0.57	0.00
															R	17.88	20.29	-2.53	-0.90	-0.54	-3.52	0.75	5.93	2.74	-0.68	1.38	4.30
26	(269.5)	(176.6)	(152.5)	(363.1)	(541.7)	(57.6)	(52.8)	(829.2)	(165.1)	(60.9)	(806.6)	26.1	(287.4)	23	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-0.52	-0.14	-0.01	-0.57	0.00
															R	12.65	31.99	5.42	-1.08	1.06	-3.67	-0.93	3.94	5.22	-2.92	11.92	2.21
27	473.4	204.2	1,006.1	109.3	(265.9)	1,176.1	554.6	(601.9)	799.4	148.7	(419.4)	442.6	302.3	23*	B	0.21	0.00	0.54	0.11	-0.16	0.72	0.34	-0.35	0.43	0.14	-0.26	0.26
															R	8.56	14.04	6.76	-4.97	0.42	-3.74	-2.19	-0.15	5.15	-6.30	1.74	0.31
28	(380.6)	(646.1)	(266.4)	(346.4)	(525.5)	(49.3)	(89.6)	(610.5)	(92.1)	475.0	(786.2)	(32.2)	(279.1)	24	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-0.52	-0.14	-0.01	-0.57	0.00
															R	4.75	-1.42	-2.69	0.10	2.21	-3.08	-3.54	19.50	10.42	35.21	13.37	-1.94
29	(377.2)	(658.2)	(149.3)	(366.3)	(519.2)	(52.2)	(93.5)	(707.4)	(181.1)	397.9	(874.5)	(35.0)	(301.3)	25	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-0.52	-0.14	-0.01	-0.57	0.00
															R	4.98	-2.28	5.64	-1.31	2.66	-3.29	-3.82	12.61	4.09	29.72	7.08	-2.13
30	473.1	168.8	1,024.9	114.0	(255.7)	1,180.7	547.4	(549.8)	813.0	273.2	(397.6)	437.3	319.1	25*	B	0.21	0.01	0.54	0.11	-0.16	0.73	0.35	-0.35	0.43	0.14	-0.26	0.26
															R	8.54	11.03	7.23	-5.04	0.92	-4.35	-3.19	3.33	5.38	2.35	2.88	-0.40
31	454.5	140.1	1,015.0	94.0	(268.1)	1,166.9	574.5	(569.3)	786.9	240.3	(421.3)	426.9	303.4	26	B	0.21	0.00	0.54	0.11	-0.16	0.72	0.34	-0.35	0.43	0.14	-0.26	0.26
															R	7.22	9.48	7.40	-6.06	0.26	-4.40	-0.78	2.16	4.26	0.21	1.60	-0.80
32	445.5	144.7	1,030.7	94.2	(267.3)	1,194.3	578.9	(561.0)	801.9	227.5	(429.2)	433.9	307.8	27	B	0.21	0.01	0.55	0.11	-0.16	0.74	0.35	-0.35	0.44	0.14	-0.25	0.26
															R	6.58	8.83	6.77	-6.86	-0.12	-4.33	-1.42	2.32	3.85	-1.09	0.23	-0.99
33	449.0	131.2	1,024.2	85.5	(269.6)	1,191.5	572.2	(564.1)	832.8	215.8	(437.9)	430.4	305.1	28	B	0.21	0.01	0.55	0.11	-0.16	0.74	0.35	-0.35	0.44	0.14	-0.25	0.26
															R	6.82	7.87	6.31	-7.47	-0.29	-4.53	-1.90	2.10	6.05	-1.93	-0.39	-1.24
34	442.0	106.5	1,005.1	67.3	(266.1)	1,171.3	583.3	(578.9)	823.4	191.8	(456.1)	421.0	292.5	29	B	0.21	0.01	0.54	0.11	-0.16	0.73	0.35	-0.35	0.43	0.14	-0.26	0.26
															R	6.32	6.59	5.82	-8.36	0.18	-5.02	-0.63	1.26	6.12	-3.44	-1.28	-1.56


Section	Feb-13	Jan-13	Dec-12	Nov-12	Oct-12	Sep-12	Aug-12	Jul-12	Jun-12	May-12	Apr-12	Mar-12	Avg
35	(485)	(640)	(263)	(413)	(472)	113	(6)	(952)	(243)	988	(1,079)	(29)	(290)
36	(485)	(615)	(239)	(414)	(490)	68	(13)	(950)	(281)	560	(1,082)	(30)	(331)
37	(488)	(646)	(263)	(417)	(588)	148	(67)	(951)	(320)	223	(1,076)	(41)	(374)
38	(488)	(644)	(232)	(417)	(588)	59	(13)	(946)	(320)	182	(1,076)	(31)	(376)
39	(489)	(649)	(251)	(418)	(589)	100	(46)	(950)	(321)	188	(1,077)	(37)	(378)
40	(490)	(650)	(246)	(420)	(586)	194	(30)	(946)	(270)	448	(992)	(34)	(335)
41	(490)	(642)	(245)	(420)	(553)	143	(27)	(950)	(278)	475	(1,030)	(34)	(337)
42	(489)	(649)	(265)	(417)	(519)	36	(54)	(912)	(318)	(129)	(1,047)	(56)	(392)
43	(492)	(648)	(257)	(425)	(538)	133	(53)	(930)	(279)	201	(1,026)	(19)	(858)
44	(489)	(642)	(255)	(399)	(585)	116	34	(919)	(238)	(112)	(1,068)	249	(359)
45	(488)	(646)	(259)	(423)	(549)	144	(26)	(930)	(269)	133	(1,041)	92	(355)
46	1,120	148	210	453	(90)	1,150	272	441	532	397	(403)	1,511	479
47	494	227	226	466	(32)	1,373	346	493	604	666	(346)	1,677	516
48	110	502	420	288	57	1,550	1,008	218	410	844	(435)	1,499	539
49	107	486	412	277	52	1,507	986	198	391	823	(453)	1,467	521
50	401	(168)	115	89	464	833	1,111	(239)	1,070	919	(577)	1,020	420
51	155	298	320	232	222	1,327	1,051	131	681	1,021	(428)	1,355	530

Section	Type	Feb-13	Jan-13	Dec-12	Nov-12	Oct-12	Sep-12	Aug-12	Jul-12	Jun-12	May-12	Apr-12	Mar-12
30	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-0.52	-0.14	-0.01	-0.57	0.00
	R	-2.66	-1.01	-2.48	-4.62	5.99	8.49	2.42	-4.83	-0.32	71.67	-7.46	-1.74
31	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-0.52	-0.14	-0.01	-0.57	0.00
	R	-2.69	0.77	-0.71	-4.68	4.76	5.27	1.89	-4.63	-3.03	41.26	-7.69	-1.76
32	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-0.52	-0.14	-0.01	-0.57	0.00
	R	-2.92	-1.39	-2.47	-4.93	-2.23	10.97	-1.93	-4.69	-5.81	17.31	-7.25	-2.54
32*	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-0.52	-0.14	-0.01	-0.57	0.00
	R	-2.92	-1.25	-0.23	-4.91	-2.20	4.59	1.90	-4.40	-5.79	14.40	-7.22	-1.86
33	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-0.52	-0.14	-0.01	-0.57	0.00
	R	-2.94	-1.60	-1.57	-4.97	-2.27	7.56	-0.46	-4.62	-5.87	14.78	-7.33	-2.28
34	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-0.52	-0.14	-0.01	-0.57	0.00
	R	-3.03	-1.71	-1.26	-5.10	-2.06	14.24	0.67	-4.39	-2.27	33.28	-1.27	-2.07
35	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-0.52	-0.14	-0.01	-0.57	0.00
	R	-3.01	-1.09	-1.18	-5.14	-0.28	10.61	0.90	-4.66	-2.83	35.24	-3.98	-2.06
36	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-0.52	-0.14	-0.01	-0.57	0.00
	R	-2.98	-1.63	-2.61	-4.95	2.69	3.02	-1.04	-1.94	-5.64	-7.74	-5.20	4.35
37	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-0.52	-0.14	-0.01	-0.57	0.00
	R	-3.15	-1.54	-2.04	-5.46	1.29	9.85	-0.93	-3.26	-2.87	15.70	-3.68	1.71
38	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-0.52	-0.14	-0.01	-0.57	0.00
	R	-2.98	-1.10	-1.87	-3.65	-2.00	8.66	5.27	-2.47	0.02	-6.53	-6.68	18.05
40	B	-0.26	-0.37	-0.13	-0.20	-0.33	0.00	-0.02	-0.52	-0.14	-0.01	-0.57	0.00
	R	-2.92	-1.41	-2.14	-5.37	0.51	10.65	0.95	-3.24	-2.14	10.86	-4.77	6.91
41	B	0.68	0.13	0.14	0.31	-0.03	0.70	0.19	0.30	0.36	0.30	-0.17	0.91
	R	-2.91	-5.71	-2.57	-4.93	-2.82	-3.35	-3.73	-4.76	-5.98	-7.54	-7.76	-2.53
42	B	0.31	0.15	0.15	0.32	-0.02	0.72	0.20	0.32	0.37	0.30	-0.16	0.93
	R	-2.98	-1.41	-2.14	-5.37	0.51	10.65	0.95	-3.24	-2.14	10.86	-4.77	6.91
43	B	0.09	0.31	0.26	0.21	0.03	0.82	0.58	0.15	0.26	0.41	-0.22	0.82
	R	-2.98	-1.41	-2.14	-5.37	0.51	10.65	0.95	-3.24	-2.14	10.86	-4.77	6.91
44	B	0.09	0.30	0.26	0.21	0.03	0.81	0.58	0.15	0.25	0.40	-0.22	0.81
	R	-3.17	-1.70	-2.20	-5.66	0.64	8.65	0.11	-3.78	-3.00	9.91	-5.60	5.67
45	B	0.26	-0.05	0.09	0.09	0.30	0.52	0.68	-0.10	0.68	0.60	-0.27	0.62
	R	-2.91	-5.71	-2.57	-4.93	-2.82	-3.35	-3.73	-4.76	-5.98	-7.54	-7.76	-2.53
46	B	0.11	0.19	0.21	0.18	0.12	0.72	0.62	0.07	0.40	0.48	-0.23	0.76
	R	-2.24	-1.72	-2.36	-4.74	0.95	6.64	-0.60	0.54	-0.54	15.00	-2.16	4.37




Annex 4.1

Fuses Co-ordinate with 140K Fuse




Annex 4.2

Fuses Co-ordinate with 100K fuse




Annex 4.3

Fuses Co-ordinate with 80K Fuse




Annex 4.4

Fuses Co-ordinate with 65K Fuse




Annex 4.6


Fuses Co-ordinate with 40K Fuse



Annex 4.5




Annex 4.7



Annex 5

Time Vs Current (Lynx Line with an AR and K Type fuses)




Annexure 6 - Temporary Fault percentage of Spur lines

Temporary Fault % of Spurs of Matara Feeder 7		
No	Name of the Section	Temporary fault percentage
1	Halgahapola spur	90
2	ehelakanda spur	76
3	Gammedagama tapping	80
4	Mawarala spur	78
5	Kudapana tapping	76
6	Rathnayaka tapping	80
7	Pallewela spur	90
8	Danhena Tapping	80
9	Padukkahena spur	80
10	Atapattukanda Tapping	90
11	Ranagala Tapping	80
12	Meepawila Tapping	85
13	Rathkekulawala spur	90
14	Kotahore Tapping	90
15	Gatara Tapping	90
16	Polgahamulla Spur	90
17	Maragoda Spur	90
18	Balakawela Water Pump Tapping	96
19	Yahamulla Tapping	60
20	Nemmahena Tapping	70
21	Pettare Tapping	80
22	Polathugoda Tapping	90
23	Udadamana Tapping	96
24	Masmulla Spur	80
25	Malimboda Tapping	90
26	Vitiyala Tapping	94
27	Miriswatta Tapping	100

Temporary Fault % of Spurs of Galle Feeder 8		
No	Name of the Section	Temporary fault percentage
1	Timber Corp Spur	0
2	Ukwatta Tapping	90
3	Welipitimodara Tapping	90
4	Wakwella Spur	95
5	Beraliyadolawatta	90
6	Ananda Mw Spur	0
7	Karapitiya Spur	80

Temporary Fault % of Spurs of Ambalagoda Feeder 3		
No	Name of the Section	Temporary fault percentage
1	Supem Uyana Tapping	100
2	Berathuduwa Spur	94
3	Daluwathumulla Spur	90
4	Manampita Tapping	95
5	Dorala Tapping	100
6	Summercitiy Tapping	96
7	Thanipolgaha Tapping	95
8	Kuleegoda Tapping	0
9	Galagoda Spur	96
10	Keoline Factory Spur	90



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk